

STARITSA, Russian Federation

WMO: 264990

Lat: 56.500N

Lon: 34.933E

Elev: 610

StdP: 14.37

Time Zone: 3.00 (E03)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.1	-8.1	-18.3	2.1	-13.8	-12.2	2.9	-7.6	19.0	28.4	17.7	28.2	2.6	0	0.580

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	83.0	68.1	79.5	66.7	76.2	64.9	69.9	80.6	68.2	77.1	66.4	73.9	6.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	98.9	74.7	64.8	94.0	72.5	63.4	89.4	70.6	34.2	80.3	32.8	77.6	31.4	74.1	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
18.1	15.9	14.0	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-21.7	86.5	7.4	4.5	-27.1	89.8	-31.4	92.4	-35.6	95.0	-41.0	98.3
			-21.9	71.9	7.4	2.4	-27.3	73.6	-31.6	75.0	-35.8	76.3	-41.1	78.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	41.5	17.8	18.7	28.6	41.3	54.5	59.3	65.2	61.8	51.9	41.4	31.7	24.5	(6)
(7)		DBStd	18.57	13.39	13.05	9.33	7.51	7.87	6.08	5.54	6.51	5.75	7.40	8.27	11.01	(7)
(8)		HDD50	4531	1000	877	665	276	43	4	0	2	44	280	548	792	(8)
(9)		HDD65	8715	1465	1297	1130	711	335	189	65	142	394	732	998	1257	(9)
(10)		CDD50	1434	0	0	0	15	183	283	470	369	101	13	0	0	(10)
(11)		CDD65	144	0	0	0	0	10	18	71	44	1	0	0	0	(11)
(12)		CDH74	1228	0	0	0	1	118	161	547	393	8	0	0	0	(12)
(13)		CDH80	286	0	0	0	0	17	23	129	117	0	0	0	0	(13)
(14)	Wind	WSAvg	6.7	7.4	6.9	7.6	7.0	6.7	6.1	5.0	5.5	5.9	6.8	7.5	7.7	(14)
(15)	Precipitation	PrecAvg	26.5	1.5	1.4	1.3	1.3	2.6	3.1	3.5	3.2	2.6	2.6	1.9	1.6	(15)
(16)		PrecMax	35.0	3.4	2.4	2.1	2.6	6.4	5.9	7.7	7.7	6.1	7.9	3.9	3.6	(16)
(17)		PrecMin	17.0	0.5	0.4	0.5	0.2	0.8	0.4	0.3	0.2	1.1	0.7	0.0	0.6	(17)
(18)		PrecStd	4.6	0.7	0.6	0.5	0.7	1.3	1.4	2.0	1.8	1.3	1.5	0.9	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.7	38.8	54.8	69.9	82.6	83.3	88.8	90.4	74.0	64.4	51.7	46.6	(19)
(20)		MCWB	39.2	35.9	43.9	51.8	66.9	67.1	70.6	72.2	64.0	54.2	49.5	45.2	(20)	
(21)		2%	DB	36.9	36.7	47.7	63.8	77.3	78.8	83.4	82.6	68.9	57.4	46.8	42.4	(21)
(22)		MCWB	35.4	34.0	39.2	49.5	62.8	65.4	68.4	68.4	59.4	53.2	44.4	40.5	(22)	
(23)		5%	DB	35.0	35.2	43.5	59.6	72.7	74.8	79.6	77.8	65.4	54.6	44.2	39.2	(23)
(24)		MCWB	33.6	33.0	37.3	47.1	59.6	62.9	67.5	66.8	57.8	51.0	42.0	37.6	(24)	
(25)		10%	DB	33.3	33.9	40.0	55.5	68.9	71.1	76.4	73.7	62.1	52.0	41.8	35.9	(25)
(26)		MCWB	31.9	32.2	35.5	45.3	57.0	60.9	65.6	64.4	55.8	49.0	40.1	34.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.4	36.9	45.0	53.5	69.2	69.8	71.8	72.7	65.8	56.1	50.0	45.0	(27)
(28)		MDCB	40.4	38.2	53.6	61.2	80.9	78.7	83.3	83.6	70.1	59.2	51.0	46.6	(28)	
(29)		2%	WB	35.6	34.7	40.5	50.8	64.1	67.1	70.0	69.9	61.0	54.0	45.1	40.7	(29)
(30)		MDCB	36.7	35.9	45.6	60.8	73.7	75.9	81.1	80.1	66.7	56.9	46.6	42.0	(30)	
(31)		5%	WB	33.8	33.5	37.9	48.7	61.3	64.8	68.5	67.7	58.6	51.4	42.4	37.7	(31)
(32)		MDCB	34.8	34.6	42.3	58.4	69.7	71.5	77.5	76.3	63.8	54.3	43.7	39.0	(32)	
(33)		10%	WB	32.1	32.3	35.9	46.3	59.0	62.6	67.0	65.3	56.5	49.4	40.1	34.6	(33)
(34)		MDCB	33.2	33.8	39.3	53.7	67.2	68.8	74.5	72.1	61.1	51.7	41.6	35.6	(34)	
(35)	Mean Daily Temperature Range	MDBR	9.4	11.7	13.3	17.0	18.4	16.6	17.3	16.4	15.2	10.8	7.1	7.5	(35)	
(36)		5% DB	MCDBR	6.4	7.6	17.8	25.2	24.4	22.2	22.4	23.3	21.5	14.8	10.2	7.1	(36)
(37)		MCWBR	6.5	6.3	11.5	13.0	11.5	10.8	9.6	10.4	12.5	9.9	8.7	6.7	(37)	
(38)		5% WB	MCDBR	6.0	6.7	15.3	21.9	22.0	18.8	19.3	21.2	19.3	12.3	8.8	6.8	(38)
(39)		MCWBR	6.3	6.0	10.5	12.2	11.0	10.8	9.1	10.2	12.1	9.1	8.2	6.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.282	0.318	0.339	0.396	0.386	0.369	0.403	0.409	0.365	0.343	0.316	0.277	(40)	
(41)		taud	2.129	2.090	2.163	2.197	2.329	2.399	2.318	2.291	2.388	2.382	2.246	2.135	(41)	
(42)		Ebn at Noon	187	226	257	259	270	277	263	252	248	222	174	155	(42)	
(43)		Edh at Noon	18	29	35	39	36	35	37	36	28	22	17	14	(43)	
(44)	All-Sky Solar Radiation	RadAvg	165	425	897	1255	1657	1741	1702	1346	866	395	143	90	(44)	
(45)		RadStd	32	62	108	121	141	167	181	141	115	75	25	26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (11 neighbors)	+1.24	N/A	N/A	N/A	N/A	N/A	-275	-401	N/A	N/A

Nomenclature: See separate page