

PALANGA INTL, Lithuania

WMO: 265020

Lat: 55.973N

Lon: 21.094E

Elev: 10

StdP: 101.20

Time Zone: 2.00 (EUE)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.2	-12.1	-18.8	0.7	-13.7	-16.2	0.9	-11.0	9.9	1.6	9.2	1.3	2.8	70	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.4	28.0	20.3	25.9	19.0	23.9	18.3	21.6	25.3	20.3	23.9	19.2	22.5	4.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	14.9	23.0	19.0	13.8	22.0	18.0	12.9	21.0	63.0	25.3	58.3	23.3	54.5	22.4	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 8.8	7.7	7.0	DB	-17.4	31.3	4.1	2.5	-20.3	33.1	-22.7	34.5	-25.0	35.9	-27.9	37.7	(4)
(5)			WB	-17.7	23.8	4.0	1.9	-20.6	25.1	-22.9	26.2	-25.1	27.2	-28.0	28.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	-1.6	-1.5	1.5	6.8	11.4	15.0	17.9	17.8	14.0	9.0	5.1	2.6	(6)
(7)		DBStd	7.83	5.34	4.95	3.82	4.21	4.37	3.50	2.93	2.63	2.92	3.56	3.51	4.08	(7)
(8)		HDD10.0	1538	361	322	263	116	31	2	0	0	6	62	146	229	(8)
(9)		HDD18.3	3762	619	556	522	346	219	113	43	41	132	289	396	487	(9)
(10)		CDD10.0	893	0	0	1	21	76	151	246	242	124	32	1	0	(10)
(11)		CDD18.3	75	0	0	0	1	6	12	31	24	2	0	0	0	(11)
(12)		CDH23.3	514	0	0	0	7	54	100	201	143	9	0	0	0	(12)
(13)		CDH26.7	112	0	0	0	0	7	23	51	31	1	0	0	0	(13)
(14)	Wind	WSAvg	3.4	4.0	3.7	3.5	3.2	3.1	3.0	2.9	3.0	3.3	3.8	3.9	4.0	(14)
(15)	Precipitation	PrecAvg	746	63	44	41	32	40	53	73	87	76	88	77	73	(15)
(16)		PrecMax	1021	142	94	90	75	111	97	213	191	168	180	152	150	(16)
(17)		PrecMin	553	16	9	5	4	10	12	0	2	16	11	12	31	(17)
(18)		PrecStd	112	29	18	21	19	23	22	43	49	35	41	37	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	7.0	14.8	24.0	27.2	29.2	30.9	29.9	24.2	18.8	11.8	9.9	(19)
(20)			MCWB	7.2	5.3	8.8	15.8	18.5	19.6	21.9	21.6	18.3	14.5	9.9	8.7	(20)
(21)		2%	DB	6.8	5.2	10.8	19.9	24.8	26.0	28.1	26.9	21.2	16.1	10.9	8.9	(21)
(22)			MCWB	6.2	4.4	7.3	12.4	17.0	18.5	20.3	20.6	16.6	13.5	9.6	8.1	(22)
(23)		5%	DB	5.9	4.7	7.2	17.0	21.9	23.2	25.8	24.8	19.9	15.0	10.1	8.0	(23)
(24)			MCWB	5.3	4.1	5.3	10.8	15.3	17.2	19.7	19.0	15.8	12.9	9.1	7.4	(24)
(25)		10%	DB	4.9	3.9	5.9	14.0	19.0	21.1	23.2	22.9	18.2	13.9	9.2	7.2	(25)
(26)			MCWB	4.3	3.4	4.6	9.0	13.9	16.3	18.8	18.3	15.3	12.4	8.4	6.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	5.6	9.9	16.2	19.6	21.9	23.4	23.9	19.0	15.2	10.7	8.9	(27)
(28)			MCDWB	7.3	6.0	12.7	23.3	25.1	26.4	28.1	26.1	23.3	17.0	11.2	9.1	(28)
(29)		2%	WB	5.9	4.6	7.3	13.3	17.8	19.8	21.7	21.7	17.6	14.0	10.0	8.0	(29)
(30)			MCDWB	6.2	5.0	9.8	17.9	23.3	24.1	25.6	24.8	20.0	15.7	10.4	8.3	(30)
(31)		5%	WB	5.0	3.9	5.7	11.0	16.0	18.2	20.6	20.1	16.6	13.2	9.4	7.2	(31)
(32)			MCDWB	5.4	4.3	7.0	15.7	20.4	21.8	24.3	23.4	18.7	14.5	9.9	7.7	(32)
(33)		10%	WB	4.1	3.1	4.5	9.5	14.6	17.0	19.5	18.9	15.7	12.6	8.5	6.5	(33)
(34)			MCDWB	4.5	3.6	5.3	13.6	18.4	20.4	22.6	21.6	17.9	13.9	9.2	7.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	4.7	6.1	8.8	9.2	8.0	7.4	7.4	5.9	3.9	3.7	(35)	
(36)			MCDBR	3.0	4.2	8.4	13.3	12.7	12.2	11.2	11.0	9.3	6.9	4.5	2.7	(36)
(37)			MCWBR	3.3	3.6	5.9	7.7	6.8	6.4	5.5	5.8	5.5	4.8	4.0	2.8	(37)
(38)		5% WB	MCDBR	3.1	4.0	7.5	12.6	11.8	10.1	9.3	9.1	7.3	5.8	3.9	2.7	(38)
(39)			MCWBR	3.4	3.6	5.6	7.9	7.0	6.3	5.5	5.9	5.1	4.6	3.9	2.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.305	0.332	0.357	0.394	0.385	0.380	0.412	0.407	0.372	0.353	0.340	0.305	(40)	
(41)		taud	2.232	2.261	2.281	2.252	2.346	2.395	2.327	2.339	2.413	2.397	2.279	2.216	(41)	
(42)		Ebn at Noon	588	722	800	821	856	863	824	802	781	696	539	485	(42)	
(43)		Edh at Noon	56	80	99	118	114	110	116	108	87	70	54	45	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.41	1.06	2.42	4.24	5.63	5.90	5.38	4.38	3.03	1.45	0.51	0.28	(44)	
(45)		RadStd	0.07	0.17	0.24	0.48	0.47	0.32	0.49	0.44	0.33	0.21	0.07	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page