

SIAULIAI INTL, Lithuania

WMO: 265021

Lat: 55.892N

Lon: 23.397E

Elev: 138

StdP: 99.68

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.2	-16.7	-22.6	0.5	-20.1	-19.0	0.7	-16.1	11.6	-0.1	10.7	-0.5	1.9	70	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	28.2	19.5	26.4	18.7	24.9	17.8	21.0	25.7	19.9	24.6	18.8	23.2	3.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.2	23.1	18.1	13.3	21.8	17.1	12.4	20.7	61.5	25.6	57.6	24.7	54.2	23.2	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.6	7.7	-22.7	31.7	4.5	1.5	-26.0	32.8	-28.6	33.7	-31.2	34.5	-34.4	35.6		
(5)			-23.0	23.1	4.4	1.2	-26.1	23.9	-28.7	24.6	-31.2	25.3	-34.4	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.1	-4.4	-4.1	0.2	6.9	12.4	15.6	18.1	17.6	12.9	7.2	3.1	-0.7
	DBStd	8.99	6.33	6.21	4.85	4.02	4.02	3.30	3.03	2.88	3.17	3.70	3.87	4.87
	HDD10.0	1927	445	394	305	111	19	1	0	0	10	101	208	332
	HDD18.3	4169	703	627	563	344	189	94	41	48	164	344	458	591
	CDD10.0	879	0	0	0	17	93	168	253	236	97	15	1	0
	CDD18.3	79	0	0	0	0	4	12	36	26	1	0	0	0
	CDH23.3	713	0	0	0	3	51	139	293	214	12	0	0	0
	CDH26.7	148	0	0	0	0	4	26	71	48	1	0	0	0
(14) Wind	WSAvg	3.7	4.2	3.9	4.0	3.7	3.4	3.4	3.2	3.1	3.3	3.7	4.1	4.5
(15) Precipitation	PrecAvg	595	34	27	33	36	47	64	75	70	55	55	53	43
	PrecMax	795	62	46	78	99	169	146	145	162	126	183	111	70
	PrecMin	398	8	6	4	4	10	6	2	5	8	4	16	12
	PrecStd	96	15	11	18	23	29	30	39	38	23	36	20	15
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	6.9	14.2	23.2	27.1	29.6	31.1	31.0	25.1	18.0	11.6	9.1
		MCWB	7.6	5.1	7.9	12.9	18.5	20.1	20.7	20.8	17.9	13.8	10.0	8.5
	2%	DB	6.0	5.1	11.1	20.0	24.9	26.8	28.7	27.8	22.1	15.5	10.0	7.7
		MCWB	5.2	3.8	6.7	11.2	16.9	18.5	20.1	19.6	16.5	13.0	8.9	7.0
	5%	DB	4.2	3.8	8.5	17.2	22.8	24.9	26.8	25.8	20.1	13.9	8.9	6.0
		MCWB	3.7	3.1	5.6	10.0	15.4	17.2	19.1	18.7	15.4	11.9	8.2	5.4
	10%	DB	3.0	2.7	6.2	14.5	20.2	22.8	24.6	23.8	18.2	12.3	8.0	4.9
		MCWB	2.6	2.2	4.3	8.5	13.9	16.2	18.2	17.5	14.6	10.8	7.4	4.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	5.2	9.0	14.3	19.7	21.1	22.8	22.6	19.1	15.0	10.3	8.5
		MCDB	7.9	6.0	12.8	22.0	25.3	27.3	28.0	27.4	23.0	16.6	11.0	8.9
	2%	WB	5.2	3.8	7.2	12.2	17.9	19.5	21.3	20.8	17.5	13.5	9.1	6.9
		MCDB	5.6	4.6	10.2	18.4	23.2	24.8	25.9	25.3	20.6	15.0	9.6	7.3
	5%	WB	3.7	2.9	5.8	10.7	16.4	18.2	20.2	19.6	16.2	12.3	8.1	5.2
		MCDB	4.1	3.4	7.9	15.5	20.9	23.1	24.7	24.0	19.2	13.7	8.6	5.7
	10%	WB	2.5	2.0	4.4	9.3	14.9	16.9	19.1	18.5	15.2	11.2	7.2	4.2
		MCDB	2.8	2.3	6.0	13.6	18.9	21.5	23.2	22.5	17.7	12.4	7.7	4.6
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	5.5	7.6	10.4	10.8	10.3	9.8	9.9	8.7	6.7	4.0	3.7
		MCDBR	3.9	5.0	10.3	14.7	13.6	13.6	13.1	12.9	11.5	8.1	4.9	3.8
		MCWBR	3.9	3.9	6.7	7.8	6.9	6.5	5.9	6.0	6.5	5.7	4.3	3.7
	5% WB	MCDBR	3.8	4.7	9.4	12.5	11.9	11.6	11.0	11.0	10.0	7.4	4.5	3.7
		MCWBR	3.9	3.9	6.5	7.3	6.8	6.4	5.8	6.0	6.3	5.6	4.2	3.7
(40) Clear-Sky Solar Irradiance	taub		0.290	0.321	0.354	0.393	0.383	0.376	0.409	0.405	0.369	0.346	0.329	0.289
	taud		2.200	2.190	2.230	2.231	2.313	2.360	2.287	2.300	2.382	2.405	2.276	2.204
	Ebn at Noon		607	729	801	822	857	868	826	803	784	706	554	508
	Edh at Noon		57	84	104	120	118	114	120	112	90	69	54	45
(44) All-Sky Solar Radiation	RadAvg		0.52	1.25	2.56	4.06	5.44	5.65	5.29	4.30	2.96	1.45	0.52	0.33
	RadStd		0.11	0.25	0.40	0.53	0.48	0.41	0.47	0.44	0.33	0.24	0.07	0.04

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page