

KLAIPEDA, Lithuania

WMO: 265090

Lat: 55.7314N

Lon: 21.0917E

Elev: 7

StdP: 101.24

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.7	-11.8	-18.7	0.7	-13.1	-16.0	0.9	-11.0	15.7	4.0	14.1	2.0	2.9	70	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	27.4	20.1	25.2	19.1	23.5	18.4	21.4	25.5	20.1	23.9	19.1	22.5	3.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.9	14.6	23.5	18.7	13.5	22.3	17.7	12.7	21.3	62.1	25.5	57.8	23.9	54.3	22.6	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	9.9	8.3	DB	-17.0	30.7	3.6	2.2	-19.6	32.3	-21.7	33.5	-23.7	34.8	-26.4	36.4	(4)
(5)			WB	-17.4	23.0	3.5	1.4	-19.9	24.0	-21.9	24.8	-23.9	25.6	-26.4	26.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	-1.5	-1.2	1.5	6.7	11.4	15.0	18.1	18.2	14.2	8.9	4.3	0.9	(6)	
	DBStd	7.98	5.11	4.71	3.35	4.03	4.19	3.13	2.91	2.54	2.88	3.52	3.95	4.67	(7)	
	HDD10.0	1601	356	315	264	118	29	1	0	0	4	62	170	281	(8)	
	HDD18.3	3813	614	548	523	350	221	108	38	34	126	292	420	539	(9)	
	CDD10.0	907	0	0	1	18	72	152	252	253	130	29	1	0	(10)	
	CDD18.3	77	0	0	0	0	5	9	32	28	2	0	0	0	(11)	
	CDH23.3	427	0	0	0	2	38	67	187	127	6	0	0	0	(12)	
	CDH26.7	86	0	0	0	0	5	14	43	24	1	0	0	0	(13)	
(14) Wind	WSAvg	4.0	4.9	4.6	4.1	3.6	3.4	3.5	3.3	3.3	3.7	4.4	4.7	5.0	(14)	
(15) Precipitation	PrecAvg	720	53	36	38	36	39	57	70	79	85	84	84	69	(15)	
	PrecMax	1022	106	104	79	100	84	115	170	167	167	238	168	134	(16)	
	PrecMin	393	7	3	6	2	2	12	0	6	16	20	17	5	(17)	
	PrecStd	133	27	20	20	22	20	26	39	46	41	52	35	29	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.3	6.4	13.1	22.9	27.3	28.8	30.3	29.2	23.7	17.7	11.2	9.0	(19)	
		MCWB	6.3	4.6	7.7	15.3	18.4	20.9	22.0	21.5	18.2	14.1	9.9	8.0	(20)	
	2%	DB	6.1	5.2	9.3	18.9	23.9	25.1	27.8	26.4	21.2	15.7	10.5	8.0	(21)	
		MCWB	5.3	4.0	6.0	12.2	16.6	18.5	20.6	20.0	16.7	13.2	9.4	7.0	(22)	
	5%	DB	5.1	4.4	6.7	15.8	21.0	22.5	25.3	24.4	19.6	14.5	9.9	7.2	(23)	
		MCWB	4.2	3.5	4.5	10.4	15.5	17.3	19.9	18.9	15.9	12.6	8.8	6.1	(24)	
	10%	DB	4.1	3.8	5.2	13.1	18.4	20.3	23.4	22.8	18.4	13.5	9.2	6.3	(25)	
		MCWB	3.3	3.0	3.6	9.1	13.9	16.3	19.0	18.3	15.3	11.9	8.1	5.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.6	5.1	8.2	15.7	19.2	21.7	23.7	22.9	19.0	14.9	10.5	8.3	(27)	
		MCDB	7.0	5.8	11.9	22.2	25.8	27.4	28.6	27.4	22.1	16.2	11.0	8.8	(28)	
	2%	WB	5.5	4.2	6.1	13.0	17.4	19.6	21.8	21.1	17.6	13.7	9.7	7.1	(29)	
		MCDB	6.1	4.8	8.7	18.4	22.4	23.8	25.8	24.9	20.1	15.1	10.2	7.8	(30)	
	5%	WB	4.3	3.6	4.9	10.9	15.6	18.1	20.5	19.9	16.6	12.9	9.0	6.3	(31)	
		MCDB	4.9	4.3	6.3	14.9	20.0	21.3	24.2	23.1	18.7	14.1	9.7	7.0	(32)	
	10%	WB	3.4	3.1	4.0	9.4	14.2	16.6	19.3	18.9	15.8	12.2	8.3	5.5	(33)	
		MCDB	4.0	3.8	4.9	12.7	18.1	19.7	22.8	21.9	17.8	13.5	9.1	6.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.8	3.8	4.7	6.6	7.3	6.3	6.2	6.6	6.1	4.7	3.4	3.6	(35)	
		MCDBR	2.8	3.0	6.8	11.2	11.0	10.7	10.1	9.7	8.2	5.6	3.4	2.4	(36)	
	5% WB	MCWBR	2.9	2.6	4.5	6.5	5.9	5.8	5.3	5.1	5.0	4.0	3.2	2.5	(37)	
		MCWBR	2.7	2.7	5.8	10.0	10.1	9.0	8.5	8.1	6.5	4.6	3.0	2.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.308	0.334	0.360	0.398	0.388	0.384	0.415	0.410	0.375	0.355	0.342	0.307	(40)	
		taud	2.238	2.260	2.275	2.243	2.345	2.394	2.324	2.335	2.410	2.400	2.282	2.223	(41)	
	Ebn at Noon		592	723	798	819	854	861	822	800	780	697	543	493	(42)	
		Edh at Noon	56	80	100	119	114	110	116	108	88	70	55	46	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.41	1.07	2.43	4.23	5.62	5.86	5.36	4.38	3.05	1.47	0.52	0.29	(44)	
	RadStd		0.07	0.17	0.23	0.48	0.47	0.34	0.50	0.45	0.33	0.21	0.07	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+65	N/A
(47) Regional (16 neighbors)		+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+52	N/A

Nomenclature: See separate page