

LAUKUVA, Lithuania

WMO: 265180

Lat: 55.6089N

Lon: 22.2394E

Elev: 544

StdP: 14.41

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.8	5.2	-5.6	4.2	0.2	-0.2	5.5	6.5	29.6	34.3	26.9	33.2	5.9	110	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.7	80.9	68.2	77.5	66.1	74.6	64.3	69.7	78.2	67.5	75.4	65.6	72.9	7.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	100.1	74.6	64.5	92.8	71.9	62.6	86.6	69.6	34.0	78.1	32.3	75.6	30.7	72.9	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.8	20.0	16.6	DB	-4.8	84.8	7.0	3.1	-9.8	87.0	-13.9	88.8	-17.9	90.5	-23.0	92.8	
			WB	-5.3	72.9	6.8	2.3	-10.2	74.5	-14.2	75.8	-18.0	77.1	-23.0	78.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	24.7	26.2	32.2	43.6	52.2	58.3	63.1	61.9	53.8	44.2	35.9	29.2
	DBStd	15.39	10.28	9.76	7.58	7.81	7.41	5.95	5.61	5.15	5.57	6.64	7.50	9.07
	HDD50	3582	784	667	551	224	59	4	0	0	26	200	422	645
	HDD65	7808	1249	1087	1015	643	401	216	107	126	336	646	872	1110
	CDD50	1347	0	0	0	31	128	253	406	368	141	20	0	0
	CDD65	97	0	0	0	0	5	14	48	29	1	0	0	0
	CDH74	767	0	0	0	4	44	129	378	205	7	0	0	0
	CDH80	123	0	0	0	0	1	18	73	31	0	0	0	0
	WSAvg	7.9	9.2	9.1	8.4	7.9	7.4	6.9	6.5	6.3	7.1	8.3	9.0	8.9
Precipitation	PrecAvg	31.5	2.7	2.0	1.9	1.4	2.0	2.8	3.2	3.5	2.8	3.3	3.0	2.8
	PrecMax	40.4	6.5	5.2	4.1	3.0	4.4	4.8	7.5	6.5	5.8	6.9	5.1	6.5
	PrecMin	20.4	0.8	0.3	0.3	0.1	0.4	0.7	0.0	0.7	0.3	0.6	1.4	1.4
	PrecStd	5.1	1.3	1.0	1.0	0.7	0.9	1.0	1.5	1.7	1.5	1.5	1.3	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.6	43.3	56.5	73.6	78.6	82.7	85.6	84.1	74.3	62.3	51.3	46.7
		MCWB	43.1	40.4	48.5	58.2	65.5	68.8	70.2	70.0	63.8	56.3	49.3	45.5
	2%	DB	41.1	40.8	49.9	66.9	74.3	77.7	81.9	79.0	69.6	58.2	48.8	44.3
		MCWB	40.0	39.1	43.5	54.3	62.3	66.1	68.7	66.6	60.9	54.5	47.2	43.1
	5%	DB	38.6	38.8	44.9	62.0	70.4	73.9	78.3	75.8	65.6	55.7	46.9	41.8
		MCWB	37.5	37.6	41.1	51.3	59.7	63.5	67.3	65.2	59.1	53.1	45.6	40.8
	10%	DB	36.4	37.0	41.4	57.1	66.1	70.2	74.7	72.5	62.8	53.6	45.2	39.9
		MCWB	35.4	36.0	38.6	48.7	57.3	61.4	65.5	63.7	57.7	51.5	44.1	38.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.4	41.2	49.4	59.5	67.8	70.5	73.5	72.0	65.1	57.6	49.8	45.7
		MCDB	44.3	42.1	55.4	70.9	74.9	79.5	81.9	79.7	71.7	59.9	50.9	46.3
	2%	WB	40.1	39.3	44.7	55.5	63.7	67.5	70.3	68.6	62.1	55.3	47.4	43.2
		MCDB	40.9	40.4	48.2	65.2	72.6	76.1	78.9	76.6	67.2	57.4	48.4	43.9
	5%	WB	37.7	37.8	41.4	52.5	60.9	64.7	68.1	66.6	60.1	53.4	45.8	40.9
		MCDB	38.5	38.7	44.2	60.3	68.5	71.8	75.8	73.7	64.6	55.3	46.8	41.6
	10%	WB	35.5	36.1	39.0	49.4	57.9	62.4	66.0	64.6	58.2	51.6	44.2	38.9
		MCDB	36.3	36.9	41.4	55.6	64.7	68.7	73.8	70.8	62.0	53.6	45.2	39.8
Mean Daily Temperature Range	5% DB	MDBR	7.3	8.0	10.7	15.7	17.8	16.1	15.7	15.5	13.5	9.9	6.3	6.2
		MCDBR	7.2	7.2	15.9	23.4	22.6	22.0	21.5	21.1	17.9	12.3	7.5	6.2
		MCWBR	6.8	6.3	11.3	13.0	12.7	12.1	10.8	10.8	11.0	9.1	6.9	6.1
	5% WB	MCDBR	6.5	7.1	14.3	21.4	20.4	19.7	19.5	18.5	15.7	10.9	7.2	6.1
		MCWBR	6.3	6.5	10.8	12.6	12.4	11.9	11.0	10.7	10.5	8.6	6.8	6.2
Clear-Sky Solar Irradiance	taub		0.293	0.323	0.355	0.394	0.383	0.378	0.411	0.405	0.369	0.348	0.331	0.293
	taud		2.208	2.212	2.244	2.227	2.314	2.359	2.288	2.301	2.382	2.403	2.282	2.208
	Ebn at Noon		193	233	255	261	272	275	262	255	249	225	178	163
	Edh at Noon		18	27	33	38	37	36	38	36	29	22	17	15
All-Sky Solar Radiation	RadAvg		160	390	808	1310	1749	1817	1689	1380	956	466	170	104
	RadStd		34	74	114	164	151	128	156	142	107	77	22	12

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+1.01	N/A	N/A	N/A	N/A	N/A	-351	-439	N/A	N/A
Regional (20 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page