

VERHNEDVINSK, Belarus

WMO: 265540

Lat: 55.8208N

Lon: 27.9400E

Elev: 132

StdP: 99.75

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.6	-18.2	-24.1	0.4	-21.5	-20.7	0.6	-17.6	8.9	-0.2	7.9	-1.6	1.6	100	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	27.9	19.7	26.2	18.8	24.5	18.0	21.0	26.2	19.9	24.6	18.9	22.9	2.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.2	23.6	18.2	13.3	22.3	17.3	12.5	21.4	61.4	26.4	57.5	24.6	54.2	23.0	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.4	5.7	DB	-26.7	30.4	2.8	1.7	-28.7	31.6	-30.4	32.6	-31.9	33.6	-34.0	34.9	(4)
(5)			WB	-26.9	22.5	2.8	1.1	-28.9	23.3	-30.5	24.0	-32.1	24.6	-34.1	25.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.4	-5.1	-4.9	-0.3	6.8	12.0	15.8	18.3	16.9	11.9	6.2	1.2	-2.8	(6)
(7)		DBStd	9.42	6.35	6.48	4.52	4.37	4.14	3.23	2.98	3.00	3.31	3.91	4.70	5.76	(7)
(8)		HDD10.0	2156	469	417	319	114	26	1	0	0	19	129	264	398	(8)
(9)		HDD18.3	4434	728	650	577	345	201	89	38	66	194	377	514	656	(9)
(10)		CDD10.0	839	0	0	0	19	87	176	257	213	76	11	0	0	(10)
(11)		CDD18.3	74	0	0	0	0	4	13	37	19	0	0	0	0	(11)
(12)		CDH23.3	606	0	0	0	1	36	99	298	162	9	0	0	0	(12)
(13)		CDH26.7	113	0	0	0	0	3	10	69	31	0	0	0	0	(13)
(14)	Wind	WSAvg	2.8	3.1	2.9	3.0	2.8	2.7	2.6	2.3	2.3	2.5	2.8	3.0	3.1	(14)
(15)	Precipitation	PrecAvg	614	34	29	33	35	59	69	80	69	56	53	53	42	(15)
(16)		PrecMax	840	72	70	60	102	131	141	194	149	149	105	123	78	(16)
(17)		PrecMin	447	9	6	5	2	9	23	10	5	16	7	18	7	(17)
(18)		PrecStd	93	16	13	14	25	29	33	45	36	30	28	23	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.1	6.3	13.3	23.0	27.0	28.2	31.2	30.1	24.7	18.2	11.6	8.5	(19)
(20)			MCWB	5.1	4.6	7.4	13.7	19.0	19.6	20.7	22.3	16.3	14.1	10.2	7.4	(20)
(21)		2%	DB	4.1	4.4	9.8	20.0	23.9	26.2	28.7	27.0	21.4	14.9	9.6	6.4	(21)
(22)			MCWB	3.2	3.0	5.4	11.8	16.7	18.7	20.6	19.2	15.6	12.4	8.5	5.6	(22)
(23)		5%	DB	2.9	3.2	7.4	17.1	21.9	24.4	26.6	25.0	19.3	13.2	8.1	4.9	(23)
(24)			MCWB	2.0	2.2	4.4	10.2	14.9	17.7	19.3	18.3	14.5	11.2	7.1	4.2	(24)
(25)		10%	DB	1.7	2.2	5.5	14.6	19.8	22.2	24.7	23.1	17.5	11.7	6.9	3.5	(25)
(26)			MCWB	1.0	1.3	3.2	9.0	13.7	16.7	18.6	17.6	13.7	10.2	6.0	2.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.4	4.7	8.0	14.4	19.9	21.2	22.6	22.6	17.6	14.5	10.4	7.7	(27)
(28)			MCDWB	5.9	5.9	12.2	21.3	25.3	26.1	28.4	28.6	21.7	17.1	11.1	8.4	(28)
(29)		2%	WB	3.4	3.3	6.2	12.5	17.9	19.8	21.3	20.7	16.2	12.7	8.7	5.7	(29)
(30)			MCDWB	4.0	4.0	8.7	18.1	22.8	24.6	27.0	25.1	19.7	14.4	9.4	6.2	(30)
(31)		5%	WB	2.2	2.4	4.7	11.2	16.0	18.7	20.2	19.4	15.3	11.5	7.2	4.3	(31)
(32)			MCDWB	2.7	3.1	6.8	15.9	20.5	22.8	25.2	23.0	18.2	12.8	7.9	4.9	(32)
(33)		10%	WB	1.1	1.5	3.5	9.7	14.4	17.4	19.2	18.1	14.2	10.4	6.1	2.8	(33)
(34)			MCDWB	1.7	2.1	5.2	13.8	18.8	21.0	23.4	21.8	16.8	11.6	6.8	3.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.4	6.6	9.0	9.6	8.7	9.2	9.4	8.5	5.7	3.7	3.7	(35)
(36)			MCDBR	3.5	4.0	9.0	13.6	12.8	12.0	12.4	12.8	11.6	7.9	4.9	3.6	(36)
(37)			MCWBR	3.3	3.3	5.7	6.8	6.2	5.7	5.3	5.7	6.3	5.4	4.2	3.4	(37)
(38)		5% WB	MCDWR	3.4	3.6	7.8	11.4	11.3	10.1	10.9	10.6	9.7	6.9	4.4	3.5	(38)
(39)			MCWBR	3.3	3.2	5.5	6.3	6.2	5.5	5.1	5.4	5.8	5.0	4.1	3.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.287	0.320	0.351	0.395	0.386	0.377	0.406	0.408	0.371	0.348	0.328	0.287	(40)	
(41)		taud	2.162	2.136	2.174	2.233	2.331	2.382	2.318	2.304	2.382	2.398	2.256	2.183	(41)	
(42)		Ebn at Noon	606	726	801	821	855	867	830	801	782	704	554	510	(42)	
(43)		Edh at Noon	59	89	110	120	116	112	117	112	90	70	55	46	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.54	1.37	2.75	3.98	5.23	5.55	5.22	4.28	2.83	1.33	0.44	0.32	(44)	
(45)		RadStd	0.13	0.26	0.43	0.48	0.53	0.45	0.53	0.39	0.25	0.26	0.08	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page