

LEPIEL, Belarus

WMO: 266590

Lat: 54.8801N

Lon: 28.6927E

Elev: 572

StdP: 14.39

Time Zone: 3.00 (E03)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.7	-0.6	-11.0	3.1	-6.2	-5.3	4.2	0.2	15.8	29.1	14.3	30.1	2.3	0	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	83.6	67.6	80.3	66.0	77.1	64.5	69.9	80.0	68.0	77.3	66.2	74.3	5.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	99.0	74.7	64.6	93.1	71.9	63.0	88.0	70.4	34.1	80.2	32.6	77.5	31.2	74.3	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	12.1	10.7	DB	-13.1	88.4	4.7	3.1	-16.4	90.6	-19.2	92.4	-21.8	94.1	-25.2	96.3	(4)
(5)			WB	-13.4	72.3	4.6	1.9	-16.7	73.7	-19.4	74.8	-22.0	75.9	-25.4	77.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.7	23.0	22.4	30.9	45.1	54.6	61.4	66.0	63.5	53.8	43.3	34.1	25.4	(6)
(7)		DBStd	17.57	10.76	11.50	8.27	8.16	7.70	6.10	5.63	5.72	6.12	7.05	8.58	10.54	(7)
(8)		HDD50	3933	836	774	591	189	40	1	0	0	32	228	478	764	(8)
(9)		HDD65	7943	1301	1194	1056	596	333	142	56	97	338	673	928	1229	(9)
(10)		CDD50	1649	0	0	0	44	183	343	495	418	146	20	0	0	(10)
(11)		CDD65	183	0	0	0	0	11	34	86	51	1	0	0	0	(11)
(12)		CDH74	1413	0	0	0	7	102	236	656	392	20	0	0	0	(12)
(13)		CDH80	312	0	0	0	1	15	28	167	100	1	0	0	0	(13)
(14)	Wind	WSAvg	5.0	5.5	5.3	5.5	4.9	4.9	4.7	4.1	4.1	4.4	5.2	5.6	5.7	(14)
(15)	Precipitation	PrecAvg	26.5	1.7	1.4	1.6	1.5	2.3	3.2	3.5	2.6	2.4	2.0	2.2	2.0	(15)
(16)		PrecMax	35.6	3.0	2.8	3.5	3.1	9.0	5.9	6.5	6.1	5.6	3.8	4.2	3.1	(16)
(17)		PrecMin	18.4	0.6	0.3	0.2	0.2	0.6	0.9	1.2	0.3	0.8	0.2	0.6	0.6	(17)
(18)		PrecStd	3.8	0.8	0.6	0.7	0.7	1.7	1.3	1.6	1.5	1.3	1.0	0.9	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.5	44.9	55.8	73.9	82.2	83.5	89.0	89.3	76.7	65.7	52.9	46.8	(19)
(20)			MCWB	42.5	40.9	45.3	56.1	65.3	67.0	70.3	70.8	62.2	56.7	50.2	45.4	(20)
(21)		2%	DB	39.3	40.7	50.1	68.3	76.5	80.3	85.0	82.0	71.4	59.2	49.4	43.0	(21)
(22)			MCWB	37.8	38.1	42.7	53.0	62.7	65.6	69.1	66.8	60.3	54.3	47.4	41.9	(22)
(23)		5%	DB	36.7	37.9	45.4	63.2	72.5	76.9	81.0	78.0	67.4	56.0	46.6	39.8	(23)
(24)			MCWB	35.3	36.2	40.3	50.9	58.9	64.0	67.0	64.9	58.1	52.3	44.9	38.6	(24)
(25)		10%	DB	34.7	35.7	41.7	59.0	68.4	73.3	77.4	74.5	64.0	53.3	44.5	37.2	(25)
(26)			MCWB	33.5	34.2	37.8	48.9	57.0	62.4	65.7	63.6	56.6	50.4	43.1	36.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.8	42.0	46.3	58.1	68.1	69.9	73.4	71.9	64.1	58.2	50.4	45.4	(27)
(28)			MCD B	44.4	44.6	53.7	69.9	78.6	78.5	85.8	85.8	73.4	62.9	51.9	46.5	(28)
(29)		2%	WB	38.0	38.7	43.6	54.6	64.1	67.8	70.6	69.2	61.4	55.2	47.9	42.1	(29)
(30)			MCD B	39.1	40.2	48.9	64.3	73.8	76.9	80.6	79.8	68.0	58.5	49.2	42.8	(30)
(31)		5%	WB	35.5	36.4	40.9	52.5	61.2	65.7	68.4	67.1	59.5	52.9	45.1	38.7	(31)
(32)			MCD B	36.5	37.7	44.6	60.7	69.9	74.0	78.2	74.5	65.2	55.4	46.2	39.6	(32)
(33)		10%	WB	33.8	34.3	38.4	50.3	58.4	63.8	66.7	65.0	57.7	50.8	43.2	36.0	(33)
(34)			MCD B	34.6	35.4	41.2	58.0	66.1	70.4	75.5	71.5	62.7	53.3	44.3	36.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.6	10.2	12.1	15.9	16.8	15.6	16.1	16.1	15.0	10.7	7.0	7.0	(35)
(36)			MCD BR	6.8	8.4	16.4	22.9	23.3	20.9	21.4	22.2	21.2	14.9	8.9	6.3	(36)
(37)			MCWBR	6.4	6.9	10.6	11.0	10.5	9.2	8.5	8.9	11.2	9.9	7.7	5.7	(37)
(38)		5% WB	MCD BR	6.2	7.9	14.3	19.2	20.2	17.8	19.3	18.7	17.4	13.0	7.9	6.3	(38)
(39)			MCWBR	6.2	7.0	9.8	10.0	10.5	9.0	8.2	8.5	10.1	9.6	7.3	5.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.287	0.321	0.351	0.402	0.393	0.379	0.407	0.411	0.372	0.349	0.329	0.289	(40)	
(41)		taud	2.158	2.117	2.164	2.209	2.315	2.377	2.312	2.296	2.374	2.403	2.265	2.185	(41)	
(42)		Ebn at Noon	200	233	256	259	270	275	264	254	250	227	183	171	(42)	
(43)		Edh at Noon	20	30	36	40	38	36	37	36	29	23	18	16	(43)	
(44)	All-Sky Solar Radiation	RadAvg	192	465	889	1263	1629	1769	1672	1387	922	445	154	111	(44)	
(45)		RadStd	46	89	142	154	172	151	167	133	69	89	28	31	45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	+0.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+167	N/A	N/A

Nomenclature: See separate page