

KYBARTAI, Lithuania

WMO: 267130

Lat: 54.650N

Lon: 22.800E

Elev: 195

StdP: 14.59

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.3	4.9	-6.6	3.9	-2.3	0.5	5.7	5.5	25.6	36.1	23.0	34.2	4.6	90	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	84.3	68.9	80.8	66.4	77.7	65.1	70.7	81.1	68.6	78.0	66.7	75.3	7.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.2	100.7	76.1	65.0	93.3	73.1	63.2	87.5	71.0	34.6	81.4	32.8	78.0	31.3	76.0	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 22.4	(b) 19.0	(c) 16.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 22.4	(b) 19.0	(c) 16.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.9	27.5	30.8	33.9	46.3	54.3	60.2	65.0	63.9	54.8	47.4	36.3	29.1
	DBStd	15.50	8.94	10.43	7.40	8.63	7.38	5.65	5.73	5.43	6.25	7.17	8.87	10.69
	HDD50	3168	697	537	501	171	39	1	0	0	27	133	415	647
	HDD65	7138	1162	957	964	562	338	165	72	89	309	546	862	1112
	CDD50	1665	0	0	2	61	173	308	466	430	170	52	3	0
	CDD65	159	0	0	0	1	7	23	73	53	2	0	0	0
	CDH74	1620	0	0	0	26	90	228	730	528	18	0	0	0
	CDH80	371	0	0	0	0	6	49	198	118	0	0	0	0
Wind	WSAvg	7.5	8.6	10.1	8.5	7.1	6.7	6.7	6.1	5.8	6.4	8.2	8.2	8.3
Precipitation	PrecAvg	24.2	1.7	1.5	1.4	1.4	1.9	2.7	3.3	2.8	2.1	2.0	1.8	1.7
	PrecMax	29.3	3.2	2.5	3.1	2.7	3.1	4.3	7.3	6.3	5.3	5.7	2.9	3.0
	PrecMin	18.4	0.6	0.4	0.3	0.2	0.7	0.6	0.4	0.2	0.9	0.1	0.7	0.6
	PrecStd	3.1	0.7	0.6	0.7	0.7	0.6	1.0	1.7	1.6	1.1	1.1	0.7	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.7	48.4	61.1	77.6	80.4	85.4	89.4	87.6	76.4	67.9	55.7	48.4
		MCWB	43.3	44.9	49.2	59.9	64.1	70.5	71.2	70.0	62.6	59.7	53.3	46.6
	2%	DB	41.5	46.3	52.5	71.9	76.4	80.8	85.3	83.1	71.0	63.3	53.1	45.7
		MCWB	39.9	43.0	46.9	57.1	62.3	68.5	69.9	67.0	60.6	57.2	50.2	43.7
	5%	DB	39.2	44.4	47.4	65.8	73.1	76.0	81.4	79.8	67.3	60.2	50.2	43.5
		MCWB	37.8	42.2	42.8	54.6	60.9	64.4	68.0	65.3	59.7	55.5	47.8	42.0
	10%	DB	37.3	42.2	43.6	60.8	69.1	72.8	77.9	76.4	64.6	57.3	47.6	41.3
		MCWB	36.1	40.3	40.8	53.1	58.8	63.5	66.5	64.1	58.5	53.7	45.8	40.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.7	45.9	50.0	61.9	67.2	73.5	74.4	71.9	64.9	61.1	53.7	47.1
		MCDB	44.9	47.7	56.4	73.9	77.5	83.8	85.0	83.6	71.7	65.6	55.5	48.2
	2%	WB	40.4	43.9	47.1	59.0	63.8	69.1	71.2	69.3	62.5	58.2	50.6	44.1
		MCDB	41.7	45.4	52.8	68.3	73.5	78.2	81.4	79.5	67.3	62.3	53.0	45.2
	5%	WB	38.0	42.1	43.6	55.8	61.6	66.5	69.3	67.3	60.8	56.0	48.1	42.1
		MCDB	39.0	43.8	46.6	64.5	71.0	74.0	79.2	76.2	66.3	59.3	50.1	43.4
	10%	WB	36.3	40.5	40.9	53.2	59.5	64.2	67.2	65.5	59.2	54.0	45.8	40.0
		MCDB	37.3	42.2	43.4	60.7	67.9	71.1	76.2	73.9	63.5	57.0	47.5	41.3
Mean Daily Temperature Range	5% DB	MDBR	7.6	9.2	11.6	16.1	20.0	17.2	18.9	19.2	14.8	11.5	8.1	7.4
		MCDBR	7.8	9.0	16.3	24.5	24.9	24.1	24.8	25.2	17.6	15.5	9.0	7.3
		MCWBR	6.9	7.2	11.2	12.4	13.5	13.0	11.9	11.2	9.9	10.0	7.6	6.7
	5% WB	MCDBR	7.8	8.4	14.8	22.1	22.7	21.6	22.2	20.7	15.7	13.9	9.0	7.4
		MCWBR	7.1	7.5	11.3	12.7	12.8	12.6	11.8	10.3	9.8	9.9	7.7	6.9
Clear-Sky Solar Irradiance	taub		0.300	0.331	0.368	0.409	0.397	0.391	0.427	0.421	0.382	0.358	0.340	0.300
	taud		2.206	2.194	2.216	2.189	2.280	2.324	2.247	2.262	2.345	2.392	2.285	2.238
	Ebn at Noon		198	233	252	257	269	272	258	251	246	225	181	172
	Edh at Noon		19	28	34	40	39	38	40	37	30	23	18	16
All-Sky Solar Radiation	RadAvg		185	420	817	1296	1696	1762	1635	1372	964	478	178	119
	RadStd		35	75	120	170	169	142	165	135	113	88	20	16

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (17 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+115	N/A	

Nomenclature: See separate page