

VILNIUS, Lithuania

WMO: 267300

Lat: 54.6261N

Lon: 25.1069E

Elev: 512

StdP: 14.43

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.8	3.1	-7.9	3.7	-1.5	-2.2	5.0	4.5	23.9	28.4	22.1	27.9	4.8	0	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	83.9	67.1	80.5	65.5	77.2	63.9	69.7	79.3	67.7	76.3	66.0	73.8	8.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	99.1	73.2	64.6	93.0	71.1	62.9	87.3	69.4	34.0	79.7	32.4	76.2	31.1	73.5	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.3	18.1	16.3	DB	-9.2	89.0	6.4	2.9	-13.9	91.1	-17.6	92.8	-21.2	94.4	-25.9	96.5	(4)
(5)			WB	-9.6	73.2	6.3	1.9	-14.2	74.6	-17.9	75.7	-21.4	76.8	-26.0	78.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.7	24.1	25.8	32.9	45.5	54.8	60.9	65.3	63.6	54.7	44.2	35.4	27.8	(6)	
	DBStd	16.55	10.51	10.03	8.02	8.22	7.67	6.30	5.78	5.71	6.28	7.08	7.86	9.75	(7)	
	HDD50	3590	803	678	531	182	38	2	0	0	26	205	437	688	(8)	
	HDD65	7591	1268	1098	995	586	327	155	69	96	313	644	887	1153	(9)	
	CDD50	1650	0	0	1	46	187	329	473	421	167	26	0	0	(10)	
	CDD65	177	0	0	0	1	11	32	77	52	4	0	0	0	(11)	
	CDH74	1495	0	0	0	11	102	294	614	437	37	0	0	0	(12)	
	CDH80	326	0	0	0	1	10	56	156	100	3	0	0	0	(13)	
(14) Wind	WSAvg	8.1	9.3	9.1	8.7	8.0	7.4	7.2	6.8	6.7	7.2	8.6	9.2	9.4	(14)	
(15) Precipitation	PrecAvg	27.2	1.9	1.7	1.7	1.7	2.4	2.6	3.7	3.0	2.4	2.3	1.9	2.0	(15)	
	PrecMax	37.7	4.1	3.1	3.6	3.1	5.4	5.7	8.1	7.8	5.8	5.9	3.9	3.0	(16)	
	PrecMin	19.8	0.4	0.7	0.6	0.3	1.1	0.7	0.5	0.7	0.5	0.3	0.4	0.8	(17)	
	PrecStd	3.7	0.7	0.5	0.7	0.7	1.0	1.2	2.2	1.7	1.2	1.2	0.8	0.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.8	44.9	58.7	75.2	80.9	85.8	88.6	87.8	78.8	66.1	53.5	46.7	(19)	
		MCWB	44.0	41.9	46.4	57.6	64.6	67.7	68.5	69.0	63.1	57.2	50.2	45.6	(20)	
	2%	DB	40.7	41.4	53.0	69.7	76.9	80.8	84.3	82.4	73.2	60.8	50.1	44.2	(21)	
		MCWB	39.9	39.3	43.9	54.4	62.0	65.2	67.7	65.9	61.7	55.5	48.1	42.9	(22)	
	5%	DB	37.8	39.2	48.0	64.5	73.3	77.2	80.6	78.8	68.4	57.1	47.8	41.1	(23)	
		MCWB	37.0	37.7	42.6	51.6	59.6	63.3	66.5	64.9	59.3	53.3	46.5	40.4	(24)	
	10%	DB	35.7	37.2	44.0	60.4	69.5	73.5	77.0	75.2	65.0	54.0	45.0	38.9	(25)	
		MCWB	35.2	36.1	39.9	49.2	57.5	61.4	65.2	63.4	57.6	51.3	44.2	38.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.1	42.9	49.2	59.4	66.8	69.9	73.0	71.7	66.2	59.2	51.3	46.3	(27)	
		MCDB	44.7	44.4	55.1	73.3	76.8	80.7	83.0	82.1	74.9	63.5	52.7	46.6	(28)	
	2%	WB	39.6	39.7	45.5	55.6	63.8	67.3	70.4	68.8	62.9	56.4	48.5	42.8	(29)	
		MCDB	40.0	40.8	50.3	65.9	73.5	77.5	79.6	78.6	69.6	59.6	49.6	43.2	(30)	
	5%	WB	37.2	37.7	42.7	53.0	61.4	65.1	68.3	66.9	60.8	54.0	46.3	40.3	(31)	
		MCDB	37.6	38.5	46.7	62.0	70.1	73.7	76.3	75.1	66.5	56.5	47.3	40.9	(32)	
	10%	WB	35.1	35.8	40.1	50.5	59.0	63.1	66.6	65.0	58.9	51.9	44.4	37.7	(33)	
		MCDB	35.6	36.9	43.1	57.7	66.8	71.1	73.9	72.3	64.3	54.2	45.1	38.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	9.5	12.9	17.9	19.1	18.2	17.6	18.1	15.8	11.8	7.5	7.4	(35)	
		MCDBR	7.3	9.2	19.0	24.8	23.9	23.3	22.6	23.2	20.8	15.9	9.9	7.6	(36)	
	5% WB	MCWBR	7.2	7.9	12.5	13.1	12.0	11.1	10.1	10.4	11.4	10.7	8.4	7.5	(37)	
		MCWBR	7.1	8.4	16.0	22.0	21.1	20.0	19.0	19.7	18.4	13.8	8.7	7.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.293	0.326	0.362	0.408	0.395	0.385	0.421	0.415	0.379	0.355	0.334	0.295	(40)	
		taud	2.186	2.153	2.193	2.190	2.300	2.355	2.272	2.283	2.356	2.398	2.281	2.218	(41)	
	Ebn at Noon		200	233	254	258	269	273	260	253	248	226	184	173	(42)	
		Edh at Noon	20	29	35	40	38	36	39	36	30	23	18	16	(43)	
(44) All-Sky Solar Radiation	RadAvg		188	425	830	1280	1648	1726	1610	1377	942	462	162	114	(44)	
	RadStd		36	80	134	162	165	152	165	128	97	96	22	21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.79	N/A	N/A	N/A	+0.68	N/A	-227	-313	N/A	N/A
(47) Regional (14 neighbors)		N/A	N/A	N/A	N/A	N/A	+1.10	N/A	N/A	N/A	N/A

Nomenclature: See separate page