

LIDA, Belarus

WMO: 268320

Lat: 53.9022N

Lon: 25.3233E

Elev: 514

StdP: 14.43

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.1	3.7	-7.3	3.8	-1.2	-1.7	5.1	4.3	18.0	37.8	15.9	35.9	3.3	40	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	83.9	67.7	80.7	65.7	77.5	64.2	69.7	79.4	68.0	77.4	66.3	74.4	6.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	99.3	74.5	64.7	93.3	72.3	63.1	88.0	70.4	34.0	79.6	32.6	77.5	31.2	74.5	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.6	13.0	11.6	DB	-9.5	88.5	5.5	3.1	-13.5	90.7	-16.7	92.5	-19.8	94.3	-23.8	96.6	(4)
			WB	-9.9	73.1	5.5	2.5	-13.9	74.9	-17.1	76.3	-20.2	77.7	-24.2	79.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	45.4	24.9	26.8	34.3	46.6	55.7	61.4	66.0	64.1	54.9	44.8	36.2	28.4	(6)
		DBStd	16.42	10.60	10.05	8.05	7.95	7.50	5.98	5.66	5.47	6.03	7.13	8.12	9.90	(7)
		HDD50	3402	778	650	489	156	28	1	0	0	24	192	416	668	(8)
		HDD65	7331	1243	1070	953	552	302	142	56	82	306	627	865	1133	(9)
		CDD50	1737	0	0	1	55	204	342	497	437	170	30	1	0	(10)
		CDD65	190	0	0	0	1	13	33	88	53	2	0	0	0	(11)
		CDH74	1543	0	0	0	13	127	276	690	409	28	0	0	0	(12)
		CDH80	337	0	0	0	1	19	45	182	89	1	0	0	0	(13)
(14)	Wind	WSAvg	5.5	6.2	6.1	6.1	5.5	5.4	4.7	4.7	4.9	5.7	5.8	6.1		(14)
(15)	Precipitation	PrecAvg	27.0	1.9	1.7	1.6	1.6	2.7	2.8	3.6	2.8	2.4	2.2	1.9	2.0	(15)
(16)		PrecMax	33.3	3.9	3.4	3.4	3.1	5.0	5.6	8.1	8.7	7.3	6.3	3.3	3.7	(16)
(17)		PrecMin	20.9	0.3	0.7	0.6	0.4	0.9	1.1	0.1	0.6	0.9	0.2	0.5	0.9	(17)
(18)		PrecStd	3.3	0.8	0.6	0.7	0.7	1.1	1.1	2.2	1.8	1.5	1.4	0.7	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	45.4	47.0	58.7	75.8	82.6	84.6	89.2	87.5	78.0	66.3	55.1	47.3		(19)
(20)		0.4% MCWB	43.2	42.5	47.5	57.9	65.1	67.6	69.1	70.1	62.5	58.6	50.6	44.9		(20)
(21)		2% DB	41.3	43.1	53.6	69.8	77.3	81.0	85.0	81.9	72.3	61.1	51.4	44.1		(21)
(22)		2% MCWB	39.3	40.2	45.0	54.4	62.2	66.0	68.3	66.4	60.7	55.7	48.8	42.4		(22)
(23)		5% DB	38.9	40.5	49.2	64.8	73.6	77.3	81.4	78.3	68.3	57.9	48.5	41.8		(23)
(24)		5% MCWB	37.3	38.3	42.9	52.2	59.5	63.9	66.6	64.6	58.9	53.9	46.3	40.3		(24)
(25)		10% DB	36.8	38.2	45.1	60.5	69.5	73.5	77.7	75.1	65.1	55.0	46.3	39.2		(25)
(26)		10% MCWB	35.5	36.4	40.6	49.8	57.6	62.0	65.3	63.5	57.5	51.9	44.6	37.8		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	43.4	43.7	49.5	59.3	67.2	70.0	73.4	72.0	64.3	59.6	52.0	45.6		(27)
(28)		0.4% MCDB	45.1	46.3	55.4	72.8	78.5	79.8	84.1	83.3	73.2	64.0	54.0	46.6		(28)
(29)		2% WB	39.9	40.7	46.1	55.6	63.8	67.6	70.3	69.2	62.2	56.9	49.2	42.8		(29)
(30)		2% MCDB	41.1	42.5	51.7	66.3	74.5	77.8	79.6	78.6	69.4	59.9	51.2	43.9		(30)
(31)		5% WB	37.4	38.6	43.5	53.2	61.4	65.6	68.4	67.2	60.2	54.4	46.7	40.4		(31)
(32)		5% MCDB	38.5	40.1	48.3	62.7	70.8	74.6	77.8	75.0	66.7	57.2	48.2	41.7		(32)
(33)		10% WB	35.5	36.5	41.0	50.9	59.1	63.4	67.0	65.0	58.3	52.1	44.7	37.9		(33)
(34)		10% MCDB	36.7	38.2	44.7	58.6	67.3	71.0	75.4	71.8	64.1	55.0	46.1	39.1		(34)
(35)	Mean Daily Temperature Range	MDBR	7.2	8.6	11.6	16.5	17.8	16.5	16.7	17.3	15.2	10.9	6.7	6.5		(35)
(36)		5% DB MCDBR	6.4	9.3	17.9	24.2	23.9	22.3	23.0	23.0	20.6	15.3	9.1	7.2		(36)
(37)		5% DB MCWBR	5.9	7.6	11.3	12.1	10.8	9.8	9.3	9.6	10.9	10.2	7.2	6.6		(37)
(38)		5% WB MCDBR	6.1	8.5	15.4	21.2	21.5	19.3	19.2	18.2	17.9	13.3	8.3	6.9		(38)
(39)		5% WB MCWBR	5.9	7.4	10.6	11.1	10.6	9.4	9.0	8.7	10.2	9.5	6.9	6.5		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.293	0.328	0.362	0.410	0.398	0.387	0.423	0.417	0.379	0.355	0.336	0.296		(40)
(41)		taud	2.187	2.145	2.193	2.186	2.293	2.350	2.264	2.276	2.348	2.396	2.287	2.220		(41)
(42)		Ebn at Noon	206	236	255	258	269	273	260	254	249	229	189	179		(42)
(43)		Edh at Noon	20	30	35	41	39	37	40	37	30	23	19	16		(43)
(44)	All-Sky Solar Radiation	RadAvg	203	442	845	1288	1656	1748	1627	1408	966	488	178	124		(44)
(45)		RadStd	36	82	136	166	164	145	165	125	108	103	20	25		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	+2.38	N/A	N/A	N/A	N/A
Regional (13 neighbors)		+0.79	N/A	N/A	N/A	N/A	+1.10	N/A	-270	N/A	N/A

Nomenclature: See separate page