

LIDA, Belarus

WMO: 268320

Lat: 53.9022N

Lon: 25.3233E

Elev: 157

StdP: 99.46

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.0	-15.7	-21.8	0.5	-18.4	-18.7	0.7	-15.4	8.1	3.2	7.1	2.2	1.5	40	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	28.8	19.8	27.1	18.7	25.3	17.9	21.0	26.3	20.0	25.2	19.1	23.6	2.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.2	23.6	18.2	13.3	22.4	17.3	12.6	21.4	61.3	26.4	57.9	25.3	54.7	23.6	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.5	5.8	5.2	DB	-23.0	31.4	3.1	1.7	-25.3	32.6	-27.1	33.6	-28.8	34.6	-31.0	35.9	(4)
(5)			WB	-23.3	22.8	3.1	1.4	-25.5	23.8	-27.3	24.6	-29.0	25.4	-31.2	26.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-3.9	-2.9	1.3	8.1	13.2	16.3	18.9	17.8	12.7	7.1	2.3	-2.0
	DBStd	9.12	5.89	5.58	4.47	4.42	4.17	3.32	3.14	3.04	3.35	3.96	4.51	5.50
	HDD10.0	1890	432	361	272	87	16	1	0	0	13	107	231	371
	HDD18.3	4073	691	594	529	307	168	79	31	46	170	348	481	629
	CDD10.0	965	0	0	1	31	113	190	276	243	94	17	1	0
	CDD18.3	106	0	0	0	1	7	18	49	29	1	0	0	0
	CDH23.3	857	0	0	0	7	71	153	383	227	16	0	0	0
	CDH26.7	187	0	0	0	1	11	25	101	49	1	0	0	0
Wind	WSAvg	2.5	2.8	2.7	2.7	2.4	2.4	2.4	2.1	2.1	2.2	2.6	2.6	2.7
Precipitation	PrecAvg	687	48	43	40	41	69	71	91	70	62	55	48	50
	PrecMax	845	98	86	87	78	126	142	207	221	186	159	83	94
	PrecMin	532	8	19	16	9	24	28	2	15	22	4	12	23
	PrecStd	84	20	15	17	19	27	29	56	45	37	35	18	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.5	8.3	14.9	24.4	28.1	29.2	31.8	30.9	25.6	19.1	12.8	8.5
		MCWB	6.2	5.8	8.6	14.4	18.4	19.8	20.6	21.1	17.0	14.8	10.3	7.2
	2%	DB	5.2	6.1	12.0	21.0	25.2	27.2	29.5	27.7	22.4	16.2	10.8	6.7
		MCWB	4.1	4.5	7.2	12.4	16.8	18.9	20.2	19.1	16.0	13.2	9.4	5.8
	5%	DB	3.8	4.7	9.5	18.2	23.1	25.2	27.5	25.7	20.2	14.4	9.2	5.4
		MCWB	2.9	3.5	6.0	11.2	15.3	17.7	19.2	18.1	15.0	12.1	8.0	4.6
	10%	DB	2.6	3.5	7.3	15.8	20.8	23.0	25.4	23.9	18.4	12.8	7.9	4.0
		MCWB	1.9	2.5	4.8	9.9	14.2	16.6	18.5	17.5	14.2	11.1	7.0	3.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.3	6.5	9.7	15.2	19.5	21.1	23.0	22.2	18.0	15.3	11.1	7.5
		MCDB	7.3	7.9	13.0	22.7	25.9	26.5	28.9	28.5	22.9	17.8	12.2	8.1
	2%	WB	4.4	4.9	7.8	13.1	17.6	19.8	21.3	20.7	16.8	13.8	9.6	6.0
		MCDB	5.1	5.8	11.0	19.1	23.6	25.5	26.5	25.9	20.8	15.5	10.7	6.6
	5%	WB	3.0	3.6	6.4	11.8	16.3	18.7	20.2	19.5	15.6	12.4	8.2	4.6
		MCDB	3.6	4.5	9.0	17.1	21.6	23.7	25.4	23.9	19.3	14.0	9.0	5.4
	10%	WB	1.9	2.5	5.0	10.5	15.1	17.4	19.4	18.3	14.6	11.2	7.1	3.3
		MCDB	2.6	3.4	7.0	14.8	19.6	21.6	24.1	22.1	17.8	12.8	7.9	3.9
Mean Daily Temperature Range	5% DB	MDBR	4.0	4.8	6.4	9.2	9.9	9.1	9.3	9.6	8.4	6.1	3.7	3.6
		MCDBR	3.6	5.2	9.9	13.4	13.3	12.4	12.8	12.8	11.5	8.5	5.1	4.0
		MCWBR	3.3	4.2	6.3	6.7	6.0	5.4	5.2	5.3	6.0	5.7	4.0	3.6
	5% WB	MCDBR	3.4	4.7	8.6	11.8	11.9	10.7	10.7	10.1	10.0	7.4	4.6	3.8
		MCWBR	3.3	4.1	5.9	6.2	5.9	5.2	5.0	4.9	5.7	5.3	3.9	3.6
Clear-Sky Solar Irradiance	taub	0.293	0.328	0.362	0.410	0.398	0.387	0.423	0.417	0.379	0.355	0.336	0.296	
	taud	2.187	2.145	2.193	2.186	2.293	2.350	2.264	2.276	2.348	2.396	2.287	2.220	
	Ebn at Noon	648	743	805	814	849	862	819	800	785	721	595	565	
	Edh at Noon	64	93	111	129	122	117	125	117	96	74	60	52	
All-Sky Solar Radiation	RadAvg	0.64	1.39	2.66	4.06	5.22	5.51	5.13	4.44	3.05	1.54	0.56	0.39	
	RadStd	0.11	0.26	0.43	0.52	0.52	0.46	0.52	0.39	0.34	0.33	0.06	0.08	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+1.32	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.44	N/A	N/A	N/A	N/A	+0.61	N/A	-150	N/A	N/A

Nomenclature: See separate page