

MOGILEV, Belarus

WMO: 268630

Lat: 53.956N

Lon: 30.096E

Elev: 193

StdP: 99.03

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.8	-18.5	-24.0	0.4	-21.3	-21.0	0.6	-18.3	11.5	-0.8	10.4	0.5	2.2	10	0.597

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	29.1	19.9	27.2	19.0	25.5	18.4	21.1	27.1	20.0	25.6	19.1	24.2	3.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	14.1	24.0	18.0	13.3	22.6	17.1	12.5	21.6	61.8	27.4	58.3	25.6	55.2	24.3	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
9.6	8.6	7.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-25.5	31.7	3.2	2.1	-27.8	33.2	-29.7	34.5	-31.5	35.6	-33.8	37.2
			-25.7	22.9	3.2	1.4	-28.0	23.9	-29.8	24.7	-31.6	25.4	-33.9	26.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	-5.6	-5.0	-0.3	7.5	13.1	16.4	18.8	17.6	12.2	6.1	0.9	-3.8
	DBStd	9.88	6.17	6.35	4.80	4.36	4.45	3.35	3.01	3.49	3.56	4.18	4.86	5.88
	HDD10.0	2198	484	421	318	100	20	1	0	0	19	133	274	428
	HDD18.3	4409	742	654	576	326	170	77	31	58	187	379	523	686
	CDD10.0	937	0	0	1	24	116	193	273	234	84	12	0	0
	CDD18.3	107	0	0	0	0	8	18	46	33	1	0	0	0
	CDH23.3	951	0	0	0	3	78	145	396	309	19	0	0	0
	CDH26.7	222	0	0	0	1	9	18	101	92	2	0	0	0
Wind	WSAvg	3.8	4.2	4.1	4.2	3.9	3.7	3.4	3.1	3.1	3.2	3.8	4.1	4.3
Precipitation	PrecAvg	625	41	38	38	42	58	66	88	63	51	55	46	39
	PrecMax	912	97	63	74	114	123	138	203	147	105	143	95	66
	PrecMin	469	11	17	5	10	10	26	19	3	16	4	3	19
	PrecStd	104	19	12	17	24	27	25	49	35	25	35	22	14
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.9	6.6	14.8	23.1	28.0	28.9	31.7	33.0	25.9	19.7	11.8	8.1
		MCWB	5.1	4.7	8.4	13.2	18.9	20.0	20.3	20.4	16.5	14.7	10.3	7.3
	2%	DB	3.7	4.2	11.0	20.2	25.8	26.9	29.4	29.0	22.8	15.9	9.6	6.0
		MCWB	2.8	3.0	6.5	12.1	17.4	18.9	20.2	19.7	15.8	12.4	8.4	5.4
	5%	DB	2.5	2.9	8.1	17.6	23.1	25.1	27.3	26.6	20.1	13.8	8.0	4.3
		MCWB	1.9	2.0	5.1	11.1	16.0	18.3	19.5	18.8	14.8	11.5	7.0	3.7
	10%	DB	1.2	1.8	5.9	15.1	21.0	23.2	25.5	24.5	18.1	12.0	6.8	2.5
		MCWB	0.6	1.1	3.8	9.7	14.7	17.0	18.7	17.8	13.7	10.2	6.0	1.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	5.0	9.4	14.6	20.1	21.4	22.6	22.1	18.3	15.8	10.7	7.5
		MCDB	5.8	6.3	13.4	20.3	26.1	26.2	28.9	28.4	23.6	17.8	11.6	7.8
	2%	WB	2.9	3.2	6.9	12.8	18.4	20.0	21.3	20.8	16.7	13.1	8.7	5.4
		MCDB	3.4	3.9	10.2	18.4	24.1	25.2	27.4	27.3	20.9	15.2	9.4	5.8
	5%	WB	1.8	2.1	5.3	11.7	16.9	19.0	20.2	19.7	15.4	11.7	7.1	3.8
		MCDB	2.3	2.7	7.6	16.6	22.1	23.9	25.5	25.4	18.9	13.5	7.8	4.3
	10%	WB	0.7	1.1	3.9	10.4	15.6	17.9	19.2	18.6	14.3	10.4	6.0	1.9
		MCDB	1.1	1.6	5.7	14.3	19.9	22.1	24.2	23.1	17.3	11.9	6.6	2.3
Mean Daily Temperature Range	5% DB	MDBR	4.5	5.4	6.8	9.5	10.2	9.8	10.0	10.4	9.2	6.9	4.1	4.0
		MCDBR	3.5	4.5	10.0	13.4	13.2	12.3	12.7	13.5	12.6	9.6	5.3	3.9
		MCWBR	3.4	3.8	6.5	7.0	6.6	6.2	5.4	5.9	6.9	6.5	4.5	3.8
	5% WB	MCDBR	3.3	4.3	8.9	11.9	12.1	11.1	11.4	12.1	10.7	8.2	4.7	3.9
		MCWBR	3.3	3.9	6.2	6.8	6.6	6.4	5.6	6.0	6.6	6.1	4.2	3.9
Clear-Sky Solar Irradiance	taub	0.290	0.323	0.353	0.410	0.398	0.381	0.409	0.418	0.376	0.350	0.330	0.293	
	taud	2.145	2.091	2.135	2.173	2.289	2.360	2.297	2.264	2.343	2.387	2.262	2.179	
	Ebn at Noon	645	743	811	813	849	868	833	799	788	725	597	560	
	Edh at Noon	66	98	117	130	122	115	121	118	96	74	61	53	
All-Sky Solar Radiation	RadAvg	0.69	1.55	2.93	4.05	5.25	5.70	5.44	4.53	3.02	1.51	0.55	0.40	
	RadStd	0.15	0.29	0.44	0.47	0.45	0.48	0.51	0.44	0.26	0.30	0.10	0.12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	-178	+100	N/A

Nomenclature: See separate page