

SLUTSK, Belarus

WMO: 269510

Lat: 53.0537N

Lon: 27.5444E

Elev: 162

StdP: 99.39

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.9	-17.3	-23.4	0.5	-20.3	-20.0	0.6	-16.9	11.3	0.6	10.3	0.2	1.7	0	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	29.3	20.2	27.5	19.5	25.8	18.7	21.6	27.4	20.5	25.7	19.6	24.3	2.8	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.5	14.5	24.2	18.6	13.7	23.0	17.7	13.0	22.0	63.4	27.7	59.5	25.8	56.5	24.3	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	8.3	7.3	-24.8	31.7	3.6	1.8	-27.4	33.0	-29.5	34.1	-31.6	35.1	-34.2	36.4		
(5)			-25.0	22.9	3.6	1.0	-27.6	23.6	-29.7	24.2	-31.7	24.8	-34.3	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-4.7	-3.7	0.9	8.2	13.3	16.5	18.9	17.8	12.6	6.9	2.0	-2.7	(6)
(7)		DBStd	9.48	6.11	6.01	4.87	4.32	4.26	3.50	3.15	3.26	3.53	4.10	4.79	5.69	(7)
(8)		HDD10.0	1984	456	384	283	83	17	1	0	0	15	112	242	393	(8)
(9)		HDD18.3	4163	714	617	540	303	163	77	31	49	174	353	491	651	(9)
(10)		CDD10.0	975	0	0	1	30	119	195	276	242	93	17	1	0	(10)
(11)		CDD18.3	114	0	0	0	1	8	22	49	33	2	0	0	0	(11)
(12)		CDH23.3	1018	0	0	0	5	82	179	437	293	22	0	0	0	(12)
(13)		CDH26.7	238	0	0	0	0	14	32	114	77	1	0	0	0	(13)
(14)	Wind	WSAvg	3.2	3.9	3.7	3.7	3.2	3.0	2.9	2.4	2.5	2.7	3.4	3.5	3.8	(14)
(15)	Precipitation	PrecAvg	632	42	36	38	38	64	80	87	61	50	49	45	42	(15)
(16)		PrecMax	851	72	80	76	91	115	214	223	188	136	172	90	72	(16)
(17)		PrecMin	481	6	18	16	4	27	20	7	4	5	2	7	19	(17)
(18)		PrecStd	108	17	15	15	19	28	44	51	43	31	38	19	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.5	7.5	15.2	23.8	28.5	29.8	32.0	32.5	26.1	20.6	13.0	8.2	(19)
(20)			MCWB	5.5	5.7	9.3	14.7	19.1	20.2	21.2	21.3	16.7	15.5	11.0	7.4	(20)
(21)		2%	DB	4.2	5.2	12.2	20.6	25.7	27.7	29.7	28.6	23.2	16.9	11.0	6.4	(21)
(22)			MCWB	3.4	4.1	7.6	12.8	17.8	19.8	20.4	19.9	16.3	13.4	9.8	5.8	(22)
(23)		5%	DB	3.0	3.8	9.4	18.1	23.2	25.6	27.7	26.5	20.9	14.6	9.3	5.1	(23)
(24)			MCWB	2.3	2.9	6.2	11.5	16.3	18.7	20.0	18.7	15.3	12.2	8.3	4.5	(24)
(25)		10%	DB	1.8	2.5	7.2	15.8	21.1	23.5	25.8	24.4	18.9	12.9	7.9	3.4	(25)
(26)			MCWB	1.2	1.7	5.0	10.2	14.9	17.6	19.3	18.1	14.2	11.2	7.1	2.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	6.0	10.1	15.7	20.2	22.1	23.0	22.7	18.2	16.3	11.6	7.5	(27)
(28)			MCDWB	6.3	7.2	14.2	21.9	26.3	27.4	28.7	28.9	23.4	19.9	12.6	7.9	(28)
(29)		2%	WB	3.6	4.3	7.9	13.7	18.5	20.6	21.8	21.0	16.9	14.0	9.9	5.9	(29)
(30)			MCDWB	4.1	5.1	11.1	18.8	24.5	25.7	27.8	26.7	21.7	15.8	11.0	6.4	(30)
(31)		5%	WB	2.4	3.0	6.5	12.3	17.2	19.5	20.8	20.0	15.9	12.6	8.4	4.5	(31)
(32)			MCDWB	2.9	3.7	9.1	16.8	22.2	24.4	26.0	24.9	19.6	14.4	9.2	5.1	(32)
(33)		10%	WB	1.3	1.8	5.1	10.9	15.9	18.4	19.8	18.9	15.0	11.1	7.1	2.9	(33)
(34)			MCDWB	1.8	2.4	7.1	14.5	19.8	22.5	24.6	22.7	18.2	12.8	7.8	3.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	5.0	6.6	9.4	10.3	9.6	10.2	10.5	9.4	6.8	4.0	3.9	(35)
(36)			MCDBR	3.2	4.6	10.0	13.4	13.3	12.3	12.9	13.5	12.7	9.6	5.9	3.9	(36)
(37)			MCWBR	3.1	3.8	6.3	6.9	6.7	5.8	5.5	5.7	6.7	6.1	4.6	3.6	(37)
(38)		5% WB	MCDWB	3.1	4.4	9.0	11.7	11.8	10.9	11.7	11.6	11.0	8.5	5.2	3.9	(38)
(39)			MCWBR	3.1	3.8	6.0	6.5	6.5	5.6	5.7	5.5	6.4	5.9	4.3	3.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.295	0.331	0.364	0.415	0.406	0.392	0.421	0.422	0.385	0.355	0.337	0.298	(40)	
(41)		taud	2.171	2.119	2.168	2.170	2.263	2.330	2.258	2.252	2.312	2.377	2.271	2.212	(41)	
(42)		Ebn at Noon	661	748	808	812	843	860	823	798	783	729	609	584	(42)	
(43)		Edh at Noon	68	98	116	132	126	119	126	120	100	77	63	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.72	1.51	2.83	4.14	5.27	5.69	5.35	4.61	3.13	1.65	0.62	0.45	(44)	
(45)		RadStd	0.13	0.28	0.42	0.48	0.51	0.41	0.50	0.40	0.34	0.31	0.07	0.12	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+1.00	N/A	N/A	N/A	N/A	
(47) Regional (9 neighbors)		+0.50	N/A	N/A	N/A	N/A	+0.85	N/A	N/A	N/A	N/A	

Nomenclature: See separate page