

BABRUYSK, Belarus

WMO: 269610

Lat: 53.2085N

Lon: 29.1273E

Elev: 156

StdP: 99.46

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.5	-17.8	-24.0	0.4	-21.3	-20.5	0.6	-17.4	10.0	2.0	8.9	2.3	1.6	30	0.558

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	29.5	19.8	27.7	19.1	25.9	18.4	21.1	27.3	20.1	25.7	19.2	24.3	3.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	14.1	23.9	18.2	13.3	22.6	17.3	12.6	21.5	61.5	27.5	58.4	25.7	55.4	24.4	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.3	6.5	DB	-26.2	32.0	2.8	2.3	-28.2	33.6	-29.8	34.9	-31.3	36.2	-33.3	37.8	(4)
(5)			WB	-26.4	22.7	2.7	1.0	-28.3	23.4	-29.9	23.9	-31.5	24.5	-33.5	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.9	-5.0	-4.1	0.5	7.7	13.0	16.5	19.0	17.6	12.2	6.6	1.5	-3.1	(6)
(7)		DBStd	9.60	6.20	6.16	4.71	4.26	4.32	3.45	3.04	3.31	3.57	4.15	4.92	5.93	(7)
(8)		HDD10.0	2067	466	395	294	93	19	0	0	19	121	255	404		(8)
(9)		HDD18.3	4271	724	628	552	319	174	77	29	53	184	364	504	663	(9)
(10)		CDD10.0	947	0	0	1	25	111	195	278	236	86	16	1	0	(10)
(11)		CDD18.3	109	0	0	0	0	7	22	48	31	1	0	0	0	(11)
(12)		CDH23.3	1072	0	0	0	5	85	204	461	297	20	0	0	0	(12)
(13)		CDH26.7	270	0	0	0	1	15	37	128	89	1	0	0	0	(13)
(14)	Wind	WSAvg	2.9	3.3	3.3	3.4	3.0	2.9	2.8	2.4	2.5	2.5	3.0	3.1	3.3	(14)
(15)	Precipitation	PrecAvg	637	40	38	38	42	61	74	92	57	50	56	46	42	(15)
(16)		PrecMax	838	80	84	74	84	114	161	173	126	126	167	97	77	(16)
(17)		PrecMin	490	8	15	6	2	13	25	12	6	5	2	3	13	(17)
(18)		PrecStd	86	16	16	17	21	27	33	43	31	30	40	23	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	7.9	15.2	23.5	28.7	29.9	32.2	33.7	25.9	21.0	12.7	8.6	(19)
(20)			MCWB	5.4	5.4	8.7	12.9	18.5	20.0	21.3	20.9	16.7	14.8	10.9	7.3	(20)
(21)		2%	DB	4.4	5.4	12.1	20.5	25.7	27.9	29.8	28.7	23.2	17.2	10.9	6.7	(21)
(22)			MCWB	3.4	3.9	7.0	11.8	17.5	19.1	20.0	19.9	16.0	13.1	9.4	5.9	(22)
(23)		5%	DB	3.2	3.8	9.3	18.0	23.3	26.0	27.9	26.4	20.7	14.7	9.1	5.2	(23)
(24)			MCWB	2.3	2.8	5.5	10.7	15.7	18.2	19.6	18.5	15.0	11.7	7.9	4.5	(24)
(25)		10%	DB	1.7	2.5	7.0	15.5	21.2	23.9	26.0	24.3	18.7	12.8	7.6	3.4	(25)
(26)			MCWB	1.1	1.6	4.5	9.6	14.4	17.4	18.9	17.7	14.0	11.0	6.7	2.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	6.1	9.6	14.4	19.8	21.2	22.7	21.8	17.8	16.3	11.4	7.6	(27)
(28)			MCDWB	6.5	7.7	14.5	21.7	26.4	27.4	29.4	28.6	24.0	19.8	12.4	8.1	(28)
(29)		2%	WB	3.6	4.2	7.5	12.7	18.1	20.0	21.5	20.7	16.8	13.8	9.7	6.1	(29)
(30)			MCDWB	4.2	5.2	10.8	17.9	24.2	25.8	27.6	27.2	21.6	16.1	10.7	6.6	(30)
(31)		5%	WB	2.4	2.9	6.0	11.5	16.8	19.2	20.4	19.8	15.6	12.3	8.1	4.5	(31)
(32)			MCDWB	3.1	3.7	8.8	16.5	22.1	24.6	25.8	24.9	19.2	14.3	9.0	5.2	(32)
(33)		10%	WB	1.2	1.7	4.5	10.4	15.4	18.1	19.4	18.6	14.6	10.9	6.7	2.7	(33)
(34)			MCDWB	1.7	2.5	6.7	14.8	19.9	22.6	24.4	22.8	17.6	12.7	7.5	3.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	5.6	7.4	10.1	10.8	10.3	10.6	11.0	10.1	7.5	4.4	4.1	(35)
(36)			MCDBR	3.7	5.4	11.1	14.4	14.1	13.6	13.5	14.2	13.5	10.6	6.1	4.3	(36)
(37)			MCWBR	3.5	4.3	6.8	7.0	6.6	6.1	5.4	6.0	7.2	6.6	4.8	3.8	(37)
(38)		5% WB	MCDWR	3.6	4.8	9.7	12.1	12.8	11.5	12.0	12.0	11.4	9.0	5.4	4.3	(38)
(39)			MCWBR	3.5	4.1	6.4	6.3	6.4	5.8	5.6	5.6	6.6	6.0	4.4	3.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.295	0.329	0.361	0.417	0.404	0.390	0.417	0.424	0.384	0.355	0.337	0.299	(40)	
(41)		taud	2.157	2.105	2.155	2.171	2.284	2.351	2.286	2.259	2.329	2.386	2.273	2.198	(41)	
(42)		Ebn at Noon	655	746	809	810	845	862	828	796	784	728	607	576	(42)	
(43)		Edh at Noon	68	99	117	132	124	117	123	119	99	76	63	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.71	1.52	2.85	4.10	5.25	5.69	5.41	4.62	3.12	1.63	0.59	0.42	(44)	
(45)		RadStd	0.14	0.30	0.43	0.49	0.46	0.43	0.49	0.41	0.30	0.30	0.08	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		+0.60	N/A	N/A	N/A	N/A	+0.75	N/A	-182	+102	N/A

Nomenclature: See separate page