

YURYEVETS, Russian Federation

WMO: 273550

Lat: 57.333N

Lon: 43.117E

Elev: 433

StdP: 14.47

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.6	-9.5	-21.2	1.7	-15.4	-14.6	2.5	-8.9	19.2	20.3	18.3	19.2	5.1	290	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.5	84.0	68.8	80.5	67.4	77.5	65.7	71.1	80.6	69.0	77.9	67.3	75.2	5.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.6	103.0	76.2	65.7	96.4	73.8	64.2	91.2	72.1	35.1	80.6	33.4	78.6	32.0	75.3	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	15.1	13.7	-20.3	87.3	5.9	3.2	-24.5	89.5	-28.0	91.4	-31.3	93.2	-35.5	95.4		
(5)			-20.6	73.5	5.8	2.9	-24.8	75.6	-28.2	77.3	-31.4	78.9	-35.6	81.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.6	14.4	15.8	26.7	41.7	54.3	62.2	67.2	62.4	52.5	40.8	27.9	20.1		
	DBStd	20.62	12.62	12.38	8.57	9.26	9.06	7.41	6.50	7.08	7.29	7.85	9.75	12.26		
	HDD50	5077	1102	958	724	284	59	3	0	2	54	300	663	928		
	HDD65	9146	1567	1378	1189	701	347	139	53	135	380	751	1113	1393		
	CDD50	1657	0	0	0	34	194	369	532	386	128	14	0	0		
	CDD65	249	0	0	0	0	16	55	120	53	5	0	0	0		
	CDH74	1562	0	0	0	1	103	335	780	331	12	0	0	0		
	CDH80	353	0	0	0	0	17	70	180	86	0	0	0	0		
	WSAvg	6.3	6.4	6.5	6.4	6.1	6.6	6.1	5.3	5.6	6.1	6.9	6.6	6.5		
	PrecAvg	24.1	1.8	1.2	1.2	1.5	1.7	2.8	2.6	2.5	2.3	2.6	2.0	1.9		
	PrecMax	33.4	3.8	2.4	3.3	3.7	3.2	6.8	5.4	6.1	6.3	7.5	4.1	3.3		
	PrecMin	16.2	0.7	0.4	0.0	0.4	0.2	0.7	0.4	0.2	0.4	0.6	0.4	0.6		
	PrecStd	4.4	0.7	0.5	0.8	0.9	0.7	1.3	1.4	1.7	1.3	1.5	1.0	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.0	37.4	51.9	71.7	82.1	86.3	89.5	88.2	76.0	63.3	49.9	42.2		
		MCWB	34.3	33.9	43.0	55.5	64.7	69.4	71.6	70.8	62.8	54.5	47.2	41.3		
	2%	DB	34.1	34.8	44.0	66.2	76.9	81.7	84.5	81.5	71.2	57.3	44.6	38.3		
		MCWB	32.6	32.6	37.5	52.9	62.0	67.1	69.1	70.0	60.9	51.4	42.7	36.8		
	5%	DB	32.9	33.3	40.1	60.6	72.3	77.7	81.3	77.1	67.0	53.9	41.8	35.3		
		MCWB	31.6	31.7	35.2	50.2	59.5	65.4	67.9	66.0	59.2	49.6	40.2	34.1		
	10%	DB	31.1	31.9	37.2	56.0	68.3	74.3	78.4	73.7	63.5	50.9	39.1	33.4		
		MCWB	29.9	30.5	33.4	47.1	56.6	63.7	67.0	64.6	57.3	47.9	37.6	32.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.0	34.9	43.3	56.7	67.3	71.5	74.0	73.7	65.8	55.5	47.2	41.7		
		MCDB	35.6	36.1	51.0	69.0	78.9	81.7	84.0	84.5	72.1	60.6	49.4	42.4		
	2%	WB	33.1	33.1	38.5	53.8	63.6	69.0	71.5	70.4	62.4	52.7	43.4	37.0		
		MCDB	33.9	34.4	42.7	64.8	74.3	78.4	81.1	79.6	69.0	56.5	44.4	38.0		
	5%	WB	31.8	32.1	36.0	51.0	61.1	67.2	69.6	67.7	59.9	50.3	40.5	34.2		
		MCDB	32.9	33.3	38.9	59.8	69.7	75.1	78.3	75.4	65.8	52.8	41.5	34.9		
	10%	WB	29.8	30.3	34.0	47.8	58.4	65.2	68.0	65.4	57.5	48.3	37.6	32.5		
		MCDB	31.0	31.9	36.6	55.2	66.0	72.3	76.1	71.8	63.2	50.7	39.0	33.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	10.4	11.7	14.1	15.5	14.4	14.5	13.6	11.7	8.3	6.3	7.7		
		MCDBR	7.0	8.2	13.5	19.9	19.1	17.9	18.4	17.9	15.8	12.2	8.0	6.5		
		MCWBR	6.9	7.7	9.0	11.8	9.5	8.4	7.9	8.3	8.5	7.7	7.5	6.4		
	5% WB	MCDBR	6.8	8.5	11.3	18.9	17.1	15.9	16.1	16.4	14.9	10.2	7.5	6.3		
		MCWBR	6.9	8.2	8.3	11.6	10.0	8.6	8.3	8.6	8.8	7.6	7.5	6.4		
(40) Clear-Sky Solar Irradiance	taub		0.280	0.317	0.348	0.402	0.376	0.371	0.405	0.413	0.365	0.347	0.308	0.274		
	taud		2.077	2.058	2.069	2.148	2.373	2.415	2.336	2.290	2.405	2.341	2.195	2.052		
	Ebn at Noon		176	221	249	255	273	276	262	250	247	214	167	140		
	Edh at Noon		18	29	37	41	35	34	36	35	27	22	16	14		
(44) All-Sky Solar Radiation	RadAvg		151	403	866	1224	1678	1734	1748	1356	806	353	133	82		
	RadStd		27	95	104	151	117	150	168	130	115	67	24	20		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (5 neighbors)	+1.15	N/A	N/A	N/A	N/A	N/A	-270	-355	N/A	N/A	

Nomenclature: See separate page