

YURYEVETS, Russian Federation

WMO: 273550

Lat: 57.333N

Lon: 43.117E

Elev: 132

StdP: 99.75

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -26.5	(c) -23.1	(d) -29.6	(e) 0.2	(f) -26.3	(g) -25.9	(h) 0.4	(i) -22.7	(j) 8.6	(k) -6.5	(l) 8.2	(m) -7.1	(n) 2.3	(o) 290	(p) 0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.1	(c) 28.9	(d) 20.4	(e) 27.0	(f) 19.7	(g) 25.3	(h) 18.7	(i) 21.7	(j) 27.0	(k) 20.6	(l) 25.5	(m) 19.6	(n) 24.0	(o) 2.3	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.7	24.5	18.7	13.8	23.2	17.9	13.0	22.3	63.7	27.0	59.7	25.9	56.6	24.1	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.1	6.7	6.1	-29.1	30.7	3.3	1.8	-31.4	32.0	-33.3	33.0	-35.1	34.0	-37.5	35.2
			-29.2	23.0	3.2	1.6	-31.5	24.2	-33.4	25.2	-35.2	26.1	-37.6	27.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	-9.8	-9.0	-3.0	5.4	12.4	16.8	19.5	16.9	11.4	4.9	-2.3	-6.6
	DBStd	11.46	7.01	6.88	4.76	5.15	5.03	4.11	3.61	3.93	4.05	4.36	5.42	6.81
	HDD10.0	2821	612	532	402	158	33	2	0	1	30	167	368	516
	HDD18.3	5081	871	766	661	389	193	77	29	75	211	417	618	774
	CDD10.0	921	0	0	0	19	108	205	296	214	71	8	0	0
	CDD18.3	138	0	0	0	0	9	31	67	29	3	0	0	0
	CDH23.3	868	0	0	0	1	57	186	433	184	7	0	0	0
	CDH26.7	196	0	0	0	0	9	39	100	48	0	0	0	0
Wind	WSAvg	2.8	2.9	2.9	2.9	2.7	3.0	2.7	2.4	2.5	2.7	3.1	2.9	2.9
Precipitation	PrecAvg	611	45	30	31	37	42	71	65	64	58	67	52	47
	PrecMax	848	96	61	85	95	82	172	138	155	161	191	104	85
	PrecMin	412	17	9	1	11	5	17	10	5	10	14	9	14
	PrecStd	113	17	13	20	22	19	34	36	42	33	39	26	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.2	3.0	11.1	22.0	27.8	30.1	32.0	31.2	24.5	17.4	10.0	5.7
		MCWB	1.3	1.0	6.1	13.0	18.1	20.8	22.0	21.5	17.1	12.5	8.4	5.2
	2%	DB	1.1	1.5	6.7	19.0	25.0	27.6	29.2	27.5	21.8	14.1	7.0	3.5
		MCWB	0.4	0.3	3.1	11.6	16.7	19.5	20.6	21.1	16.1	10.8	5.9	2.7
	5%	DB	0.5	0.7	4.5	15.9	22.4	25.4	27.4	25.0	19.5	12.1	5.5	1.9
		MCWB	-0.2	-0.2	1.8	10.1	15.3	18.5	19.9	18.9	15.1	9.8	4.5	1.1
	10%	DB	-0.5	-0.1	2.9	13.3	20.2	23.5	25.8	23.2	17.5	10.5	3.9	0.8
		MCWB	-1.2	-0.9	0.8	8.4	13.7	17.6	19.4	18.1	14.1	8.8	3.1	0.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.6	1.6	6.3	13.7	19.6	21.9	23.4	23.2	18.8	13.1	8.4	5.4
		MCDB	2.0	2.3	10.6	20.6	26.1	27.6	28.9	29.2	22.3	15.9	9.7	5.8
	2%	WB	0.6	0.6	3.6	12.1	17.6	20.6	22.0	21.3	16.9	11.5	6.3	2.8
		MCDB	1.0	1.3	5.9	18.2	23.5	25.8	27.3	26.5	20.5	13.6	6.9	3.3
	5%	WB	-0.1	0.0	2.2	10.5	16.2	19.5	20.9	19.8	15.5	10.2	4.7	1.2
		MCDB	0.5	0.7	3.8	15.5	21.0	24.0	25.7	24.1	18.8	11.6	5.3	1.6
	10%	WB	-1.2	-1.0	1.1	8.8	14.7	18.5	20.0	18.6	14.2	9.1	3.1	0.3
		MCDB	-0.5	0.0	2.6	12.9	18.9	22.4	24.5	22.1	17.3	10.4	3.9	0.7
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.8	6.5	7.8	8.6	8.0	8.1	7.5	6.5	4.6	3.5	4.3
		MCDBR	3.9	4.6	7.5	11.1	10.6	10.0	10.2	10.0	8.8	6.8	4.5	3.6
		MCWBR	3.8	4.3	5.0	6.5	5.3	4.7	4.4	4.6	4.7	4.3	4.2	3.6
	5% WB	MCDBR	3.8	4.7	6.3	10.5	9.5	8.8	8.9	9.1	8.3	5.7	4.2	3.5
		MCWBR	3.8	4.6	4.6	6.4	5.5	4.8	4.6	4.8	4.9	4.2	4.2	3.6
Clear-Sky Solar Irradiance	taub	0.280	0.317	0.348	0.402	0.376	0.371	0.405	0.413	0.365	0.347	0.308	0.274	
	taud	2.077	2.058	2.069	2.148	2.373	2.415	2.336	2.290	2.405	2.341	2.195	2.052	
	Ebn at Noon	556	696	784	803	860	869	826	788	778	676	526	442	
	Edh at Noon	57	91	118	129	110	107	114	111	86	70	52	44	
All-Sky Solar Radiation	RadAvg	0.48	1.27	2.73	3.86	5.29	5.47	5.51	4.27	2.54	1.11	0.42	0.26	
	RadStd	0.09	0.30	0.33	0.48	0.37	0.47	0.53	0.41	0.36	0.21	0.08	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	+0.64	N/A	N/A	N/A	N/A	N/A	-150	-197	N/A	N/A

Nomenclature: See separate page