

BEGISHEVO, Russian Federation

WMO: 276070

Lat: **55.565N**Lon: **52.093E**Elev: **643**StdP: **14.36**Time Zone: **3.00 (E03)**Period: **04-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.0	-12.9	-22.4	1.6	-16.4	-18.1	2.1	-12.8	31.8	24.4	28.7	21.5	7.6	230	0.726

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	88.2	67.1	84.5	66.3	80.9	64.9	70.0	81.9	68.4	80.5	67.1	78.4	10.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	99.0	74.9	64.5	93.1	72.5	62.8	87.4	72.1	34.3	83.3	33.0	80.0	31.9	78.5	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.8	23.8	21.0	DB	-21.7	92.2	5.9	3.5	-26.0	94.7	-29.4	96.8	-32.8	98.7	-37.0	101.3	(4)
(5)			WB	-21.8	73.2	5.7	3.3	-25.9	75.6	-29.2	77.5	-32.4	79.3	-36.5	81.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	39.8	9.8	11.1	23.7	41.1	56.9	63.3	67.2	64.9	53.5	39.9	27.6	16.4
	DBStd	22.67	12.91	11.70	8.77	8.93	8.99	8.28	7.02	8.13	7.44	8.33	9.61	12.17
	HDD50	5577	1248	1088	815	293	37	7	0	1	46	329	673	1040
	HDD65	9543	1713	1508	1280	717	279	127	58	103	352	779	1122	1505
	CDD50	1847	0	0	0	27	251	406	532	465	151	15	0	0
	CDD65	339	0	0	0	0	29	76	125	102	7	0	0	0
	CDH74	3231	0	0	0	5	328	693	1162	988	55	0	0	0
	CDH80	1020	0	0	0	0	63	200	379	372	6	0	0	0
	WSAvg	11.3	11.8	11.3	12.2	12.1	11.4	10.6	9.6	9.6	10.3	12.3	12.8	12.1
(15) Precipitation	PrecAvg	21.1	1.4	1.1	1.2	1.1	1.8	2.3	2.1	2.5	2.1	2.1	1.8	1.7
	PrecMax	28.3	3.0	2.1	2.5	2.4	4.3	5.4	4.5	6.5	4.6	4.5	3.0	4.4
	PrecMin	11.2	0.4	0.2	0.1	0.0	0.3	0.2	0.4	0.3	0.2	0.6	0.1	0.2
	PrecStd	3.6	0.6	0.6	0.7	0.7	1.1	1.1	1.0	1.4	1.2	1.0	0.9	0.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.3	35.4	46.1	73.4	85.8	89.9	93.2	95.1	79.2	65.9	51.6	37.1
		MCWB	34.3	33.1	38.8	55.9	63.4	66.7	67.6	67.8	60.0	51.0	49.0	35.2
	2%	DB	32.3	33.5	41.0	66.4	81.0	85.7	87.9	89.4	74.8	59.4	46.4	35.2
		MCWB	31.9	32.4	35.6	52.2	61.1	67.0	67.9	67.2	58.8	48.7	45.1	34.3
	5%	DB	30.3	30.5	37.4	61.1	77.4	81.0	84.2	83.9	69.6	55.5	42.6	33.7
		MCWB	29.7	29.4	33.8	48.5	59.5	65.5	67.0	66.4	58.0	48.4	41.0	33.0
	10%	DB	26.8	26.6	35.3	55.7	73.4	77.3	80.5	78.9	65.9	51.8	39.0	31.8
		MCWB	25.9	25.1	32.8	45.9	57.5	63.7	65.8	64.7	55.9	46.4	37.7	31.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.9	33.5	39.4	56.7	66.5	71.3	73.1	70.4	63.5	54.0	49.4	35.7
		MCDB	34.5	34.0	44.6	70.7	81.6	83.8	84.0	82.8	73.3	60.5	51.0	35.8
	2%	WB	31.9	31.9	36.3	53.8	63.5	69.5	70.4	69.0	61.0	51.1	44.8	33.9
		MCDB	32.2	32.9	39.6	64.7	77.7	81.7	80.9	82.8	69.7	56.4	46.0	34.3
	5%	WB	29.3	29.3	34.3	50.0	61.2	67.4	68.5	67.7	58.8	49.3	40.8	32.5
		MCDB	29.8	30.6	36.3	58.9	73.8	77.7	79.5	81.3	66.5	53.5	41.9	33.0
	10%	WB	26.0	25.1	32.8	46.6	58.9	65.2	67.2	66.1	57.1	47.3	37.2	30.7
		MCDB	26.7	26.2	34.5	54.5	70.4	74.8	78.0	77.2	64.2	51.6	38.0	31.3
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	11.5	12.6	15.2	19.7	18.1	18.0	18.0	15.0	10.7	7.5	8.8
		MCDBR	8.5	10.0	12.3	23.6	24.2	22.5	23.1	23.9	21.2	17.1	8.9	5.1
		MCWBR	8.8	9.5	9.3	12.9	11.1	10.6	9.8	9.2	10.7	10.8	8.0	5.4
	5% WB	MCDBR	8.4	9.6	10.6	21.7	22.7	20.6	19.3	21.4	18.8	14.6	8.6	5.4
		MCWBR	8.7	9.5	8.7	12.8	11.4	11.0	9.6	9.5	10.4	10.8	8.3	5.8
(40) Clear-Sky Solar Irradiance	taub		0.291	0.315	0.365	0.406	0.391	0.385	0.404	0.428	0.375	0.350	0.313	0.288
	taud		2.042	2.040	1.976	2.110	2.298	2.359	2.309	2.221	2.348	2.304	2.178	2.025
	Ebn at Noon		185	230	246	256	270	273	264	247	220	179	153	
	Edh at Noon		21	31	43	43	38	36	37	38	30	24	19	17
(44) All-Sky Solar Radiation	RadAvg		233	552	994	1400	1729	1881	1845	1438	895	409	172	129
	RadStd		32	59	106	121	154	173	166	125	109	84	33	33

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	+1.03	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+241	N/A

Nomenclature: See separate page