

ULYANOVSK VOSTOCHNY, Russian Federation

WMO: 279621

Lat: 54.401N

Lon: 48.803E

Elev: 77

StdP: 100.41

Time Zone: 4.00 (E04)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-28.8	-25.1	-31.8	0.2	-28.7	-28.1	0.3	-24.8	10.5	-6.8	9.6	-7.0	0.9	350	0.610

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	33.2	21.9	31.1	21.2	29.1	20.1	23.1	30.5	22.1	28.7	21.1	27.8	4.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.8	26.6	20.0	14.8	25.4	18.9	13.9	23.8	69.0	30.2	65.0	28.6	61.6	27.4	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4)	9.8	8.7	7.8	DB	-32.5	36.3	3.5	1.9	-35.0	37.7	-37.1	38.8	-39.0	39.9	-41.6	41.3
(5)				WB	-32.6	24.4	3.3	1.2	-34.9	25.3	-36.9	26.0	-38.7	26.7	-41.1	27.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.7	-11.5	-11.0	-4.7	6.1	15.7	19.3	21.3	19.7	13.6	5.9	-0.5	-6.9	(6)
(7)		DBStd	12.79	7.13	6.94	5.51	4.95	4.23	3.85	3.28	3.97	3.80	4.42	4.58	6.17	(7)
(8)		HDD10.0	2846	667	587	457	139	4	1	0	0	11	141	314	525	(8)
(9)		HDD18.3	4891	926	821	715	366	104	34	10	32	149	387	564	783	(9)
(10)		CDD10.0	1262	0	0	0	22	182	279	349	299	117	13	1	0	(10)
(11)		CDD18.3	265	0	0	0	0	23	62	101	73	6	0	0	0	(11)
(12)		CDH23.3	3039	0	0	0	13	347	711	1081	808	78	0	0	0	(12)
(13)		CDH26.7	1134	0	0	0	1	96	265	426	331	16	0	0	0	(13)
(14)	Wind	WSAvg	3.7	3.8	3.6	3.9	3.9	3.6	3.5	3.2	3.3	3.3	4.1	4.0	4.1	(14)
(15)	Precipitation	PrecAvg	497	36	27	26	33	40	62	50	54	54	43	38	34	(15)
(16)		PrecMax	681	74	54	63	88	94	121	133	115	141	77	88	87	(16)
(17)		PrecMin	341	13	9	1	2	2	2	3	12	9	19	11	13	(17)
(18)		PrecStd	79	15	13	15	20	24	34	32	27	37	18	18	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.2	3.0	9.0	25.1	31.2	35.0	36.1	36.2	28.9	19.1	11.2	4.1	(19)
(20)		MCWB	1.6	1.4	5.7	15.3	20.1	23.1	22.4	21.1	18.2	12.3	9.2	3.5		(20)
(21)		2%	DB	1.1	1.9	5.1	21.9	29.1	32.1	33.1	33.1	25.3	16.9	9.0	2.9	(21)
(22)		MCWB	0.7	0.8	2.6	13.4	18.8	21.5	22.3	21.1	16.9	11.5	8.1	2.2		(22)
(23)		5%	DB	0.0	0.8	3.2	18.9	27.2	29.8	31.0	30.1	23.1	14.2	7.1	1.9	(23)
(24)		MCWB	-0.4	0.0	1.6	11.8	18.1	20.5	21.5	20.8	15.8	10.8	6.2	1.3		(24)
(25)		10%	DB	-1.9	-1.2	2.2	15.2	25.0	27.2	28.9	27.9	20.9	12.2	5.8	0.9	(25)
(26)		MCWB	-2.4	-2.0	1.1	9.7	16.8	19.5	20.6	19.7	15.0	9.6	5.2	0.5		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.6	1.6	5.8	16.4	21.2	24.1	25.0	23.2	19.6	13.8	10.1	3.8	(27)
(28)		MDCB	1.8	2.2	8.6	24.3	28.0	32.8	33.0	31.9	26.2	16.5	11.0	3.9		(28)
(29)		2%	WB	0.6	0.6	3.0	14.2	19.8	22.3	23.5	22.2	18.0	12.5	8.1	2.0	(29)
(30)		MDCB	0.9	1.3	4.3	20.4	27.7	29.9	30.2	30.0	23.1	15.7	8.8	2.3		(30)
(31)		5%	WB	-0.5	-0.4	2.0	12.1	18.6	21.1	22.5	21.2	16.8	11.3	6.2	1.1	(31)
(32)		MDCB	-0.1	0.3	3.0	17.9	25.8	28.0	28.7	28.7	21.6	13.9	6.8	1.4		(32)
(33)		10%	WB	-2.4	-2.3	1.2	10.2	17.5	20.3	21.5	20.4	15.6	10.1	4.9	0.2	(33)
(34)		MDCB	-2.0	-1.6	2.1	14.9	24.2	26.5	27.3	27.0	19.5	11.8	5.4	0.5		(34)
(35)	Mean Daily Temperature Range	MDBR	7.2	8.7	9.2	10.7	12.6	11.3	11.8	11.6	10.1	6.8	4.7	5.7		(35)
(36)		5% DB	MCDBR	5.4	6.8	8.4	16.3	16.6	15.7	15.6	15.9	14.5	10.9	6.1	4.0	(36)
(37)		MCWBR	5.4	6.1	6.7	9.3	7.9	7.2	6.9	6.6	7.5	6.9	5.3	4.1		(37)
(38)		5% WB	MCDBR	5.3	6.2	7.6	15.6	15.2	13.6	13.8	13.9	12.8	9.4	5.4	4.2	(38)
(39)		MCWBR	5.4	5.7	6.2	9.5	7.7	6.6	6.7	6.3	7.0	6.7	5.1	4.3		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.294	0.325	0.368	0.423	0.399	0.390	0.406	0.433	0.381	0.355	0.320	0.293		(40)
(41)		taud	2.071	2.040	2.039	2.119	2.311	2.386	2.340	2.244	2.363	2.333	2.210	2.065		(41)
(42)		Ebn at Noon	615	729	785	797	847	859	834	782	781	708	590	522		(42)
(43)		Edh at Noon	69	102	128	137	119	112	115	120	94	77	61	57		(43)
(44)	All-Sky Solar Radiation	RadAvg	0.79	1.79	3.15	4.25	5.57	5.98	5.91	4.71	2.98	1.46	0.62	0.45		(44)
(45)		RadStd	0.12	0.22	0.39	0.37	0.42	0.56	0.50	0.41	0.41	0.26	0.10	0.11		(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+113	N/A

Nomenclature: See separate page