

GLAZOV, Russian Federation

WMO: 282140

Lat: 58.133N

Lon: 52.583E

Elev: 557

StdP: 14.40

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.7	-18.1	-30.0	1.0	-24.3	-23.1	1.6	-17.8	23.2	23.0	20.8	23.3	2.1	270	0.616

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	84.2	68.2	80.9	66.5	77.5	64.6	70.1	81.3	68.2	78.3	66.2	74.9	5.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	98.4	75.6	64.4	92.4	73.2	62.7	86.9	71.4	34.4	81.9	32.8	78.3	31.2	74.9	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.4	16.9	14.9	-31.3	88.5	6.0	3.5	-35.6	91.0	-39.1	93.0	-42.4	95.0	-46.8	97.5		
			-31.5	72.9	5.9	2.4	-35.8	74.6	-39.2	76.0	-42.6	77.3	-46.8	79.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	36.5	8.1	10.1	22.4	37.2	51.7	60.1	64.3	59.9	49.8	37.4	23.0	12.7	(6)
(7)		DBStd	22.31	14.18	13.83	8.83	8.80	9.26	7.54	6.81	7.68	7.54	8.06	11.70	13.92	(7)
(8)		HDD50	6241	1299	1118	857	394	95	9	1	8	95	399	809	1157	(8)
(9)		HDD65	10551	1764	1538	1322	835	420	184	97	197	456	857	1259	1622	(9)
(10)		CDD50	1324	0	0	0	10	147	311	444	316	90	6	0	0	(10)
(11)		CDD65	159	0	0	0	0	7	36	75	40	1	0	0	0	(11)
(12)		CDH74	1574	0	0	0	1	116	333	758	352	14	0	0	0	(12)
(13)		CDH80	377	0	0	0	0	16	62	197	100	2	0	0	0	(13)
(14)	Wind	WSAvg	6.6	7.2	7.3	7.9	7.0	6.8	5.7	4.3	5.0	5.7	7.2	7.4	7.4	(14)
(15)	Precipitation	PrecAvg	24.9	1.5	1.1	1.4	1.5	2.0	3.0	2.5	3.1	2.5	2.6	1.9	1.7	(15)
(16)		PrecMax	29.1	2.8	2.0	2.8	3.2	3.6	5.2	6.7	7.9	6.1	5.2	4.4	2.9	(16)
(17)		PrecMin	20.0	0.6	0.4	0.4	0.2	0.7	0.8	0.6	0.7	0.4	0.8	0.5	0.8	(17)
(18)		PrecStd	2.5	0.5	0.4	0.6	0.8	0.8	1.3	1.4	1.6	1.2	1.0	0.9	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.0	34.8	44.7	68.9	82.3	86.0	88.8	88.3	75.3	62.7	48.5	36.8	(19)
(20)			MCWB	32.6	32.6	38.0	54.1	63.3	69.5	69.1	69.0	60.8	52.2	45.8	35.9	(20)
(21)		2%	DB	32.3	33.2	39.8	60.9	77.3	81.3	84.8	82.1	69.9	55.9	42.8	34.3	(21)
(22)			MCWB	31.4	31.9	34.7	49.7	58.9	67.0	68.6	67.8	59.8	49.3	41.3	33.2	(22)
(23)		5%	DB	30.2	31.7	36.4	55.2	72.8	77.9	81.8	77.5	65.6	51.6	38.6	32.8	(23)
(24)			MCWB	29.3	30.6	33.0	46.2	56.8	64.8	67.3	65.6	57.0	47.3	37.3	31.9	(24)
(25)		10%	DB	27.2	28.8	34.2	50.3	68.4	74.1	78.3	73.1	61.8	48.7	35.2	30.4	(25)
(26)			MCWB	26.3	27.5	31.8	42.8	54.6	62.7	65.8	63.4	55.2	46.0	34.0	29.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.2	33.5	38.3	55.2	65.5	71.6	72.2	71.4	63.1	54.2	46.3	36.2	(27)
(28)			MCDB	33.7	34.0	43.6	66.3	78.2	82.2	83.1	83.9	71.5	59.0	47.6	36.5	(28)
(29)		2%	WB	31.7	32.3	35.5	50.7	61.4	68.8	70.5	69.0	60.3	50.3	41.6	33.5	(29)
(30)			MCDB	32.4	33.0	38.1	59.4	73.6	79.1	81.5	80.0	68.2	54.3	43.0	34.0	(30)
(31)		5%	WB	29.3	30.4	33.8	46.8	58.8	66.3	68.9	66.3	58.1	48.0	37.5	32.0	(31)
(32)			MCDB	30.1	31.7	35.9	54.3	68.4	75.1	79.2	75.3	64.2	50.9	38.6	32.7	(32)
(33)		10%	WB	26.3	27.5	32.2	43.5	56.3	64.0	67.1	64.2	55.8	45.9	34.4	29.4	(33)
(34)			MCDB	27.2	28.8	34.1	49.7	66.0	72.4	76.1	71.8	60.7	48.5	35.1	30.3	(34)
(35)	Mean Daily Temperature Range	MDBR	11.8	13.5	14.7	15.6	19.3	18.0	18.9	16.9	14.5	9.5	8.0	10.1	(35)	
(36)		5% DB	MCDBR	9.6	9.6	14.5	23.2	26.3	22.8	25.1	23.0	21.1	16.2	7.8	6.5	(36)
(37)			MCWBR	9.6	9.4	10.9	13.0	12.1	11.0	10.8	10.2	11.8	11.0	7.4	6.7	(37)
(38)		5% WB	MCDBR	9.7	10.0	10.9	21.1	22.9	20.7	22.2	20.9	19.0	14.5	8.0	6.4	(38)
(39)			MCWBR	9.8	9.9	8.8	12.8	12.1	10.8	10.5	10.0	11.2	10.8	7.8	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.284	0.312	0.364	0.392	0.382	0.375	0.398	0.410	0.367	0.341	0.301	0.274	(40)	
(41)		taud	2.018	2.030	1.955	2.093	2.328	2.389	2.332	2.279	2.367	2.298	2.126	1.992	(41)	
(42)		Ebn at Noon	162	217	238	256	270	273	263	249	243	211	157	125	(42)	
(43)		Edh at Noon	18	29	41	43	36	35	36	36	28	22	16	14	(43)	
(44)	All-Sky Solar Radiation	RadAvg	156	425	819	1240	1624	1755	1755	1310	771	337	129	88	(44)	
(45)		RadStd	25	84	112	162	180	135	180	119	101	51	24	19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	+1.22	N/A	N/A	N/A	N/A	N/A	N/A	-362	N/A	N/A	
(47) Regional (9 neighbors)	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page