

NOZHOVKA, Russian Federation

WMO: 283190

Lat: 57.083N

Lon: 54.750E

Elev: 430

StdP: 14.47

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.3	-15.6	-27.2	1.2	-20.8	-21.4	1.7	-15.2	18.0	18.5	16.4	18.3	2.6	270	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	85.8	69.5	82.4	67.4	79.1	65.7	70.9	82.5	69.1	79.6	67.3	76.7	5.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	100.9	76.4	65.2	94.8	74.5	63.5	89.2	72.9	34.9	82.9	33.5	79.6	32.0	76.8	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.5	14.3	12.3	-28.3	89.5	6.6	3.3	-33.0	91.9	-36.9	93.9	-40.6	95.7	-45.4	98.1
			-28.5	73.9	6.6	3.7	-33.2	76.5	-37.1	78.7	-40.8	80.7	-45.6	83.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	38.2	9.2	11.2	24.2	39.1	53.2	62.0	66.4	62.2	51.7	39.1	24.3	13.4	(6)
	DBStd	22.53	13.46	12.65	8.52	9.14	9.01	7.75	7.14	7.53	7.92	8.18	11.46	13.29	(7)
	HDD50	5905	1265	1085	799	345	72	7	0	2	72	352	771	1135	(8)
	HDD65	10042	1730	1505	1264	776	374	145	72	147	405	803	1221	1600	(9)
	CDD50	1585	0	0	0	19	173	367	510	380	122	14	0	0	(10)
	CDD65	245	0	0	0	0	10	55	116	59	5	0	0	0	(11)
	CDH74	2133	0	0	0	2	123	471	1038	464	35	0	0	0	(12)
	CDH80	565	0	0	0	0	17	108	300	136	4	0	0	0	(13)
	WSAvg	5.2	5.2	5.4	5.8	5.2	5.5	4.9	4.0	4.4	4.7	5.7	5.8	5.4	(14)
(15) Precipitation	PrecAvg	22.2	1.5	1.1	1.1	1.3	1.9	2.6	2.3	2.7	2.3	2.2	1.9	1.5	(15)
	PrecMax	28.2	2.6	1.9	2.0	2.4	3.3	5.9	5.2	5.2	5.3	3.9	3.2	2.5	(16)
	PrecMin	16.1	0.2	0.4	0.1	0.0	0.6	0.7	0.9	0.5	0.4	0.6	0.2	0.8	(17)
	PrecStd	2.8	0.6	0.5	0.5	0.7	0.8	1.1	1.0	1.1	1.1	0.8	0.8	0.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	35.3	46.4	71.9	82.7	87.7	90.0	89.9	79.3	64.6	48.3	36.1	(19)
		MCWB	32.9	33.2	38.8	56.5	62.1	69.5	71.2	70.7	60.9	52.9	45.8	34.5	(20)
	2%	DB	32.3	33.4	41.3	64.7	77.4	83.0	86.6	83.4	72.2	59.4	43.9	34.1	(21)
		MCWB	31.1	32.0	35.7	51.9	59.7	67.2	70.1	68.4	59.4	50.3	42.0	32.7	(22)
	5%	DB	30.2	31.8	37.7	58.2	73.4	79.5	83.5	78.8	67.7	54.8	40.1	32.7	(23)
		MCWB	28.9	30.5	33.9	47.8	58.4	66.0	68.9	65.9	57.8	48.8	38.4	31.6	(24)
	10%	DB	27.2	28.7	35.1	52.9	69.2	76.0	80.2	74.7	63.5	50.7	36.4	30.1	(25)
		MCWB	26.0	27.2	32.3	44.6	56.0	64.0	67.0	64.7	56.2	46.7	34.9	29.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.3	33.9	40.1	57.6	64.9	71.5	73.5	72.5	63.6	55.0	45.8	35.1	(27)
		MCDB	33.9	34.5	45.0	69.9	76.9	83.9	86.0	84.6	72.4	60.8	47.5	35.7	(28)
	2%	WB	31.5	32.3	36.6	52.8	61.8	68.9	71.6	69.8	60.8	51.8	42.3	33.1	(29)
		MCDB	32.3	33.3	39.7	62.7	73.7	80.0	83.4	80.8	68.5	57.9	43.9	34.0	(30)
	5%	WB	29.1	30.3	34.7	48.8	59.7	67.0	70.0	67.3	59.0	49.2	38.6	31.5	(31)
		MCDB	30.1	31.7	37.1	57.1	70.8	77.4	81.0	76.5	65.8	53.6	40.1	32.6	(32)
	10%	WB	26.0	27.4	32.9	45.4	57.3	65.1	68.4	65.3	57.0	47.0	35.2	29.0	(33)
		MCDB	27.2	28.8	35.0	52.3	66.9	74.2	78.0	73.1	63.4	50.8	36.2	30.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	12.5	13.4	15.7	18.9	17.1	17.6	15.6	13.2	9.2	7.6	9.8	(35)
		MCDBR	9.8	9.3	13.8	23.1	24.9	21.9	22.6	21.6	18.6	16.0	7.8	6.9	(36)
	5% WB	MCWBR	9.7	8.8	9.9	13.0	12.1	10.0	9.2	9.1	9.5	9.4	7.1	7.2	(37)
		MCWBR	10.0	9.1	11.4	21.1	22.3	20.3	20.6	20.1	16.8	14.2	7.6	7.2	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.295	0.319	0.375	0.405	0.393	0.390	0.410	0.430	0.377	0.352	0.311	0.288	(40)
		taud	2.008	2.013	1.936	2.083	2.294	2.360	2.311	2.228	2.346	2.270	2.110	1.982	(41)
	Ebn at Noon	Ebn at Noon	167	220	237	253	267	270	260	245	242	211	162	131	(42)
		Edh at Noon	20	30	43	44	38	36	37	38	29	24	18	16	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	193	487	920	1336	1675	1777	1782	1348	815	352	153	106	(44)
	RadStd	RadStd	29	71	101	163	179	157	193	120	91	61	31	24	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page