

OKHANSK, Russian Federation

WMO: 283210

Lat: 57.717N

Lon: 55.383E

Elev: 535

StdP: 14.41

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.2	-15.7	-26.4	1.3	-20.7	-20.8	1.8	-15.2	16.0	18.9	14.2	16.1	3.6	180	0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	85.4	68.7	82.2	66.9	78.9	65.1	71.1	81.3	69.1	78.8	67.1	75.9	4.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	103.7	75.4	65.6	96.5	73.6	63.8	90.2	71.8	35.2	81.1	33.5	78.9	31.9	75.8	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.6	12.7	11.5	-28.8	90.3	6.4	4.0	-33.4	93.2	-37.1	95.5	-40.7	97.8	-45.4	100.7		
(5)			-29.0	73.9	6.4	2.8	-33.5	76.0	-37.3	77.6	-40.8	79.2	-45.4	81.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.7	8.2	10.7	24.3	39.2	53.0	62.1	66.6	61.3	50.9	38.2	23.3	12.5
	DBStd	22.70	13.24	12.52	8.41	8.81	9.38	7.79	7.42	7.42	7.76	8.20	11.38	13.41
	HDD50	6045	1297	1100	797	341	80	7	0	3	80	378	801	1161
	HDD65	10216	1762	1520	1262	774	384	145	73	163	424	832	1251	1626
	CDD50	1546	0	0	0	17	173	369	514	354	108	11	0	0
	CDD65	243	0	0	0	0	12	57	122	49	3	0	0	0
	CDH74	2036	0	0	0	1	146	482	1038	350	19	0	0	0
	CDH80	531	0	0	0	0	24	100	310	95	2	0	0	0
	WSAvg	5.0	5.3	5.2	5.5	4.9	5.2	4.5	3.9	4.2	4.5	5.6	5.3	5.4
	PrecAvg	23.3	1.6	1.1	1.3	1.3	1.9	2.8	2.6	2.7	2.4	2.2	1.9	1.7
(15) Precipitation	PrecMax	30.5	3.3	2.0	2.1	2.3	4.2	5.0	7.4	5.9	4.9	3.8	3.6	3.0
	PrecMin	16.2	0.4	0.5	0.1	0.0	0.6	1.3	0.2	0.3	0.4	0.8	0.4	0.9
	PrecStd	3.0	0.6	0.4	0.6	0.7	0.9	1.0	1.5	1.2	1.1	0.8	0.8	0.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	34.5	46.8	72.3	83.2	86.5	90.1	88.5	76.8	63.8	46.8	35.7
		MCWB	32.7	32.2	38.0	55.1	61.7	68.6	70.1	68.7	60.8	52.4	45.0	34.5
	2%	DB	31.7	32.8	41.0	64.1	78.0	82.8	86.4	81.7	70.5	58.0	42.4	33.6
		MCWB	30.9	31.3	34.7	50.4	59.4	66.4	69.6	67.5	58.7	50.2	40.9	32.6
	5%	DB	29.3	31.0	37.6	58.0	73.5	79.7	83.5	77.4	66.4	53.1	38.3	32.0
		MCWB	28.5	29.8	33.0	46.7	57.3	65.5	68.5	65.9	57.6	48.5	37.1	31.2
	10%	DB	26.0	28.0	35.0	52.7	69.1	76.1	80.2	73.4	62.1	49.3	35.2	29.0
		MCWB	25.1	26.7	31.8	43.9	55.0	63.2	66.7	64.1	55.2	46.2	33.9	28.1
	0.4%	WB	33.0	33.2	39.3	55.6	64.7	71.5	76.2	72.0	63.3	54.4	45.3	35.0
		MCDB	33.4	33.6	45.0	69.9	78.1	82.3	84.8	81.3	71.5	60.0	46.7	35.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	31.0	31.6	36.0	51.5	61.4	69.1	72.3	69.6	60.5	51.2	40.9	32.9
		MCDB	31.6	32.5	39.2	61.8	74.7	79.8	82.6	79.8	67.5	56.4	42.0	33.4
	5%	WB	28.5	29.8	34.1	47.8	59.0	66.7	70.0	67.4	58.4	48.7	37.2	31.2
		MCDB	29.4	31.0	36.4	57.1	70.3	76.2	79.9	75.0	64.0	52.4	38.0	32.0
	10%	WB	25.1	26.7	32.4	44.6	56.6	64.6	68.1	65.1	56.4	46.4	34.2	28.2
		MCDB	25.9	28.0	34.6	51.8	66.3	73.8	77.2	71.5	61.4	49.4	34.9	28.9
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	12.2	13.3	15.6	18.5	16.9	16.8	14.5	12.5	8.4	7.3	9.1
		MCDBR	9.2	9.4	14.6	23.9	25.2	22.0	21.7	20.3	18.5	15.1	7.7	7.2
		MCWBR	9.1	8.7	10.2	13.0	11.6	9.8	8.7	8.9	9.3	8.7	7.1	7.4
	5% WB	MCDBR	9.2	8.9	12.0	21.8	21.9	20.0	19.2	18.3	15.7	13.6	7.1	7.2
		MCWBR	9.2	8.5	9.6	12.4	11.7	10.0	9.3	9.2	8.9	8.9	6.8	7.5
(40) Clear-Sky Solar Irradiance	taub		0.291	0.317	0.372	0.401	0.391	0.388	0.409	0.425	0.377	0.348	0.308	0.284
	taud		2.001	2.009	1.929	2.069	2.299	2.361	2.310	2.237	2.340	2.272	2.100	1.971
	Ebn at Noon		162	217	235	253	267	270	260	245	240	210	157	124
	Edh at Noon		19	30	43	44	37	36	37	37	29	23	17	15
(44) All-Sky Solar Radiation	RadAvg		175	458	882	1307	1644	1752	1756	1317	780	338	141	95
	RadStd		28	73	103	166	181	156	191	118	92	50	28	21

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	+1.91	+1.94	N/A	N/A	N/A	N/A	
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page