

SHAMARY, Russian Federation

WMO: 283340

Lat: 57.350N

Lon: 58.217E

Elev: 800

StdP: 14.28

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.9	-21.0	-32.4	0.9	-26.6	-26.2	1.3	-20.7	18.3	16.6	14.4	13.5	0.9	90	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	84.9	67.7	81.5	65.8	78.2	64.0	69.5	81.0	67.8	78.8	66.0	75.5	4.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	97.5	75.0	63.8	91.3	72.4	62.1	85.7	70.9	34.0	81.2	32.6	78.9	31.1	75.9	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.4	12.7	10.6	-34.7	89.4	7.3	3.5	-39.9	91.9	-44.2	93.9	-48.3	95.8	-53.6	98.3
			-34.8	72.4	7.3	2.9	-40.1	74.5	-44.3	76.2	-48.4	77.9	-53.7	80.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	35.7	6.1	9.1	23.3	37.5	51.1	59.9	63.8	59.3	49.3	36.7	21.0	9.9	
	DBStd	22.86	14.00	13.31	9.22	9.18	8.79	7.95	7.28	7.47	7.94	8.24	12.86	14.64	
	HDD50	6474	1362	1144	827	384	96	13	2	8	107	419	869	1243	
	HDD65	10836	1827	1564	1292	824	437	191	114	209	473	878	1319	1708	
	CDD50	1270	0	0	0	10	129	311	430	298	87	5	0	0	
	CDD65	154	0	0	0	0	5	38	76	33	2	0	0	0	
	CDH74	1763	0	0	0	1	116	451	819	348	28	0	0	0	
	CDH80	440	0	0	0	0	8	109	224	97	2	0	0	0	
Wind	WSAvg	4.0	4.0	4.3	4.8	4.5	4.2	3.9	3.0	2.9	3.4	4.5	4.3	4.3	
Precipitation	PrecAvg	28.9	2.0	1.6	1.7	1.6	2.0	3.2	3.3	3.3	2.6	2.9	2.5	2.3	
	PrecMax	39.6	4.2	3.9	3.4	3.7	4.3	6.9	7.3	7.2	5.1	4.8	4.2	5.0	
	PrecMin	23.6	0.2	0.6	0.1	0.0	0.6	0.7	0.9	0.7	0.8	0.6	0.9	1.1	
	PrecStd	3.8	0.9	0.8	0.8	1.0	0.9	1.6	1.7	1.5	1.2	1.2	0.9	1.0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.0	35.9	49.5	71.2	81.1	88.2	89.1	88.0	78.1	63.3	47.1	34.3	
		MCWB	32.2	32.4	39.9	53.8	59.7	67.6	69.1	68.4	61.2	52.3	44.0	32.9	
	2%	DB	31.0	32.9	42.8	63.2	77.6	83.0	85.3	82.2	71.8	57.6	41.7	32.8	
		MCWB	29.8	30.9	35.5	49.8	58.8	65.7	68.5	67.1	59.5	49.2	39.7	31.6	
	5%	DB	28.5	30.7	38.4	57.6	73.1	79.4	82.3	77.3	66.2	52.8	37.6	31.1	
		MCWB	27.4	28.9	33.4	46.3	56.8	64.0	67.4	64.9	57.5	46.9	35.7	29.8	
	10%	DB	25.1	27.6	35.5	52.3	68.5	75.3	78.8	72.7	61.6	48.8	34.7	28.3	
		MCWB	23.9	25.7	31.9	42.8	54.7	62.5	66.0	63.2	55.2	45.0	33.3	27.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.6	33.1	41.0	55.1	63.2	70.1	72.8	70.1	64.0	53.4	44.0	33.7
			MCDB	33.8	35.2	48.4	68.7	76.2	82.5	84.9	82.6	72.7	59.2	46.2	34.0
2%		WB	29.8	31.3	36.7	50.8	60.3	67.5	70.5	68.4	60.4	50.2	39.8	31.8	
		MCDB	30.8	32.9	41.0	61.6	72.9	79.3	81.3	79.6	68.6	55.8	41.4	32.5	
5%		WB	27.4	28.9	34.4	47.3	58.1	65.6	68.6	66.3	58.1	47.5	36.1	29.7	
		MCDB	28.5	30.6	37.4	56.2	70.2	76.1	79.6	75.2	64.7	51.8	37.4	31.0	
10%		WB	23.9	25.9	32.3	44.1	56.1	63.6	67.0	63.9	55.8	45.0	33.4	26.9	
		MCDB	25.0	27.6	35.3	51.0	66.4	73.4	77.2	71.1	61.0	48.8	34.4	28.3	
Mean Daily Temperature Range	5% DB	MDBR	13.2	16.3	16.5	18.3	21.3	19.5	19.5	17.2	15.1	9.9	9.3	11.5	
		MCDBR	9.8	11.5	20.0	27.5	30.2	26.2	26.1	24.9	23.0	19.9	9.7	8.3	
		MCWBR	9.5	10.1	14.3	15.9	14.1	11.9	10.9	11.5	12.4	12.5	8.2	7.9	
	5% WB	MCDBR	9.4	10.6	15.2	24.7	25.4	23.0	23.4	23.0	20.5	17.5	8.9	8.7	
		MCWBR	9.3	9.7	11.4	15.0	13.8	11.9	10.9	11.3	12.0	12.0	8.2	8.4	
Clear-Sky Solar Irradiance	taub	0.288	0.314	0.370	0.406	0.400	0.395	0.421	0.434	0.379	0.349	0.307	0.284		
	taud	2.006	2.014	1.927	2.032	2.264	2.338	2.265	2.200	2.324	2.262	2.093	1.968		
	Ebn at Noon	168	220	237	252	265	268	257	242	240	211	161	129		
	Edh at Noon	19	30	43	46	39	37	39	39	30	24	18	15		
All-Sky Solar Radiation	RadAvg	184	468	874	1279	1588	1693	1689	1264	767	339	155	105		
	RadStd	28	71	90	163	173	160	175	143	71	60	30	22		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page