

TYUMEN, Russian Federation

WMO: 283670

Lat: 57.117N

Lon: 65.433E

Elev: 334

StdP: 14.52

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.9	-20.9	-31.2	1.0	-25.8	-26.2	1.3	-20.5	14.1	17.5	12.5	15.9	2.9	330	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.4	85.5	67.5	82.3	66.2	79.3	64.7	70.1	81.4	68.5	78.7	66.7	76.1	6.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	97.9	75.2	64.6	92.3	73.7	63.0	87.2	71.8	34.3	81.7	32.9	78.7	31.5	76.2	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.0	12.2	11.0	DB	-30.5	90.4	5.6	2.2	-34.5	92.0	-37.8	93.3	-40.9	94.5	-45.0	96.1	(4)
(5)			WB	-30.6	73.5	5.6	2.7	-34.7	75.4	-37.9	77.0	-41.1	78.5	-45.2	80.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.2	3.7	8.4	23.3	39.5	52.9	62.2	65.1	60.9	50.1	37.4	20.0	8.9		
	DBStd	23.98	13.15	12.96	9.35	9.92	9.61	8.22	7.03	7.54	8.00	8.86	13.47	13.72		
	HDD50	6531	1437	1163	828	337	83	8	1	4	96	399	901	1274		
	HDD65	10741	1902	1583	1293	766	389	148	89	175	451	855	1351	1739		
	CDD50	1485	0	0	0	21	173	373	469	342	99	8	0	0		
	CDD65	221	0	0	0	0	14	63	92	48	4	0	0	0		
	CDH74	2144	0	0	0	6	211	649	829	412	37	0	0	0		
	CDH80	539	0	0	0	0	39	182	206	109	3	0	0	0		
	WSAvg	5.3	5.0	5.1	5.9	6.1	5.8	5.1	4.6	4.5	4.9	5.5	5.5	5.3		
	PrecAvg	18.5	0.9	0.6	0.6	1.0	1.6	2.4	3.5	2.4	1.9	1.5	1.2	1.0		
	PrecMax	26.1	3.2	1.5	1.6	2.3	5.7	6.3	7.6	6.7	6.9	3.7	2.6	2.0		
(15) Precipitation	PrecMin	13.0	0.2	0.0	0.0	0.0	0.3	0.4	0.5	0.3	0.4	0.3	0.0	0.0		
	PrecStd	2.6	0.6	0.4	0.4	0.6	0.9	1.3	1.7	1.2	1.3	0.8	0.6	0.6		
	DB	34.7	38.1	48.5	73.1	84.3	88.9	89.0	87.6	78.7	65.1	45.8	36.8			
	MCWB	32.7	33.1	39.7	54.3	60.6	68.8	69.6	69.8	60.6	52.0	40.9	34.1			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	30.3	34.3	42.3	65.2	79.8	85.1	84.9	82.8	72.8	59.0	41.6	33.5			
	2% MCWB	28.1	31.1	35.3	50.9	59.2	66.6	68.4	67.8	59.0	49.4	38.9	31.4			
	5% DB	26.8	30.5	38.7	59.5	75.2	81.6	82.0	78.5	67.6	53.9	38.4	30.5			
	5% MCWB	25.2	27.8	33.3	47.7	57.3	65.2	67.8	65.9	56.9	46.8	36.2	28.7			
	10% DB	22.2	26.8	36.1	54.6	70.6	77.5	78.8	74.1	63.0	49.7	35.4	26.8			
	10% MCWB	20.8	24.3	31.9	44.9	55.1	64.0	66.2	63.9	54.5	44.8	33.2	25.2			
	0.4% WB	32.8	34.2	40.1	55.8	65.4	72.0	72.3	71.4	63.9	53.3	42.3	34.2			
	0.4% MCDB	34.6	36.9	46.9	68.8	78.3	84.8	83.5	83.8	74.0	62.1	45.3	36.0			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	28.5	31.3	36.2	52.0	61.2	68.9	70.4	69.4	60.5	50.3	39.3	31.6			
	2% MCDB	30.0	34.1	40.7	63.9	74.4	80.5	81.5	79.9	69.0	57.7	41.3	33.4			
	5% WB	25.2	28.0	34.2	48.6	58.8	66.8	69.0	67.0	57.9	47.5	36.4	28.8			
	5% MCDB	26.8	30.4	37.9	58.0	72.2	77.9	79.4	75.8	65.6	52.5	38.3	30.3			
	10% WB	20.9	24.4	32.3	45.6	56.5	64.8	67.5	64.9	55.4	45.2	33.5	25.3			
	10% MCDB	22.1	26.7	35.7	53.8	68.7	75.4	76.9	72.8	62.2	49.7	35.1	26.8			
	MDBR	13.0	16.2	16.4	16.8	20.0	18.7	17.4	16.5	15.2	12.2	10.7	11.9			
	5% DB	11.9	14.0	16.8	24.0	27.1	24.3	22.3	22.9	22.3	20.1	10.5	10.9			
(36) Mean Daily Temperature Range	MCWBR	11.2	11.7	11.7	13.2	12.1	10.1	9.0	10.1	11.2	11.7	8.9	9.9			
	5% WB	11.9	12.8	15.3	22.2	24.5	21.3	20.0	20.7	20.1	17.9	10.0	11.1			
	MCWBR	11.3	11.0	11.5	13.0	12.4	10.2	8.9	10.0	10.9	11.7	9.1	10.5			
	MCWBR	11.3	11.0	11.5	13.0	12.4	10.2	8.9	10.0	10.9	11.7	9.1	10.5			
(40) Clear-Sky Solar Irradiance	taub	0.281	0.311	0.368	0.409	0.406	0.404	0.420	0.429	0.381	0.348	0.305	0.279			
	taud	2.039	2.034	1.953	2.095	2.236	2.311	2.267	2.213	2.308	2.266	2.129	1.998			
	Ebn at Noon	176	224	239	252	263	265	257	245	240	213	166	136			
	Edh at Noon	19	30	42	43	40	38	39	38	30	24	17	15			
(44) All-Sky Solar Radiation	RadAvg	226	538	1016	1411	1653	1809	1737	1335	843	428	208	136			
	RadStd	16	37	56	113	142	141	154	129	85	69	29	17			

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page