

TEVRIZ, Russian Federation

WMO: 283830

Lat: 57.517N

Lon: 72.400E

Elev: 67

StdP: 100.53

Time Zone: 6.00 (E06)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.1	-33.2	-38.9	0.1	-36.1	-36.0	0.1	-33.2	8.2	-10.6	7.4	-10.5	1.1	70	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	28.6	20.0	27.0	19.1	25.4	18.2	21.3	26.5	20.2	25.2	19.2	23.9	2.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.2	24.2	18.4	13.4	22.8	17.4	12.6	21.7	62.2	26.8	58.4	25.2	55.2	24.0	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.2	6.3	-38.8	31.2	3.7	1.4	-41.5	32.2	-43.7	33.0	-45.8	33.8	-48.5	34.8		
(5)			-38.9	22.4	3.7	1.1	-41.5	23.2	-43.7	23.9	-45.8	24.5	-48.5	25.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	0.9	-18.7	-15.5	-6.7	2.5	10.6	16.4	17.9	15.3	9.5	2.1	-8.2	-15.2
	DBStd	14.20	8.43	7.62	6.22	5.77	5.54	4.67	3.74	3.91	4.25	5.10	8.14	8.49
	HDD10.0	4058	889	713	517	230	63	7	0	3	61	247	547	780
	HDD18.3	6451	1148	947	776	474	247	90	54	112	267	503	797	1038
	CDD10.0	746	0	0	0	6	81	198	247	167	45	3	0	0
	CDD18.3	97	0	0	0	0	6	31	43	16	1	0	0	0
	CDH23.3	876	0	0	0	1	89	287	352	138	9	0	0	0
	CDH26.7	173	0	0	0	0	17	63	69	24	0	0	0	0
Wind	WSAvg	2.9	2.7	2.8	3.4	3.5	3.3	2.7	2.3	2.4	2.8	3.1	3.2	3.0
Precipitation	PrecAvg	515	25	18	22	30	40	68	75	72	52	42	38	32
	PrecMax	732	47	36	57	73	91	178	250	141	106	97	62	60
	PrecMin	317	2	1	1	2	3	22	27	20	17	6	8	9
	PrecStd	104	12	7	13	17	20	34	51	26	22	22	14	13
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.4	2.4	7.6	20.6	28.5	30.3	30.5	29.4	24.6	16.7	6.3	1.7
		MCWB	-0.4	0.5	3.1	11.5	16.4	19.7	21.8	20.8	15.3	10.7	4.6	0.9
	2%	DB	-1.8	-0.2	4.7	16.8	25.7	28.5	28.4	26.6	21.3	13.6	4.3	0.2
		MCWB	-2.5	-1.4	1.4	9.6	15.0	19.5	20.6	19.6	14.6	9.1	3.1	-0.5
	5%	DB	-4.0	-2.1	2.9	13.7	23.3	26.7	27.0	24.7	18.6	11.3	2.5	-1.7
		MCWB	-4.6	-3.0	0.5	7.8	13.9	18.8	19.8	18.7	13.4	7.7	1.5	-2.4
	10%	DB	-6.4	-4.3	1.4	11.2	20.5	24.7	25.3	22.5	16.6	9.2	1.1	-3.9
		MCWB	-7.0	-5.3	-0.4	6.5	12.7	17.8	19.0	17.5	12.2	6.6	0.3	-4.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.3	0.6	3.5	12.5	17.5	22.5	23.0	21.7	16.7	11.6	4.9	1.2
		MCDB	0.3	2.1	6.8	18.9	26.2	28.2	28.6	27.3	21.9	15.3	5.8	1.6
	2%	WB	-2.4	-1.3	1.9	10.3	15.8	20.7	21.6	20.3	15.2	9.6	3.2	-0.5
		MCDB	-1.8	-0.3	3.9	16.0	23.4	26.2	26.9	25.3	20.0	12.5	4.1	0.1
	5%	WB	-4.6	-3.0	0.9	8.4	14.6	19.6	20.6	19.2	13.9	8.2	1.6	-2.5
		MCDB	-4.0	-2.1	2.6	13.1	21.8	24.8	25.4	23.6	17.6	10.5	2.3	-1.8
	10%	WB	-6.9	-5.3	-0.3	6.6	13.3	18.5	19.6	18.1	12.7	6.9	0.4	-4.5
		MCDB	-6.4	-4.4	1.4	10.7	19.5	23.4	24.2	21.7	15.8	9.2	1.0	-4.0
Mean Daily Temperature Range	5% DB	MDBR	7.6	9.3	9.5	9.5	11.2	10.3	9.7	9.5	8.6	6.4	6.1	7.2
		MCDBR	6.6	7.9	8.6	13.0	15.2	13.5	12.6	12.8	12.1	10.2	5.5	6.2
		MCWBR	6.3	7.1	6.2	7.6	6.8	6.1	5.7	6.3	6.4	6.5	5.0	6.0
	5% WB	MCDBR	6.4	7.5	7.8	12.2	13.5	12.1	11.3	11.4	10.5	9.1	5.2	6.4
		MCWBR	6.2	7.1	6.1	7.7	7.0	6.1	5.7	6.0	6.3	6.3	4.9	6.2
Clear-Sky Solar Irradiance	taub	0.276	0.312	0.370	0.409	0.403	0.409	0.427	0.422	0.374	0.349	0.307	0.277	
	taud	2.019	2.009	1.926	2.046	2.249	2.304	2.252	2.238	2.331	2.236	2.075	1.964	
	Ebn at Noon	545	694	746	791	830	831	803	776	762	657	497	408	
	Edh at Noon	59	94	136	142	124	119	123	117	92	76	56	47	
All-Sky Solar Radiation	RadAvg	0.68	1.69	3.10	4.45	5.12	5.55	5.24	4.05	2.63	1.30	0.58	0.40	
	RadStd	0.07	0.13	0.23	0.38	0.41	0.45	0.44	0.36	0.27	0.17	0.11	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page