

IZHEVSK, Russian Federation

WMO: 284110

Lat: 56.833N

Lon: 53.450E

Elev: 156

StdP: 99.46

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.0	-25.6	-32.1	0.2	-28.7	-28.5	0.3	-25.4	10.7	-6.3	9.7	-6.4	1.7	340	0.627

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	29.8	20.0	28.0	19.1	26.2	18.3	21.1	27.4	20.2	26.3	19.2	24.7	3.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	14.1	23.9	18.0	13.2	23.0	17.1	12.4	22.1	61.6	27.2	58.7	26.4	55.4	24.9	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.0	6.9	-32.2	32.1	3.8	1.9	-34.9	33.4	-37.1	34.5	-39.3	35.6	-42.0	37.0		
(5)			-32.3	22.7	3.8	1.3	-35.0	23.7	-37.2	24.4	-39.3	25.2	-42.1	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.4	-12.6	-11.5	-4.7	4.0	12.1	16.5	18.8	16.5	10.7	3.7	-4.1	-10.3	(6)
(7)		DBStd	12.44	7.20	6.91	4.48	5.27	5.18	4.44	3.85	4.50	4.38	4.60	6.24	7.20	(7)
(8)		HDD10.0	3292	702	602	454	192	39	4	0	3	42	202	423	628	(8)
(9)		HDD18.3	5599	960	836	713	429	201	85	42	90	230	454	673	887	(9)
(10)		CDD10.0	866	0	0	0	13	104	201	272	206	64	7	0	0	(10)
(11)		CDD18.3	132	0	0	0	0	8	31	56	34	3	0	0	0	(11)
(12)		CDH23.3	1197	0	0	0	1	96	280	502	299	19	0	0	0	(12)
(13)		CDH26.7	318	0	0	0	0	16	66	137	97	2	0	0	0	(13)
(14)	Wind	WSAvg	3.3	3.4	3.5	3.8	3.5	3.6	3.1	2.6	2.8	3.0	3.6	3.7	3.5	(14)
(15)	Precipitation	PrecAvg	527	37	27	27	30	34	59	68	61	51	50	45	38	(15)
(16)		PrecMax	717	68	74	96	64	92	118	118	237	123	96	88	80	(16)
(17)		PrecMin	358	7	3	3	11	9	4	16	12	12	24	10	2	(17)
(18)		PrecStd	92	17	16	20	16	20	27	28	45	29	20	21	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.1	1.6	6.6	22.5	28.7	31.1	32.1	32.5	26.0	18.2	9.0	2.3	(19)
(20)			MCWB	0.3	0.4	3.1	13.5	17.2	20.1	20.2	19.8	16.2	11.7	7.8	1.6	(20)
(21)		2%	DB	0.2	0.6	4.2	18.7	26.0	28.5	29.9	29.3	22.5	14.7	6.4	1.1	(21)
(22)			MCWB	-0.4	-0.1	1.6	11.5	15.9	19.2	20.4	19.8	15.3	10.1	5.4	0.4	(22)
(23)		5%	DB	-1.0	-0.2	2.6	15.1	23.6	26.6	28.0	26.6	19.8	12.1	4.4	0.3	(23)
(24)			MCWB	-1.7	-0.8	0.6	9.4	14.8	18.4	19.7	18.9	14.2	9.0	3.5	-0.2	(24)
(25)		10%	DB	-2.6	-2.0	1.4	12.0	21.3	24.6	26.2	24.1	17.7	10.1	2.3	-1.0	(25)
(26)			MCWB	-3.3	-2.7	0.1	7.7	13.7	17.5	19.0	17.9	13.4	8.1	1.5	-1.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.6	0.9	3.5	14.0	19.0	21.7	22.6	21.7	17.6	12.8	8.0	1.7	(27)
(28)			MCDWB	1.0	1.1	5.8	21.4	25.7	27.9	28.6	28.2	22.8	15.9	8.8	2.0	(28)
(29)		2%	WB	-0.3	0.1	2.0	11.8	17.0	20.2	21.4	20.6	16.0	10.8	5.6	0.6	(29)
(30)			MCDWB	0.1	0.5	3.5	17.9	24.2	26.8	27.4	27.4	20.8	13.8	6.3	1.0	(30)
(31)		5%	WB	-1.6	-0.9	1.0	10.0	15.6	19.2	20.6	19.4	14.8	9.5	3.6	-0.2	(31)
(32)			MCDWB	-1.0	-0.2	2.1	14.3	22.0	25.2	26.4	25.6	18.8	11.6	4.3	0.3	(32)
(33)		10%	WB	-3.2	-2.6	0.2	7.9	14.2	18.1	19.7	18.3	13.7	8.2	1.6	-1.5	(33)
(34)			MCDWB	-2.7	-1.9	1.3	12.0	20.0	23.4	24.9	23.2	17.3	10.1	2.2	-1.0	(34)
(35)	Mean Daily Temperature Range	MDBR	6.0	6.8	7.1	8.4	10.6	9.9	10.1	9.4	8.2	5.6	4.3	5.4	(35)	
(36)		5% DB	MCDBR	5.2	5.0	7.3	12.8	13.8	12.6	12.8	12.6	11.9	9.3	4.7	4.3	(36)
(37)			MCWBR	5.1	4.6	5.5	7.2	6.7	5.5	5.4	5.2	6.1	5.8	4.3	4.2	(37)
(38)			5% WB	MCDBR	5.2	4.7	5.9	12.0	12.7	11.2	11.5	11.5	10.5	8.3	4.5	4.0
(39)		MCWBR		5.3	4.6	4.9	7.4	6.6	5.6	5.5	5.5	6.0	5.7	4.3	4.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.291	0.316	0.371	0.402	0.389	0.385	0.407	0.425	0.372	0.350	0.310	0.286	(40)	
(41)		taud	2.026	2.029	1.950	2.098	2.305	2.367	2.314	2.237	2.357	2.285	2.141	2.003	(41)	
(42)		Ebn at Noon	544	703	754	804	848	857	826	777	771	673	527	432	(42)	
(43)		Edh at Noon	63	95	134	136	118	113	117	118	91	75	56	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.62	1.56	2.95	4.27	5.33	5.72	5.67	4.30	2.65	1.18	0.49	0.35	(44)	
(45)		RadStd	0.09	0.22	0.30	0.46	0.53	0.48	0.55	0.40	0.32	0.21	0.10	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page