

YANAUL, Russian Federation

WMO: 284190

Lat: 56.2767N

Lon: 54.9690E

Elev: 326

StdP: 14.52

Time Zone: 5.00 (E05)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.7	-20.0	-30.4	1.0	-26.8	-24.1	1.5	-19.6	28.0	20.2	27.1	20.9	1.3	160	0.627

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	86.0	68.8	82.8	67.1	79.5	65.3	70.7	82.6	68.9	80.0	66.9	77.0	7.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	98.4	77.0	64.7	92.6	74.5	63.0	87.0	72.2	34.7	83.0	33.2	80.1	31.6	76.8	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.1	22.0	18.4	-37.6	91.1	7.6	4.2	-43.0	94.1	-47.4	96.6	-51.7	98.9	-57.2	101.9		
(5)			-37.6	73.8	7.5	2.4	-43.0	75.5	-47.4	76.9	-51.6	78.2	-57.1	80.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.8	9.5	9.3	21.4	37.1	52.4	61.1	66.1	60.4	51.4	39.3	21.1	10.1		
	DBStd	23.28	14.17	14.99	8.98	10.55	8.93	7.55	6.03	6.99	7.89	7.85	12.99	15.00		
	HDD50	6302	1256	1138	887	404	83	6	0	4	77	343	868	1236		
	HDD65	10498	1721	1558	1352	836	399	163	63	179	412	796	1318	1701		
	CDD50	1470	0	0	0	18	156	340	500	325	119	12	0	0		
	CDD65	192	0	0	0	0	7	47	98	36	4	0	0	0		
	CDH74	2229	0	0	0	3	143	539	1071	407	66	0	0	0		
	CDH80	622	0	0	0	0	16	156	308	128	14	0	0	0		
	WSAvg	7.3	8.7	9.0	8.9	7.1	7.4	6.0	4.4	5.2	6.1	8.4	8.0	8.9		
	PrecAvg	20.2	1.2	0.9	1.0	1.0	1.7	2.4	2.1	2.3	2.0	2.3	1.7	1.2		
(15) Precipitation	PrecMax	27.1	2.2	1.5	2.0	2.4	3.3	4.7	4.4	5.0	4.9	3.9	2.8	2.1		
	PrecMin	14.2	0.2	0.2	0.0	0.0	0.6	0.4	0.5	0.4	0.2	0.5	0.2	0.4		
	PrecStd	2.8	0.5	0.4	0.5	0.7	0.8	1.1	1.1	1.0	1.1	0.9	0.7	0.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.1	35.5	39.7	73.0	82.7	91.2	89.2	89.7	81.7	66.2	42.9	35.3		
		MCWB	33.2	33.1	35.6	56.4	60.7	68.7	69.9	67.8	61.4	52.6	41.2	33.4		
	2%	DB	32.5	33.7	36.9	66.2	78.6	84.1	86.2	83.3	73.8	61.0	40.3	33.6		
		MCWB	31.3	32.4	34.1	51.8	60.5	67.7	69.4	67.3	59.4	50.3	38.9	32.4		
	5%	DB	30.4	32.2	35.3	60.1	74.4	80.0	83.7	78.2	69.1	55.7	37.7	32.0		
		MCWB	29.2	31.2	33.2	49.7	58.9	66.1	68.7	65.0	58.0	49.0	36.2	31.2		
	10%	DB	27.8	29.9	33.8	53.7	69.9	76.1	80.6	73.4	64.1	51.3	35.3	29.4		
		MCWB	26.7	28.8	31.8	46.3	56.6	64.3	67.3	62.8	55.6	47.4	34.0	28.6		
	0.4%	WB	33.2	33.8	36.4	56.9	64.8	71.9	72.9	72.2	65.4	55.2	41.5	34.0		
		MCDB	33.5	34.5	38.1	71.6	76.6	84.6	84.4	84.0	74.6	60.4	42.1	34.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	31.5	32.5	34.8	53.2	62.1	69.4	71.2	68.3	60.9	52.3	38.9	32.8		
		MCDB	32.3	33.3	36.4	63.5	74.2	81.4	83.2	79.3	69.8	59.3	39.9	33.6		
	5%	WB	29.3	31.1	33.6	49.7	59.9	67.4	69.8	66.0	58.7	49.5	36.6	31.1		
		MCDB	30.3	32.0	35.2	59.5	71.4	77.9	81.5	76.3	67.2	54.3	37.5	32.0		
	10%	WB	26.9	28.8	32.2	46.2	57.6	65.2	68.1	63.9	56.7	47.1	34.2	28.6		
		MCDB	27.9	29.9	33.6	53.6	69.5	74.2	78.2	71.8	64.1	51.4	35.0	29.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	15.1	15.0	17.1	19.8	20.0	20.8	18.1	17.3	10.8	10.5	12.8		
		MCDBR	11.1	9.2	11.0	26.7	27.9	26.5	26.4	26.6	25.5	20.9	9.1	10.5		
		MCWBR	11.1	8.8	9.2	14.8	13.7	12.4	11.5	11.7	12.6	12.2	8.4	10.3		
		MCDBR	11.3	9.6	9.3	25.1	25.3	23.6	24.6	23.4	21.9	17.9	8.6	10.2		
	5% WB	MCWBR	11.2	9.3	8.2	14.5	14.0	12.1	11.8	11.5	12.4	11.6	8.3	10.1		
(40) Clear-Sky Solar Irradiance	taub		0.299	0.322	0.377	0.410	0.399	0.394	0.414	0.435	0.381	0.358	0.317	0.295		
	taud		2.009	2.011	1.924	2.059	2.264	2.333	2.287	2.201	2.322	2.251	2.123	1.984		
	Ebn at Noon		173	222	238	253	266	269	260	244	242	212	168	138		
	Edh at Noon		21	31	44	45	39	37	38	39	30	25	19	17		
(44) All-Sky Solar Radiation	RadAvg		220	526	971	1361	1703	1810	1811	1389	857	373	168	123		
	RadStd		30	68	97	154	170	160	187	122	88	74	35	28		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page