

TARA, Russian Federation

WMO: 284930

Lat: 56.900N

Lon: 74.383E

Elev: 73

StdP: 100.45

Time Zone: 6.00 (E06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.3	-33.2	-39.0	0.1	-36.1	-36.1	0.1	-33.1	6.8	-8.6	6.1	-9.7	0.8	60	0.604

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	29.2	19.8	27.6	19.0	25.9	18.2	21.1	26.9	20.1	25.7	19.1	24.3	3.0	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.9	24.6	18.0	13.0	23.1	17.0	12.2	21.9	61.6	27.0	58.1	25.6	54.7	24.4	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.9	6.1	5.3	DB	-40.0	32.0	4.0	1.7	-42.9	33.2	-45.2	34.2	-47.5	35.2	-50.4	36.4	(4)
(5)			WB	-39.9	22.7	3.8	1.1	-42.6	23.4	-44.9	24.1	-47.0	24.7	-49.8	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	1.1	-19.0	-15.9	-6.9	2.8	11.0	16.7	18.3	15.4	9.5	2.7	-7.9	-15.1	(6)
(7)		DBStd	14.33	8.24	7.60	6.14	5.88	5.41	4.68	3.75	3.87	4.25	4.87	7.94	8.47	(7)
(8)		HDD10.0	4041	899	726	523	226	54	6	0	3	60	230	536	778	(8)
(9)		HDD18.3	6414	1158	959	781	468	233	84	49	109	266	485	786	1036	(9)
(10)		CDD10.0	774	0	0	0	8	86	207	256	169	45	3	0	0	(10)
(11)		CDD18.3	106	0	0	0	0	7	35	47	17	1	0	0	0	(11)
(12)		CDH23.3	1053	0	0	0	3	119	349	413	151	18	0	0	0	(12)
(13)		CDH26.7	242	0	0	0	1	28	85	96	29	2	0	0	0	(13)
(14)	Wind	WSAvg	2.4	2.2	2.3	2.7	2.8	2.8	2.3	2.1	2.1	2.3	2.5	2.6	2.4	(14)
(15)	Precipitation	PrecAvg	442	20	13	14	26	39	65	68	61	46	37	29	25	(15)
(16)		PrecMax	640	49	36	34	61	125	174	184	129	109	108	51	53	(16)
(17)		PrecMin	290	5	2	0	2	8	8	5	10	6	9	4	1	(17)
(18)		PrecStd	91	10	7	9	17	26	40	43	29	25	19	12	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.1	1.8	7.2	22.4	29.7	31.1	31.2	29.7	25.7	17.5	6.6	1.8	(19)
(20)			MCWB	-0.9	-0.1	2.9	12.8	16.9	19.9	21.5	20.2	15.7	10.5	4.5	0.9	(20)
(21)		2%	DB	-2.3	-0.3	4.8	17.6	26.5	29.1	29.1	27.0	22.1	14.4	4.3	0.3	(21)
(22)			MCWB	-3.0	-1.5	1.5	10.3	15.6	19.2	20.6	19.4	14.6	9.1	3.2	-0.6	(22)
(23)		5%	DB	-4.4	-2.2	3.1	14.4	24.0	27.1	27.5	24.9	19.2	12.0	2.6	-1.7	(23)
(24)			MCWB	-5.0	-3.2	0.6	8.5	14.4	18.6	19.7	18.0	13.4	8.0	1.6	-2.5	(24)
(25)		10%	DB	-6.8	-4.7	1.6	11.8	21.3	25.2	25.8	22.7	16.9	9.8	1.2	-3.8	(25)
(26)			MCWB	-7.4	-5.7	-0.4	6.9	13.2	17.9	19.1	17.4	12.3	6.8	0.3	-4.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.7	0.2	3.3	13.4	18.2	22.2	22.8	21.6	17.4	11.5	4.7	1.1	(27)
(28)			MCDWB	-0.2	1.5	6.4	20.5	28.1	28.4	29.7	28.0	23.4	15.0	5.9	1.6	(28)
(29)		2%	WB	-3.1	-1.5	1.9	10.7	16.3	20.5	21.5	20.0	15.3	10.1	3.3	-0.5	(29)
(30)			MCDWB	-2.3	-0.4	4.0	16.7	24.8	26.3	27.6	25.1	20.5	13.5	4.3	0.2	(30)
(31)		5%	WB	-5.0	-3.2	0.9	9.0	14.9	19.5	20.5	18.8	13.9	8.5	1.7	-2.4	(31)
(32)			MCDWB	-4.3	-2.2	2.8	14.1	22.2	25.5	26.2	23.6	18.3	11.5	2.4	-1.7	(32)
(33)		10%	WB	-7.4	-5.7	-0.2	7.2	13.6	18.4	19.5	17.7	12.5	7.0	0.5	-4.5	(33)
(34)			MCDWB	-6.8	-4.7	1.5	11.4	20.1	24.1	24.6	21.9	16.2	9.8	1.1	-3.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	10.3	10.3	9.9	11.6	10.5	9.9	9.8	9.1	6.8	6.3	7.7	(35)
(36)			MCDBR	7.0	8.1	9.7	14.2	16.1	13.7	12.5	13.3	13.5	11.3	5.2	7.2	(36)
(37)			MCWBR	6.8	7.4	7.2	8.3	7.2	6.4	5.6	6.5	7.2	7.0	4.6	7.0	(37)
(38)		5% WB	MCDWR	7.0	7.8	8.4	13.3	14.5	11.9	11.6	11.5	12.2	10.2	5.1	7.1	(38)
(39)			MCWBR	6.8	7.1	6.5	8.2	7.1	6.2	5.6	6.3	6.9	6.9	4.8	6.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.278	0.314	0.372	0.412	0.403	0.410	0.427	0.420	0.370	0.352	0.312	0.282	(40)	
(41)		taud	2.027	2.011	1.920	2.043	2.235	2.290	2.245	2.238	2.337	2.228	2.072	1.969	(41)	
(42)		Ebn at Noon	562	702	749	791	833	831	805	781	771	663	509	426	(42)	
(43)		Edh at Noon	61	96	138	143	126	122	125	118	92	78	59	50	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.75	1.78	3.24	4.44	5.14	5.72	5.27	4.11	2.74	1.34	0.61	0.45	(44)	
(45)		RadStd	0.07	0.12	0.23	0.41	0.48	0.47	0.38	0.39	0.29	0.15	0.12	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page