

ASZKINO, Russian Federation

WMO: 285220

Lat: 56.110N

Lon: 56.574E

Elev: 678

StdP: 14.34

Time Zone: 5.00 (E05)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.9	-17.8	-29.7	1.1	-23.9	-22.8	1.6	-17.6	23.4	23.9	22.3	26.8	3.2	90	0.638

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	86.0	66.0	82.5	65.6	79.2	64.2	69.1	80.6	67.6	78.9	66.0	76.3	7.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	95.5	73.6	63.6	90.3	72.2	62.1	85.5	71.0	33.6	80.6	32.4	79.0	31.1	76.1	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.7	19.4	17.3	-32.3	89.7	7.1	4.1	-37.4	92.7	-41.5	95.1	-45.5	97.4	-50.7	100.4		
(5)			-32.4	71.9	7.0	1.5	-37.5	73.0	-41.6	73.9	-45.5	74.8	-50.6	75.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.5	6.6	10.1	23.0	39.1	53.8	61.2	64.4	62.5	51.5	38.2	24.8	13.0		
	DBStd	22.74	13.75	11.57	9.24	8.73	8.78	8.24	6.93	7.75	7.78	8.38	10.87	13.33		
	HDD50	6070	1345	1118	837	346	61	12	1	5	70	373	757	1145		
	HDD65	10243	1810	1538	1302	777	358	166	96	142	408	829	1207	1610		
	CDD50	1512	0	0	0	20	180	347	447	392	117	9	0	0		
	CDD65	209	0	0	0	0	12	51	77	65	4	0	0	0		
	CDH74	2203	0	0	0	5	172	511	821	658	36	0	0	0		
	CDH80	608	0	0	0	0	21	128	231	225	3	0	0	0		
	CDH80	608	0	0	0	0	21	128	231	225	3	0	0	0		
(14) Wind	WSAvg	7.5	7.4	7.3	8.5	8.1	7.9	7.3	6.3	6.3	6.7	7.8	8.2	7.7		
(15) Precipitation	PrecAvg	25.1	1.6	1.3	1.1	1.1	1.6	2.8	2.7	2.5	2.1	2.5	2.0	1.7		
	PrecMax	30.3	3.2	2.9	2.4	2.3	3.2	6.0	6.5	5.5	4.3	4.6	4.0	3.0		
	PrecMin	18.9	0.3	0.2	0.1	0.1	0.4	0.9	0.2	0.6	0.7	0.4	0.7	0.2		
	PrecStd	3.5	0.6	0.6	0.7	0.7	0.8	1.5	1.7	1.5	1.1	1.2	1.0	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.8	34.4	45.9	72.9	82.9	88.2	91.1	91.3	78.8	64.4	49.4	34.9		
		MCWB	32.3	32.0	38.3	54.1	63.5	67.7	67.5	65.8	58.9	50.2	46.0	31.9		
	2%	DB	31.4	32.3	41.1	64.8	78.8	83.8	85.5	86.2	72.8	58.8	44.7	33.2		
		MCWB	29.9	30.9	35.6	51.3	60.4	65.6	66.7	65.8	58.4	48.4	42.9	31.8		
	5%	DB	28.8	29.6	37.8	58.4	74.9	79.8	82.1	81.3	68.0	54.1	40.9	32.1		
		MCWB	27.5	27.6	33.9	47.7	58.9	64.8	66.2	65.7	56.9	46.6	39.5	31.0		
	10%	DB	25.0	26.2	35.0	52.5	70.7	76.1	78.7	76.6	63.9	50.5	37.1	29.8		
		MCWB	23.7	24.2	32.0	44.5	56.4	63.3	65.1	64.1	55.3	45.6	35.5	28.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.6	32.9	39.6	55.6	65.4	69.8	71.1	70.1	62.9	52.9	46.7	33.3		
		MCDB	33.1	34.0	43.8	69.8	76.9	81.4	81.5	82.3	72.5	59.5	50.0	33.7		
	2%	WB	30.1	31.1	36.4	52.2	62.2	68.0	69.5	68.2	60.3	50.0	43.0	32.3		
		MCDB	31.2	32.2	39.9	63.2	75.0	78.8	80.7	80.4	68.3	56.1	44.7	33.1		
	5%	WB	27.5	27.9	34.2	48.6	59.9	66.5	68.1	66.6	58.3	47.7	39.4	31.0		
		MCDB	28.7	29.3	36.8	56.6	72.7	76.9	79.5	78.3	65.3	52.7	41.1	32.3		
	10%	WB	23.8	24.4	32.4	45.4	57.7	64.5	66.3	64.9	56.4	45.7	35.6	28.3		
		MCDB	25.1	26.0	34.9	52.3	68.4	74.3	76.1	74.8	62.8	50.3	36.8	29.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	14.5	14.4	15.1	21.1	19.2	19.0	18.7	15.2	10.7	8.1	9.9		
		MCDBR	8.3	11.1	15.3	23.5	26.8	24.1	25.5	26.3	21.7	19.3	9.2	6.5		
		MCWBR	7.8	9.5	10.9	12.6	12.5	9.7	9.8	9.7	10.7	11.6	7.3	6.3		
	5% WB	MCDBR	8.2	9.6	11.8	20.9	24.8	20.8	22.1	22.8	18.2	16.3	8.2	6.7		
		MCWBR	8.1	8.9	9.1	11.6	12.5	10.3	9.5	9.9	9.8	10.8	7.0	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.294	0.318	0.372	0.407	0.398	0.391	0.412	0.431	0.379	0.354	0.314	0.292		
	taud		2.017	2.022	1.934	2.065	2.261	2.340	2.289	2.210	2.323	2.260	2.124	1.985		
	Ebn at Noon		178	226	240	254	267	270	261	246	243	215	171	142		
	Edh at Noon		21	31	44	45	39	37	38	39	30	25	19	17		
(44) All-Sky Solar Radiation	RadAvg		219	522	956	1338	1640	1751	1750	1348	836	370	174	127		
	RadStd		30	70	93	164	171	186	186	140	75	77	37	29		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page