

SAMARA SMYSHLYAEVKA, Russian Federation

WMO: 288070

Lat: 53.250N

Lon: 50.450E

Elev: 131

StdP: 14.63

Time Zone: 4.00 (E04)

Period: 96-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.4	-13.6	-24.6	1.4	-19.2	-18.7	2.0	-13.1	23.6	21.0	22.6	19.9	2.8	170	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	92.2	69.3	88.3	68.6	85.0	67.2	71.7	86.1	70.3	84.7	68.8	82.3	7.9	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	100.0	77.8	65.5	94.5	75.9	63.9	89.5	74.6	35.5	86.1	34.3	84.6	33.0	82.2	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.6	20.2	17.5	DB	-24.4	96.6	5.1	3.2	-28.1	98.9	-31.0	100.7	-33.9	102.5	-37.6	104.8	(4)
(5)			WB	-24.6	74.9	4.9	2.2	-28.1	76.5	-31.0	77.8	-33.8	79.0	-37.3	80.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.8	13.1	12.4	25.1	44.4	57.3	65.9	70.8	66.9	55.3	43.0	28.7	16.7
	DBStd	23.12	13.41	12.59	9.38	10.07	8.36	7.80	6.42	7.33	7.12	7.75	10.98	14.03
	HDD50	5167	1143	1053	773	223	30	2	0	0	26	245	640	1032
	HDD65	8937	1608	1473	1238	619	260	82	22	66	300	683	1089	1497
	CDD50	2173	0	0	0	56	258	478	645	523	186	27	0	0
	CDD65	469	0	0	0	2	23	108	202	124	10	0	0	0
	CDH74	5507	0	0	0	35	379	1214	2263	1435	181	0	0	0
	CDH80	2110	0	0	0	3	92	441	935	604	35	0	0	0
Wind	WSAvg	7.2	7.2	7.3	8.0	8.1	8.2	7.0	6.1	6.2	6.1	7.2	7.9	7.4
Precipitation	PrecAvg	20.9	1.8	1.3	1.2	1.5	1.1	2.3	2.3	1.9	1.7	2.0	1.9	1.9
	PrecMax	25.5	3.6	3.6	3.4	3.9	2.6	6.6	4.6	4.3	4.1	4.2	5.9	5.2
	PrecMin	11.2	0.6	0.0	0.1	0.0	0.0	0.0	0.3	0.0	0.0	0.5	0.3	0.4
	PrecStd	3.0	0.8	0.9	0.7	1.0	0.7	1.5	1.4	1.2	1.1	1.0	1.2	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.9	36.4	53.1	78.3	86.9	95.4	97.4	97.3	84.3	70.0	53.1	40.1
		MCWB	34.9	33.9	45.2	57.9	63.7	68.2	69.1	69.0	61.4	54.7	50.4	38.3
	2%	DB	35.0	35.0	44.4	72.5	82.4	90.0	91.9	91.2	79.4	64.7	47.6	36.7
		MCWB	33.5	33.3	38.7	55.1	62.4	67.9	70.1	68.4	61.0	52.3	44.6	34.7
	5%	DB	33.6	33.7	39.4	67.7	78.3	85.0	88.5	86.8	74.3	59.6	44.3	35.1
		MCWB	32.5	32.5	35.6	52.8	60.1	67.2	69.6	67.8	59.6	50.5	42.1	33.5
	10%	DB	31.5	31.3	36.7	62.1	73.9	80.8	85.5	82.1	69.2	55.6	41.3	33.7
		MCWB	30.4	30.0	33.9	50.0	58.4	65.5	68.4	65.9	57.4	49.1	39.4	32.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.6	34.5	45.4	60.0	67.4	72.0	74.6	72.3	65.9	57.5	51.4	39.1
		MCDB	36.6	35.6	53.2	74.7	81.5	87.6	87.7	88.9	76.7	63.1	53.1	40.0
	2%	WB	33.9	33.5	38.9	57.1	64.3	70.2	72.6	70.5	62.9	54.3	45.4	35.2
		MCDB	34.7	34.7	43.7	69.9	78.2	85.3	86.0	87.0	74.4	61.5	47.3	36.3
	5%	WB	32.6	32.5	36.0	53.6	62.1	68.5	71.0	68.9	60.9	51.7	42.3	33.7
		MCDB	33.7	33.7	38.6	65.5	75.9	81.7	84.2	84.4	71.7	58.2	44.1	34.6
	10%	WB	30.3	29.9	34.2	50.5	59.6	66.8	69.8	66.8	58.5	49.4	39.6	32.5
		MCDB	31.5	31.3	36.4	61.3	70.8	78.6	82.9	79.6	67.9	55.1	41.2	33.7
Mean Daily Temperature Range	5% DB	MDBR	12.3	15.0	15.1	19.3	22.4	21.6	22.1	22.7	21.3	15.8	9.5	10.8
		MCDBR	9.9	9.6	15.3	29.0	29.5	27.4	27.6	29.8	30.5	24.9	11.5	7.5
		MCWBR	9.3	8.6	10.6	14.4	13.4	11.3	10.8	11.8	14.7	14.3	9.8	7.2
	5% WB	MCDBR	9.9	8.9	14.1	26.2	26.9	23.5	24.0	26.9	26.2	19.9	10.3	7.0
		MCWBR	9.5	8.7	10.4	13.9	13.3	10.8	10.4	11.7	13.9	12.5	9.4	6.9
Clear-Sky Solar Irradiance	taub	0.305	0.328	0.375	0.432	0.408	0.401	0.411	0.430	0.385	0.355	0.331	0.303	
	taud	2.063	2.031	1.995	2.086	2.271	2.343	2.312	2.240	2.338	2.332	2.235	2.085	
	Ebn at Noon	198	234	249	251	267	270	264	251	248	229	193	173	
	Edh at Noon	24	34	43	45	40	37	38	39	31	25	20	19	
All-Sky Solar Radiation	RadAvg	292	630	1060	1376	1789	1927	1905	1559	1031	520	222	162	
	RadStd	46	63	122	142	133	212	161	128	145	90	37	45	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+1.96	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page