

SAMARA OGMS, Russian Federation

WMO: 289000

Lat: 53.2480N

Lon: 50.2069E

Elev: 139

StdP: 99.66

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-26.2	-23.1	-29.8	0.2	-26.3	-26.2	0.4	-22.6	12.6	-6.1	11.2	-5.3	2.8	350	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	32.9	19.5	30.9	19.0	29.0	18.3	21.3	28.1	20.5	27.4	19.6	26.3	3.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	14.2	23.8	18.1	13.3	22.6	17.1	12.4	22.2	62.6	28.0	59.5	27.3	56.7	25.9	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.1	8.1	DB	-29.0	35.4	3.4	1.9	-31.4	36.7	-33.4	37.8	-35.3	38.9	-37.8	40.3	(4)
(5)			WB	-29.2	22.8	3.4	1.3	-31.6	23.7	-33.6	24.5	-35.5	25.2	-37.9	26.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.7	-10.3	-10.4	-3.6	6.8	14.9	19.0	21.2	19.6	13.5	6.0	-1.8	-7.6	(6)
(7)		DBStd	12.65	6.88	6.72	5.02	5.45	4.93	4.48	3.59	4.35	4.24	4.57	5.65	6.44	(7)
(8)		HDD10.0	2814	629	571	421	126	13	1	0	0	14	139	353	546	(8)
(9)		HDD18.3	4884	887	804	679	346	129	45	14	37	153	382	603	804	(9)
(10)		CDD10.0	1245	0	0	0	31	164	271	346	298	119	16	0	0	(10)
(11)		CDD18.3	275	0	0	0	1	22	65	102	77	9	0	0	0	(11)
(12)		CDH23.3	2755	0	0	0	10	259	654	984	758	89	0	0	0	(12)
(13)		CDH26.7	986	0	0	0	1	64	239	365	300	16	0	0	0	(13)
(14)	Wind	WSAvg	4.0	4.2	4.2	4.3	4.2	4.1	3.8	3.4	3.6	3.6	3.9	4.1	4.2	(14)
(15)	Precipitation	PrecAvg	495	45	35	31	33	39	48	47	39	44	43	48	42	(15)
(16)		PrecMax	772	93	71	70	108	102	117	125	108	181	98	136	108	(16)
(17)		PrecMin	309	3	1	2	0	4	3	0	0	1	2	5	2	(17)
(18)		PrecStd	116	20	18	16	25	22	33	30	29	41	25	32	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.2	2.8	10.0	24.9	30.2	34.2	35.1	35.8	28.9	20.1	11.1	3.9	(19)
(20)			MCWB	1.8	1.3	6.1	13.1	17.3	18.9	19.0	19.1	16.5	11.7	9.4	3.3	(20)
(21)		2%	DB	1.1	1.2	6.2	21.2	28.6	31.9	32.2	32.2	26.0	17.2	8.8	2.1	(21)
(22)			MCWB	0.7	0.7	3.4	11.5	16.3	18.7	19.7	19.2	15.8	11.1	7.4	1.5	(22)
(23)		5%	DB	0.1	0.2	4.0	18.9	26.2	29.8	30.2	30.0	23.2	15.0	6.8	1.1	(23)
(24)			MCWB	-0.2	-0.2	2.0	10.6	15.4	18.4	19.4	19.0	14.6	10.1	5.8	0.7	(24)
(25)		10%	DB	-1.0	-0.9	2.3	16.1	24.0	27.1	28.8	27.8	21.0	12.9	5.0	0.2	(25)
(26)			MCWB	-1.3	-1.4	1.0	9.2	14.4	17.9	18.9	18.2	13.9	9.0	4.2	-0.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.1	1.6	6.4	14.3	19.0	21.9	22.7	21.9	18.5	14.2	10.3	3.2	(27)
(28)			MCDWB	2.2	2.0	9.4	21.9	27.1	29.0	29.3	29.6	24.0	17.6	11.0	3.4	(28)
(29)		2%	WB	0.6	0.7	3.6	12.7	17.5	20.6	21.6	20.8	17.0	12.1	7.3	1.6	(29)
(30)			MCDWB	0.8	1.0	5.7	19.6	26.1	27.9	27.7	28.5	23.5	16.1	8.0	1.8	(30)
(31)		5%	WB	-0.2	-0.1	2.2	11.0	16.5	19.6	20.8	19.7	15.8	10.6	5.6	0.6	(31)
(32)			MCDWB	0.0	0.2	3.5	17.9	24.2	26.8	27.1	27.1	21.1	13.7	6.3	0.9	(32)
(33)		10%	WB	-1.5	-1.4	1.2	9.7	15.3	18.6	20.0	18.7	14.6	9.6	4.1	-0.1	(33)
(34)			MCDWB	-1.2	-1.0	2.1	15.3	22.1	25.2	26.2	25.7	19.9	12.3	4.7	0.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.1	7.2	7.5	9.7	11.2	10.7	10.6	9.6	7.0	4.9	5.3	(35)	
(36)			MCDBR	5.5	5.7	7.9	13.7	14.0	13.7	13.1	13.4	13.6	11.1	6.2	4.2	(36)
(37)			MCWBR	5.3	5.2	5.7	6.9	5.9	5.2	4.8	4.9	6.3	6.4	5.4	4.0	(37)
(38)		5% WB	MCDWR	5.5	5.5	6.8	12.8	12.5	11.7	11.2	11.8	11.6	9.4	5.5	4.1	(38)
(39)			MCWBR	5.4	5.2	5.3	6.9	5.9	5.4	4.8	5.0	6.3	6.2	5.1	4.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.300	0.324	0.369	0.426	0.402	0.394	0.405	0.423	0.379	0.351	0.326	0.299	(40)	
(41)		taud	2.071	2.041	2.012	2.101	2.285	2.355	2.323	2.253	2.351	2.344	2.242	2.092	(41)	
(42)		Ebn at Noon	633	746	791	799	847	857	839	796	790	728	615	554	(42)	
(43)		Edh at Noon	74	105	134	141	123	116	118	120	96	78	64	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.91	1.97	3.35	4.34	5.63	6.08	6.01	4.91	3.24	1.64	0.70	0.50	(44)	
(45)		RadStd	0.15	0.20	0.38	0.44	0.41	0.64	0.50	0.40	0.45	0.28	0.11	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	+1.09	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page