

NAZIMOVO, Russian Federation

WMO: 290680

Lat: 59.513N

Lon: 90.928E

Elev: 218

StdP: 14.58

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-50.3	-43.2	-53.5	0.2	-50.0	-47.3	0.3	-43.3	16.5	4.7	14.9	1.8	1.0	320	0.648

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.2	83.6	66.7	80.1	65.5	76.9	63.6	69.1	78.7	67.4	76.9	65.7	74.1	5.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.9	96.3	72.9	64.1	90.2	71.2	62.3	84.7	70.0	33.4	78.6	32.1	77.3	30.7	74.2	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.9	13.8	11.9	DB	-52.9	89.1	4.9	2.5	-56.4	90.9	-59.3	92.3	-62.0	93.7	-65.5	95.5
			WB	-52.9	73.1	4.9	2.5	-56.4	74.8	-59.3	76.3	-62.0	77.7	-65.5	79.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.9	-10.6	-0.1	15.0	32.4	44.7	59.9	64.5	58.8	45.3	29.6	6.0	0.0
	DBStd	28.10	19.06	14.49	13.66	8.54	9.07	8.34	5.63	6.54	8.07	9.88	16.43	19.46
	HDD50	8832	1878	1403	1084	529	219	18	0	9	188	634	1321	1549
	HDD65	13282	2343	1823	1549	978	632	190	79	212	592	1099	1771	2014
	CDD50	1144	0	0	0	1	54	315	449	280	45	0	0	0
	CDD65	120	0	0	0	0	1	38	63	18	0	0	0	0
	CDH74	1328	0	0	0	0	32	496	604	192	4	0	0	0
	CDH80	283	0	0	0	0	4	125	120	34	0	0	0	0
	WSAvg	5.0	4.5	4.5	5.1	6.2	6.0	4.8	3.9	4.2	4.7	5.7	5.0	5.0
	PrecAvg	23.7	1.3	1.2	1.0	1.4	2.0	2.5	2.1	2.8	2.6	2.5	2.0	2.0
(15) Precipitation	PrecMax	28.7	2.0	1.7	1.8	3.2	3.8	5.2	4.1	5.7	4.9	3.4	3.5	3.5
	PrecMin	16.3	0.1	0.5	0.3	0.5	1.0	0.2	0.1	1.1	0.7	0.7	0.7	0.7
	PrecStd	3.8	0.4	0.3	0.5	0.7	0.7	1.3	1.2	1.0	1.1	0.7	0.6	0.8
	PrecStd	3.8	0.4	0.3	0.5	0.7	0.7	1.3	1.2	1.0	1.1	0.7	0.6	0.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.2	31.2	45.5	59.8	78.7	87.9	88.0	84.5	72.7	56.9	39.5	31.9
		MCWB	28.2	29.4	37.8	46.1	59.9	66.9	68.6	67.3	58.2	47.1	38.9	30.7
	2%	DB	24.1	28.3	40.0	54.5	71.4	83.6	83.8	79.3	66.7	50.0	35.0	29.0
		MCWB	23.0	27.0	33.7	43.5	54.6	65.6	67.6	65.9	56.5	43.8	34.3	28.0
	5%	DB	19.9	24.3	36.7	49.8	66.0	79.7	80.4	75.4	62.1	45.3	32.7	26.5
		MCWB	18.9	22.9	32.1	39.9	53.1	64.3	66.3	64.3	54.3	41.4	31.9	25.8
	10%	DB	15.6	20.6	33.7	45.1	60.2	75.7	77.5	71.0	58.0	41.8	29.5	22.8
		MCWB	14.7	19.2	30.8	37.8	49.0	62.2	64.6	62.1	52.8	39.0	28.3	21.9
	0.4%	WB	28.9	29.7	38.4	47.5	61.3	70.4	72.5	69.8	60.3	48.0	38.8	30.8
		MCDB	29.6	30.7	44.3	57.0	74.1	81.6	82.3	79.6	67.8	54.4	39.1	31.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	23.1	27.0	35.0	44.1	56.8	67.6	69.9	67.5	58.1	44.6	34.3	28.3
		MCDB	24.0	28.2	38.7	52.8	67.6	79.0	79.0	76.9	64.4	49.1	34.7	29.1
	5%	WB	18.9	23.0	32.7	41.3	54.2	65.7	68.3	65.6	55.7	42.1	32.2	25.7
		MCDB	19.7	24.1	36.1	48.7	64.3	76.8	77.5	72.7	61.4	45.1	32.8	26.4
	10%	WB	14.7	19.2	30.4	38.3	50.9	63.8	66.7	63.4	53.0	38.9	28.4	21.9
		MCDB	15.5	20.5	34.2	43.8	58.8	73.5	74.9	69.2	57.4	41.6	29.5	22.8
(35) Mean Daily Temperature Range	5% DB	MDBR	15.2	19.1	23.2	17.5	18.9	20.1	20.2	17.5	14.6	10.6	12.8	12.8
		MCDBR	14.4	17.8	20.6	24.4	28.0	28.4	26.3	24.9	23.3	15.8	8.9	10.3
		MCWBR	14.1	17.0	16.1	14.7	14.5	13.1	12.4	12.8	13.5	10.9	8.7	10.0
		MCDBR	14.5	17.6	17.7	22.2	25.9	24.4	22.3	21.4	20.2	13.9	8.9	9.8
	5% WB	MCWBR	14.2	16.9	14.3	14.6	14.6	12.4	11.8	11.9	12.6	10.3	8.8	9.9
		MCWBR	14.2	16.9	14.3	14.6	14.6	12.4	11.8	11.9	12.6	10.3	8.8	9.9
(40) Clear-Sky Solar Irradiance	taub		0.279	0.315	0.349	0.375	0.392	0.399	0.449	0.408	0.362	0.334	0.285	0.263
	taud		1.948	1.969	1.967	2.047	2.257	2.358	2.199	2.300	2.385	2.248	1.997	1.904
	Ebn at Noon		144	205	239	258	265	265	246	248	241	205	140	102
	Edh at Noon		17	29	40	44	38	36	41	34	27	22	16	12
(44) All-Sky Solar Radiation	RadAvg		156	442	861	1343	1553	1790	1662	1210	709	323	159	79
	RadStd		24	44	91	115	154	207	118	118	113	47	32	16

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page