

NAZIMOVO, Russian Federation

WMO: 290680

Lat: 59.513N

Lon: 90.928E

Elev: 67

StdP: 100.53

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-45.7	-41.8	-47.5	0.0	-45.5	-44.1	0.0	-41.8	7.4	-15.1	6.7	-16.8	0.4	320	0.648

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	28.7	19.3	26.7	18.6	24.9	17.6	20.6	25.9	19.7	24.9	18.7	23.4	2.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.8	22.7	17.8	12.9	21.8	16.8	12.1	21.1	59.9	25.9	56.8	25.2	53.6	23.5	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	6.2	5.3	-47.2	31.7	2.7	1.4	-49.1	32.7	-50.7	33.5	-52.2	34.3	-54.2	35.3		
(5)			-47.2	22.8	2.7	1.4	-49.1	23.8	-50.7	24.6	-52.2	25.4	-54.2	26.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.7	-23.6	-17.8	-9.4	0.2	7.0	15.5	18.0	14.9	7.4	-1.4	-14.5	-17.8	(6)
(7)		DBStd	15.61	10.59	8.05	7.59	4.74	5.04	4.63	3.13	3.63	4.48	5.49	9.13	10.81	(7)
(8)		HDD10.0	4907	1043	779	602	294	122	10	0	5	104	352	734	861	(8)
(9)		HDD18.3	7379	1302	1013	861	543	351	106	44	118	329	611	984	1119	(9)
(10)		CDD10.0	636	0	0	0	1	30	175	249	156	25	0	0	0	(10)
(11)		CDD18.3	67	0	0	0	0	1	21	35	10	0	0	0	0	(11)
(12)		CDH23.3	738	0	0	0	0	18	276	336	107	2	0	0	0	(12)
(13)		CDH26.7	157	0	0	0	0	2	69	67	19	0	0	0	0	(13)
(14)	Wind	WSAvg	2.2	2.0	2.0	2.3	2.7	2.2	1.8	1.9	2.1	2.5	2.2	2.2	(14)	
(15)	Precipitation	PrecAvg	603	34	31	26	35	52	63	53	72	67	64	52	50	(15)
(16)		PrecMax	730	52	44	45	81	97	131	103	146	125	86	89	88	(16)
(17)		PrecMin	413	2	13	7	12	26	5	2	27	19	17	18	18	(17)
(18)		PrecStd	97	11	8	12	17	18	33	30	26	28	18	16	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.5	-0.4	7.5	15.4	26.0	31.1	31.1	29.1	22.6	13.8	4.2	0.0	(19)
(20)			MCWB	-2.1	-1.4	3.2	7.8	15.5	19.4	20.3	19.6	14.5	8.4	3.9	-0.7	(20)
(21)		2%	DB	-4.4	-2.1	4.4	12.5	21.9	28.7	28.8	26.3	19.3	10.0	1.6	-1.7	(21)
(22)			MCWB	-5.0	-2.8	1.0	6.4	12.6	18.7	19.8	18.8	13.6	6.5	1.3	-2.2	(22)
(23)		5%	DB	-6.7	-4.3	2.6	9.9	18.9	26.5	26.9	24.1	16.7	7.4	0.4	-3.1	(23)
(24)			MCWB	-7.3	-5.1	0.1	4.4	11.7	17.9	19.0	17.9	12.4	5.2	0.0	-3.5	(24)
(25)		10%	DB	-9.1	-6.3	1.0	7.3	15.6	24.3	25.3	21.7	14.5	5.4	-1.4	-5.1	(25)
(26)			MCWB	-9.6	-7.1	-0.7	3.2	9.4	16.8	18.1	16.7	11.6	3.9	-2.1	-5.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.7	-1.3	3.5	8.6	16.3	21.3	22.5	21.0	15.7	8.9	3.8	-0.7	(27)
(28)			MCDWB	-1.3	-0.7	6.8	13.9	23.4	27.6	27.9	26.5	19.9	12.5	4.0	-0.3	(28)
(29)		2%	WB	-4.9	-2.8	1.7	6.7	13.8	19.8	21.1	19.7	14.5	7.0	1.3	-2.1	(29)
(30)			MCDWB	-4.4	-2.1	3.7	11.6	19.8	26.1	26.1	24.9	18.0	9.5	1.5	-1.6	(30)
(31)		5%	WB	-7.3	-5.0	0.4	5.2	12.3	18.7	20.2	18.7	13.2	5.6	0.1	-3.5	(31)
(32)			MCDWB	-6.8	-4.4	2.3	9.3	17.9	24.9	25.3	22.6	16.4	7.3	0.4	-3.1	(32)
(33)		10%	WB	-9.6	-7.1	-0.9	3.5	10.5	17.7	19.3	17.4	11.7	3.8	-2.0	-5.6	(33)
(34)			MCDWB	-9.1	-6.4	1.2	6.6	14.9	23.0	23.8	20.7	14.1	5.3	-1.4	-5.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	10.6	12.9	9.7	10.5	11.2	11.2	9.7	8.1	5.9	7.1	7.1	(35)
(36)			MCDBR	8.0	9.9	11.5	13.6	15.6	15.8	14.6	13.8	12.9	8.8	5.0	5.7	(36)
(37)			MCWBR	7.8	9.4	8.9	8.1	8.0	7.3	6.9	7.1	7.5	6.1	4.9	5.6	(37)
(38)		5% WB	MCDBR	8.0	9.8	9.8	12.3	14.4	13.6	12.4	11.9	11.2	7.7	5.0	5.5	(38)
(39)			MCWBR	7.9	9.4	7.9	8.1	8.1	6.9	6.6	6.6	7.0	5.7	4.9	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.279	0.315	0.349	0.375	0.392	0.399	0.449	0.408	0.362	0.334	0.285	0.263	(40)	
(41)		taud	1.948	1.969	1.967	2.047	2.257	2.358	2.199	2.300	2.385	2.248	1.997	1.904	(41)	
(42)		Ebn at Noon	453	647	753	813	834	835	775	781	761	645	442	321	(42)	
(43)		Edh at Noon	54	91	125	138	121	112	128	108	84	69	50	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.49	1.39	2.71	4.23	4.90	5.64	5.24	3.81	2.24	1.02	0.50	0.25	(44)	
(45)		RadStd	0.08	0.14	0.29	0.36	0.49	0.65	0.37	0.37	0.35	0.15	0.10	0.05	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page