

NOVYY VASYUGAN, Russian Federation

WMO: 292030

Lat: 58.5822N

Lon: 76.5095E

Elev: 263

StdP: 14.56

Time Zone: 7.00 (E07)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -36.7	(c) -31.6	(d) -42.0	(e) 0.5	(f) -35.9	(g) -36.8	(h) 0.7	(i) -31.7	(j) 16.2	(k) 14.6	(l) 14.3	(m) 13.6	(n) 2.4	(o) 340	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.7	(c) 85.2	(d) 65.6	(e) 82.0	(f) 64.3	(g) 78.7	(h) 63.0	(i) 68.5	(j) 79.6	(k) 66.7	(l) 77.2	(m) 65.3	(n) 74.8	(o) 7.1	(p) 310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	92.8	72.6	63.1	87.1	70.7	61.5	82.5	69.6	33.0	79.3	31.5	77.8	30.4	74.0	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	14.7	13.1	-42.8	88.5	6.7	1.1	-47.6	89.3	-51.5	89.9	-55.3	90.5	-60.1	91.3
			-42.6	70.9	5.9	3.0	-46.8	73.1	-50.3	74.8	-53.6	76.5	-57.9	78.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	32.8	-2.0	4.6	20.4	36.9	47.1	62.2	65.4	59.9	47.8	32.4	12.5	4.7
	DBStd	25.99	14.96	15.08	12.12	8.50	10.04	9.00	6.41	6.61	8.36	9.86	15.82	16.82
	HDD50	7622	1613	1272	917	400	182	17	0	4	139	549	1125	1404
	HDD65	11941	2078	1692	1382	844	563	154	74	185	516	1009	1575	1869
	CDD50	1351	0	0	0	7	92	383	479	311	75	4	0	0
	CDD65	195	0	0	0	0	8	70	88	27	2	0	0	0
	CDH74	1945	0	0	0	0	103	764	839	228	11	0	0	0
	CDH80	496	0	0	0	0	17	214	228	37	0	0	0	0
(14) Wind	WSAvg	6.4	5.8	6.1	7.2	7.4	8.0	5.9	5.7	5.7	6.1	6.7	6.6	6.0
(15) Precipitation	PrecAvg	28.7	1.8	1.4	1.8	1.7	2.2	2.9	3.0	3.3	2.4	2.8	3.0	2.4
	PrecMax	36.6	3.2	2.3	3.8	3.3	5.2	6.3	4.9	5.8	3.9	4.8	4.6	5.1
	PrecMin	21.1	0.3	0.2	0.4	0.3	1.0	1.2	1.0	1.3	0.6	1.2	0.9	0.9
	PrecStd	3.7	0.7	0.6	0.8	0.6	0.9	1.1	1.0	1.1	0.7	1.0	0.9	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.6	35.6	45.4	64.8	82.3	88.7	92.0	84.3	75.5	62.8	39.3	32.2
		MCWB	27.9	31.9	35.8	50.6	57.5	65.9	70.8	66.6	58.8	50.5	38.9	31.1
	2%	DB	25.6	32.7	40.9	59.5	76.7	85.7	85.3	79.5	69.8	54.7	34.9	30.4
		MCWB	24.5	30.4	33.4	47.7	56.9	65.1	66.4	64.6	57.8	46.5	33.8	29.5
	5%	DB	22.7	29.7	37.7	54.9	71.2	82.2	82.1	76.2	65.2	50.3	33.2	27.8
		MCWB	21.7	28.1	32.3	45.1	54.7	64.4	65.4	63.3	55.6	45.3	32.1	26.8
	10%	DB	18.9	24.1	35.1	51.4	64.9	78.5	78.7	72.8	60.6	46.0	31.8	24.5
		MCWB	17.9	22.3	31.6	42.5	52.0	62.7	63.8	62.3	53.0	41.8	30.8	23.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.9	33.0	37.3	53.4	60.8	69.9	72.9	68.8	61.3	51.7	38.6	31.2
		MCDB	28.1	34.9	43.3	61.4	75.2	81.4	85.2	78.6	70.5	61.6	39.0	31.5
	2%	WB	24.7	30.5	34.8	48.9	58.0	67.5	70.0	66.8	58.7	48.4	34.3	29.5
		MCDB	25.6	32.4	38.3	57.5	72.0	80.0	81.2	76.5	67.4	54.3	34.9	30.3
	5%	WB	21.8	28.1	33.3	45.8	55.6	66.0	67.4	65.1	56.4	45.2	32.4	26.8
		MCDB	22.8	29.9	36.3	54.2	68.8	78.6	77.5	73.3	63.9	49.7	33.0	27.8
	10%	WB	18.0	22.4	31.9	43.0	53.0	64.2	65.7	63.2	53.9	42.2	30.8	23.7
		MCDB	18.9	24.2	35.3	50.5	65.1	75.2	74.5	70.0	60.0	46.0	31.7	24.6
(35) Mean Daily Temperature Range	5% DB	MDBR	14.0	16.1	17.4	17.0	18.8	19.7	19.7	17.5	14.6	10.8	12.9	12.1
		MCDBR	12.4	10.7	17.3	23.1	26.8	25.6	25.3	23.8	20.8	16.3	7.9	10.2
		MCWBR	12.1	9.3	12.2	14.2	12.6	9.8	10.0	11.0	10.6	10.1	8.0	10.2
	5% WB	MCDBR	12.3	10.1	13.5	20.2	23.7	21.0	21.8	19.5	18.4	14.7	8.3	10.0
		MCWBR	12.1	9.0	10.4	13.2	12.9	9.4	10.4	9.8	10.0	10.0	8.3	10.0
(40) Clear-Sky Solar Irradiance	taub		0.274	0.310	0.364	0.394	0.394	0.410	0.439	0.415	0.366	0.340	0.297	0.272
	taud		2.009	2.017	1.946	2.068	2.281	2.311	2.214	2.266	2.359	2.273	2.077	1.955
	Ebn at Noon		162	215	236	254	265	262	250	247	242	208	151	116
	Edh at Noon		17	29	41	43	38	37	40	36	28	23	16	13
(44) All-Sky Solar Radiation	RadAvg		189	496	938	1343	1553	1755	1600	1197	774	377	163	107
	RadStd		21	41	70	141	161	173	143	126	96	34	33	15

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page