

MAYSK, Russian Federation

WMO: 292090

Lat: 57.811N

Lon: 77.217E

Elev: 327

StdP: 14.52

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -38.2	(c) -32.0	(d) -42.1	(e) 0.5	(f) -37.4	(g) -36.2	(h) 0.7	(i) -31.5	(j) 13.7	(k) 17.9	(l) 12.0	(m) 15.8	(n) 0.7	(o) 320	(p) 0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	83.6	67.4	80.3	65.8	77.2	64.1	70.1	79.0	68.0	76.7	66.1	74.6	4.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	100.5	74.7	64.8	93.0	72.4	62.8	86.6	70.4	34.4	79.2	32.6	76.7	31.1	74.7	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.3	(b) 12.0	(c) 10.7	(e) -44.9	(f) 88.6	(g) 7.9	(h) 2.9	(i) -50.6	(j) 90.7	(k) -55.2	(l) 92.4	(m) -59.6	(n) 94.0	(o) -65.4	(p) 96.0		
(a) 14.3	(b) 12.0	(c) 10.7	(e) -44.2	(f) 73.5	(g) 6.8	(h) 3.1	(i) -49.1	(j) 75.8	(k) -53.1	(l) 77.6	(m) -56.9	(n) 79.4	(o) -61.9	(p) 81.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	32.2	-3.5	3.7	20.2	35.4	47.8	59.9	63.0	57.4	47.2	34.6	16.0	3.4	
	DBStd	25.37	15.59	14.19	11.48	10.59	9.87	8.32	6.15	6.52	7.78	9.43	14.80	16.27	
	HDD50	7614	1659	1297	924	445	166	18	1	11	144	483	1020	1446	
	HDD65	12065	2124	1717	1389	889	538	190	111	248	535	943	1470	1911	
	CDD50	1131	0	0	0	7	98	316	404	241	60	5	0	0	
	CDD65	107	0	0	0	0	5	38	49	14	1	0	0	0	
	CDH74	1438	0	0	0	1	127	550	567	171	22	0	0	0	
	CDH80	305	0	0	0	0	21	135	122	24	3	0	0	0	
Wind	WSAvg	4.1	3.6	4.4	5.0	5.2	5.0	3.5	3.0	3.3	3.7	4.3	4.5	4.2	
Precipitation	PrecAvg	21.7	1.1	0.8	0.9	1.2	1.9	3.0	3.0	3.0	2.1	1.9	1.7	1.6	
	PrecMax	31.1	2.2	1.8	2.3	2.9	4.8	14.5	6.0	5.0	4.3	4.0	2.5	3.5	
	PrecMin	14.5	0.2	0.0	0.1	0.1	0.5	1.1	0.7	1.0	0.2	0.7	0.4	0.4	
	PrecStd	3.9	0.6	0.4	0.6	0.7	1.0	2.6	1.3	1.1	1.0	0.9	0.5	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.5	35.1	48.2	68.7	82.7	87.2	88.0	83.3	76.8	63.3	42.2	33.3	
		MCWB	30.3	32.1	38.5	56.2	62.1	66.9	70.8	70.0	60.2	51.3	39.8	32.4	
	2%	DB	27.0	31.0	42.6	61.2	77.8	84.2	83.2	78.6	70.9	57.0	38.3	31.4	
		MCWB	25.8	29.0	35.1	49.0	59.0	66.7	68.2	66.4	58.7	48.2	36.8	30.6	
	5%	DB	23.1	28.1	38.6	56.2	72.4	80.3	80.1	74.9	65.9	52.3	35.2	28.2	
		MCWB	22.2	26.2	33.4	46.1	56.4	65.1	67.1	64.4	55.8	45.7	34.1	27.0	
	10%	DB	18.9	24.0	35.5	51.9	66.9	76.6	76.8	71.0	61.1	48.2	33.2	24.3	
		MCWB	17.9	22.3	31.7	43.7	54.1	63.7	65.3	62.5	53.7	43.6	32.2	23.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.4	32.5	39.6	56.4	63.4	71.8	73.8	73.3	63.3	52.7	40.1	33.0
			MCDB	31.5	34.2	46.8	67.4	76.8	82.9	82.7	80.3	73.6	59.6	41.7	33.2
2%		WB	25.9	29.3	36.2	50.6	60.6	69.1	70.8	68.1	59.6	49.7	36.9	30.5	
		MCDB	27.1	31.1	40.5	59.4	74.7	79.0	79.7	75.6	67.9	55.4	37.8	31.4	
5%		WB	22.2	26.4	34.1	47.1	57.7	67.0	68.7	65.7	56.9	46.7	34.1	27.0	
		MCDB	23.1	27.9	37.9	55.0	70.0	77.0	77.0	72.7	64.7	51.3	34.7	27.9	
10%		WB	17.9	22.3	31.9	43.9	55.0	64.8	66.8	63.3	54.2	43.7	32.4	23.4	
		MCDB	18.9	24.0	35.4	51.0	65.8	74.1	74.9	69.5	60.3	47.9	33.2	24.2	
Mean Daily Temperature Range	5% DB	MDBR	16.5	19.5	20.0	19.6	21.9	22.1	20.8	19.4	18.0	13.1	12.8	14.5	
		MCDBR	11.6	15.7	20.9	26.5	31.4	29.4	27.2	26.9	27.5	21.2	9.1	12.7	
		MCWBR	11.3	14.2	15.0	16.6	15.9	14.0	14.0	15.5	15.5	13.4	8.6	12.5	
	5% WB	MCDBR	12.2	13.8	17.3	24.8	28.0	25.4	24.6	23.3	24.0	19.9	8.9	12.5	
		MCWBR	11.9	12.9	13.0	16.8	15.6	13.5	14.2	14.8	14.3	13.4	8.5	12.4	
Clear-Sky Solar Irradiance	taub		0.275	0.310	0.365	0.399	0.397	0.407	0.439	0.415	0.366	0.344	0.303	0.276	
	taud		2.018	2.021	1.946	2.077	2.268	2.316	2.215	2.265	2.359	2.262	2.084	1.965	
	Ebn at Noon		170	220	238	254	265	264	251	248	244	210	157	126	
	Edh at Noon		18	29	42	43	38	37	41	36	28	23	17	14	
All-Sky Solar Radiation	RadAvg		209	526	979	1371	1581	1774	1623	1235	817	402	175	120	
	RadStd		25	43	69	140	153	173	116	132	93	36	34	19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page