

MAYSK, Russian Federation

WMO: 292090

Lat: 57.811N

Lon: 77.217E

Elev: 100

StdP: 100.13

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -39.0	(c) -35.6	(d) -41.1	(e) 0.1	(f) -38.6	(g) -37.9	(h) 0.1	(i) -35.3	(j) 6.1	(k) -7.8	(l) 5.4	(m) -9.0	(n) 0.3	(o) 320	(p) 0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	28.7	19.7	26.8	18.8	25.1	17.9	21.2	26.1	20.0	24.8	18.9	23.7	2.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.4	23.7	18.2	13.3	22.5	17.1	12.4	21.3	62.0	26.2	58.0	24.9	54.4	23.7	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.4	5.4	4.8	-42.7	31.5	4.4	1.6	-45.9	32.6	-48.4	33.5	-50.9	34.4	-54.1	35.6
			-42.3	23.1	3.8	1.7	-45.1	24.3	-47.3	25.4	-49.4	26.3	-52.2	27.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.1	-19.7	-15.7	-6.6	1.9	8.8	15.5	17.2	14.1	8.5	1.4	-8.9	-15.9		
	DBStd	14.10	8.66	7.88	6.38	5.88	5.48	4.62	3.42	3.62	4.32	5.24	8.22	9.04		
	HDD10.0	4230	922	721	513	247	92	10	1	6	80	268	567	803		
	HDD18.3	6703	1180	954	772	494	299	106	62	138	297	524	817	1062		
	CDD10.0	628	0	0	0	4	54	176	224	134	33	3	0	0		
	CDD18.3	59	0	0	0	0	3	21	27	8	1	0	0	0		
	CDH23.3	799	0	0	0	1	71	306	315	95	12	0	0	0		
	CDH26.7	169	0	0	0	0	12	75	68	13	2	0	0	0		
(14) Wind	WSAvg	1.8	1.6	2.0	2.2	2.3	2.2	1.5	1.4	1.5	1.7	1.9	2.0	1.9		
(15) Precipitation	PrecAvg	552	28	21	24	30	48	77	77	76	54	47	44	40		
	PrecMax	789	55	45	58	73	122	368	152	126	110	101	63	90		
	PrecMin	368	4	1	2	2	12	28	19	25	4	19	11	10		
	PrecStd	98	15	11	15	17	26	65	34	29	26	22	13	16		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.3	1.7	9.0	20.4	28.2	30.7	31.1	28.5	24.9	17.4	5.7	0.7		
		MCWB	-1.0	0.0	3.6	13.5	16.7	19.4	21.6	21.1	15.7	10.7	4.3	0.2		
	2%	DB	-2.8	-0.5	5.9	16.2	25.4	29.0	28.4	25.9	21.6	13.9	3.5	-0.3		
		MCWB	-3.5	-1.7	1.7	9.4	15.0	19.3	20.1	19.1	14.8	9.0	2.7	-0.8		
	5%	DB	-4.9	-2.2	3.7	13.5	22.4	26.8	26.7	23.8	18.8	11.3	1.8	-2.1		
		MCWB	-5.4	-3.2	0.8	7.8	13.6	18.4	19.5	18.0	13.2	7.6	1.1	-2.8		
	10%	DB	-7.3	-4.4	1.9	11.1	19.4	24.8	24.9	21.7	16.2	9.0	0.7	-4.3		
		MCWB	-7.8	-5.4	-0.2	6.5	12.3	17.6	18.5	16.9	12.0	6.4	0.1	-4.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.9	0.3	4.2	13.5	17.4	22.1	23.2	22.9	17.4	11.5	4.5	0.5		
		MCDB	-0.3	1.2	8.2	19.7	24.9	28.3	28.2	26.8	23.1	15.3	5.4	0.7		
	2%	WB	-3.4	-1.5	2.3	10.4	15.9	20.6	21.6	20.1	15.4	9.8	2.7	-0.8		
		MCDB	-2.7	-0.5	4.7	15.2	23.7	26.1	26.5	24.2	19.9	13.0	3.2	-0.4		
	5%	WB	-5.4	-3.1	1.2	8.4	14.3	19.5	20.4	18.7	13.9	8.2	1.2	-2.8		
		MCDB	-4.9	-2.3	3.3	12.8	21.1	25.0	25.0	22.6	18.2	10.7	1.5	-2.3		
	10%	WB	-7.8	-5.4	0.0	6.6	12.8	18.2	19.3	17.4	12.3	6.5	0.2	-4.8		
		MCDB	-7.3	-4.5	1.9	10.6	18.8	23.4	23.8	20.8	15.7	8.9	0.6	-4.3		
(35) Mean Daily Temperature Range	MDBR		9.2	10.8	11.1	10.9	12.1	12.3	11.6	10.8	10.0	7.3	7.1	8.0		
	5% DB	MCDBR	6.4	8.7	11.6	14.7	17.4	16.3	15.1	14.9	15.3	11.8	5.1	7.1		
		MCWBR	6.3	7.9	8.3	9.2	8.8	7.8	7.8	8.6	8.6	7.4	4.8	6.9		
	5% WB	MCDBR	6.8	7.6	9.6	13.8	15.5	14.1	13.6	12.9	13.3	11.1	4.9	7.0		
		MCWBR	6.6	7.2	7.2	9.3	8.7	7.5	7.9	8.2	7.9	7.5	4.7	6.9		
(40) Clear-Sky Solar Irradiance	taub		0.275	0.310	0.365	0.399	0.397	0.407	0.439	0.415	0.366	0.344	0.303	0.276		
	taud		2.018	2.021	1.946	2.077	2.268	2.316	2.215	2.265	2.359	2.262	2.084	1.965		
	Ebn at Noon		536	693	750	800	836	832	791	783	770	663	495	397		
	Edh at Noon		58	92	132	137	121	118	128	114	89	73	54	45		
(44) All-Sky Solar Radiation	RadAvg		0.66	1.66	3.09	4.32	4.98	5.59	5.12	3.89	2.58	1.27	0.55	0.38		
	RadStd		0.08	0.14	0.22	0.44	0.48	0.55	0.37	0.42	0.29	0.11	0.11	0.06		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page