

YENISEYSK, Russian Federation

WMO: 292630

Lat: 58.4540N

Lon: 92.2035E

Elev: 259

StdP: 14.56

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-42.9	-36.5	-45.9	0.4	-41.8	-40.2	0.5	-35.8	15.3	12.7	13.2	14.5	0.5	80	0.604

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	84.3	67.0	81.0	65.1	77.8	63.9	69.6	79.4	67.8	77.0	66.0	74.9	4.9	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	97.9	74.1	64.4	91.5	72.8	62.5	85.3	70.3	34.0	79.8	32.4	76.9	31.0	75.1	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.3	12.2	10.8	DB	-44.5	89.2	7.1	2.4	-49.6	91.0	-53.8	92.4	-57.8	93.7	-63.0	95.5	
			WB	-44.2	72.8	6.4	2.3	-48.8	74.4	-52.5	75.7	-56.1	77.0	-60.8	78.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	31.3	-6.2	1.9	18.1	34.1	47.5	61.2	65.4	59.6	47.0	32.8	12.3	0.4
	DBStd	27.16	18.17	15.13	12.69	9.31	9.41	7.88	5.72	6.61	7.65	9.81	15.68	17.06
	HDD50	8090	1742	1348	988	480	165	10	0	7	147	536	1130	1537
	HDD65	12443	2207	1768	1453	927	547	160	66	192	542	999	1580	2002
	CDD50	1276	0	0	0	3	87	347	477	304	56	2	0	0
	CDD65	151	0	0	0	0	4	46	77	23	1	0	0	0
	CDH74	1612	0	0	0	1	72	581	726	221	11	0	0	0
	CDH80	372	0	0	0	0	13	151	166	41	1	0	0	0
	WSAvg	4.4	3.5	3.8	4.7	5.5	5.4	4.1	3.5	3.7	4.3	5.1	5.0	4.3
	PrecAvg	18.7	1.0	0.7	0.7	1.0	1.7	2.2	2.2	2.5	2.0	1.7	1.7	1.3
Precipitation	PrecMax	25.9	2.0	1.5	1.8	1.9	3.7	6.4	7.0	6.3	4.4	3.1	3.2	2.5
	PrecMin	13.8	0.1	0.2	0.0	0.3	0.4	0.0	0.3	0.5	0.3	0.5	0.4	0.4
	PrecStd	3.0	0.4	0.3	0.4	0.4	0.8	1.3	1.3	1.2	0.9	0.6	0.5	0.5
	PrecStd	3.0	0.4	0.3	0.4	0.4	0.8	1.3	1.3	1.2	0.9	0.6	0.5	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.5	34.0	47.9	65.2	81.5	88.7	87.9	84.9	75.1	59.2	42.6	33.5
		MCWB	28.1	30.2	38.4	49.5	59.5	67.3	69.0	70.0	61.3	49.5	40.3	31.4
	2%	DB	27.2	30.8	42.3	58.6	75.0	84.3	84.5	79.7	68.4	53.9	38.0	30.0
		MCWB	25.4	28.2	34.8	45.3	56.4	65.7	68.1	65.9	57.3	46.4	35.4	28.8
	5%	DB	23.3	27.0	38.9	53.4	69.7	80.7	81.3	75.7	64.0	49.4	35.4	26.4
		MCWB	22.0	24.7	33.1	42.7	53.9	63.5	66.6	64.3	55.3	44.3	33.5	25.2
	10%	DB	19.4	23.0	35.6	48.5	64.5	76.9	78.0	72.0	59.0	45.6	32.6	22.6
		MCWB	18.4	21.3	31.3	40.1	51.5	62.7	65.1	62.5	52.9	41.8	30.9	21.4
	0.4%	WB	29.0	31.3	39.4	50.8	61.7	70.8	72.9	71.9	62.2	50.6	39.9	31.9
		MCDB	30.4	33.3	46.4	62.7	76.6	82.7	82.5	81.5	71.2	56.2	41.6	33.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	25.4	28.3	35.8	46.6	58.1	68.0	70.3	68.3	58.7	47.7	36.0	28.9
		MCDB	27.1	30.6	40.6	55.8	70.8	79.1	80.0	76.7	66.3	52.6	37.4	30.1
	5%	WB	22.1	24.8	33.6	43.6	55.6	66.1	68.5	65.9	56.1	44.8	33.6	25.3
		MCDB	23.3	26.8	38.3	52.6	67.8	77.3	77.6	73.0	61.9	49.0	35.4	26.4
	10%	WB	18.4	21.1	31.4	40.3	52.7	64.0	66.9	63.5	53.7	42.0	30.8	21.5
		MCDB	19.5	23.0	35.8	47.5	63.1	73.9	75.6	70.5	58.6	45.6	32.6	22.6
Mean Daily Temperature Range	5% DB	MDBR	14.4	18.3	20.7	17.2	19.2	20.2	19.7	17.7	15.1	11.1	11.5	12.6
		MCDBR	12.4	15.4	20.7	25.2	28.0	28.0	25.4	24.0	24.0	17.8	11.6	12.6
		MCWBR	11.5	13.5	15.0	14.8	13.2	11.9	11.1	11.9	13.6	11.6	10.3	11.9
	5% WB	MCDBR	11.9	14.8	18.0	23.4	25.2	23.4	21.4	20.2	20.2	15.9	11.3	12.0
		MCWBR	11.3	13.3	13.6	14.5	13.0	11.1	10.7	11.1	12.4	11.1	10.3	11.5
Clear-Sky Solar Irradiance	taub		0.290	0.322	0.358	0.389	0.403	0.411	0.446	0.414	0.369	0.344	0.301	0.278
	taud		1.952	1.952	1.939	2.038	2.227	2.304	2.201	2.269	2.354	2.231	1.998	1.913
	Ebn at Noon		151	208	238	255	262	262	248	247	241	206	145	112
	Edh at Noon		19	31	42	45	40	38	41	36	28	23	18	14
	RadAvg		183	473	890	1347	1572	1846	1711	1304	762	364	176	98
All-Sky Solar Radiation	RadStd		28	45	77	107	158	194	119	109	117	41	34	22

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page