

YENISEYSK, Russian Federation

WMO: 292630

Lat: 58.4540N

Lon: 92.2035E

Elev: 79

StdP: 100.38

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -41.6	(c) -38.1	(d) -43.3	(e) 0.1	(f) -41.0	(g) -40.1	(h) 0.1	(i) -37.6	(j) 6.8	(k) -10.7	(l) 5.9	(m) -9.7	(n) 0.2	(o) 80	(p) 0.604

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.9	(c) 29.1	(d) 19.5	(e) 27.2	(f) 18.4	(g) 25.4	(h) 17.7	(i) 20.9	(j) 26.4	(k) 19.9	(l) 25.0	(m) 18.9	(n) 23.8	(o) 2.2	(p) 130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 19.1	(b) 14.0	(c) 23.4	(d) 18.0	(e) 13.1	(f) 22.7	(g) 16.9	(h) 12.2	(i) 21.3	(j) 61.2	(k) 26.6	(l) 57.5	(m) 24.9	(n) 54.2	(o) 24.0	(p) 24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 6.4	(b) 5.5	(c) 4.8	(e) -42.5	(f) 31.8	(g) 4.0	(h) 1.3	(i) -45.3	(j) 32.8	(k) -47.7	(l) 33.5	(m) -49.9	(n) 34.3	(o) -52.8	(p) 35.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.4	-21.2	-16.7	-7.7	1.2	8.6	16.2	18.5	15.3	8.3	0.4	-10.9	-17.5		
	DBStd	15.09	10.10	8.41	7.05	5.17	5.23	4.38	3.18	3.67	4.25	5.45	8.71	9.48		
	HDD10.0	4494	968	749	549	267	92	6	0	4	82	298	628	854		
	HDD18.3	6913	1226	982	807	515	304	89	37	107	301	555	878	1112		
	CDD10.0	709	0	0	0	2	48	193	265	169	31	1	0	0		
	CDD18.3	84	0	0	0	0	2	26	43	13	1	0	0	0		
	CDH23.3	896	0	0	0	1	40	323	403	123	6	0	0	0		
	CDH26.7	207	0	0	0	0	7	84	92	23	1	0	0	0		
(14) Wind	WSAvg	2.0	1.6	1.7	2.1	2.5	2.4	1.8	1.5	1.6	1.9	2.3	2.2	1.9		
(15) Precipitation	PrecAvg	476	26	19	18	26	42	55	57	64	51	43	42	34		
	PrecMax	659	50	37	45	48	95	162	178	160	112	78	81	64		
	PrecMin	350	2	6	1	8	9	0	8	13	7	12	10	10		
	PrecStd	75	9	8	9	11	20	33	33	31	22	15	13	12		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.9	1.1	8.8	18.5	27.5	31.5	31.1	29.4	24.0	15.1	5.9	0.8		
		MCWB	-2.2	-1.0	3.6	9.7	15.3	19.6	20.6	21.1	16.3	9.7	4.6	-0.3		
	2%	DB	-2.7	-0.6	5.7	14.8	23.9	29.0	29.1	26.5	20.2	12.1	3.3	-1.1		
		MCWB	-3.7	-2.1	1.6	7.4	13.6	18.7	20.1	18.8	14.0	8.0	1.9	-1.8		
	5%	DB	-4.9	-2.8	3.8	11.9	21.0	27.0	27.4	24.3	17.8	9.6	1.9	-3.1		
		MCWB	-5.6	-4.1	0.6	6.0	12.2	17.5	19.2	18.0	12.9	6.9	0.8	-3.8		
	10%	DB	-7.0	-5.0	2.0	9.2	18.1	24.9	25.6	22.2	15.0	7.6	0.3	-5.2		
		MCWB	-7.6	-6.0	-0.4	4.5	10.8	17.1	18.4	16.9	11.6	5.5	-0.6	-5.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.6	-0.4	4.1	10.5	16.5	21.6	22.7	22.1	16.8	10.3	4.4	-0.1		
		MCDB	-0.9	0.7	8.0	17.1	24.8	28.2	28.1	27.5	21.8	13.4	5.4	0.7		
	2%	WB	-3.7	-2.1	2.1	8.1	14.5	20.0	21.3	20.2	14.8	8.7	2.2	-1.7		
		MCDB	-2.7	-0.8	4.8	13.2	21.5	26.2	26.7	24.8	19.1	11.4	3.0	-1.1		
	5%	WB	-5.5	-4.0	0.9	6.4	13.1	19.0	20.3	18.8	13.4	7.1	0.9	-3.7		
		MCDB	-4.8	-2.9	3.5	11.5	19.9	25.2	25.3	22.8	16.6	9.4	1.9	-3.1		
	10%	WB	-7.5	-6.0	-0.3	4.6	11.5	17.8	19.4	17.5	12.0	5.6	-0.6	-5.8		
		MCDB	-6.9	-5.0	2.1	8.6	17.3	23.3	24.2	21.4	14.8	7.6	0.3	-5.2		
(35) Mean Daily Temperature Range	MDBR		8.0	10.2	11.5	9.6	10.7	11.2	10.9	9.8	8.4	6.2	6.4	7.0		
	5% DB	MCDBR	6.9	8.5	11.5	14.0	15.6	15.5	14.1	13.3	13.3	9.9	6.4	7.0		
		MCWBR	6.4	7.5	8.3	8.2	7.4	6.6	6.2	6.6	7.5	6.5	5.7	6.6		
	5% WB	MCDBR	6.6	8.2	10.0	13.0	14.0	13.0	11.9	11.2	11.2	8.8	6.3	6.7		
		MCWBR	6.3	7.4	7.5	8.1	7.2	6.2	5.9	6.1	6.9	6.2	5.7	6.4		
(40) Clear-Sky Solar Irradiance	taub		0.290	0.322	0.358	0.389	0.403	0.411	0.446	0.414	0.369	0.344	0.301	0.278		
	taud		1.952	1.952	1.939	2.038	2.227	2.304	2.201	2.269	2.354	2.231	1.998	1.913		
	Ebn at Noon		477	655	751	805	827	826	781	780	761	648	457	353		
	Edh at Noon		60	97	131	141	126	119	129	112	88	74	56	44		
(44) All-Sky Solar Radiation	RadAvg		0.58	1.49	2.81	4.25	4.96	5.82	5.39	4.11	2.40	1.15	0.55	0.31		
	RadStd		0.09	0.14	0.24	0.34	0.50	0.61	0.38	0.34	0.37	0.13	0.11	0.07		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page