

PERVOMAYSKOYE, Russian Federation

WMO: 293480

Lat: 57.0753N

Lon: 86.2374E

Elev: 114

StdP: 99.96

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-37.3	-34.0	-40.1	0.1	-37.1	-36.8	0.1	-34.0	7.2	-10.1	6.3	-10.0	0.7	230	0.572

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	29.2	19.8	27.6	19.1	25.9	18.2	21.3	26.6	20.3	25.5	19.2	24.3	1.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.5	24.0	18.4	13.4	22.9	17.3	12.5	22.0	62.8	26.8	59.0	25.6	55.5	24.3	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	5.2	4.5	DB	-39.7	32.0	3.8	1.5	-42.4	33.0	-44.6	33.9	-46.7	34.8	-49.4	35.9	(4)
(5)			WB	-39.9	22.8	3.6	1.3	-42.5	23.7	-44.7	24.5	-46.7	25.2	-49.4	26.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.1	-18.5	-14.6	-6.0	2.4	10.0	17.0	19.0	15.8	9.3	1.8	-8.6	-15.4	(6)	
	DBStd	14.33	8.93	7.69	6.41	5.45	5.56	4.48	3.25	3.73	4.52	5.29	8.07	8.83	(7)	
	HDD10.0	4053	884	688	496	234	71	5	0	3	68	259	558	787	(8)	
	HDD18.3	6403	1143	922	754	478	262	76	31	96	273	514	808	1046	(9)	
	CDD10.0	804	0	0	0	5	72	214	280	183	46	3	0	0	(10)	
	CDD18.3	112	0	0	0	0	6	36	53	17	1	0	0	0	(11)	
	CDH23.3	1067	0	0	0	1	83	352	457	161	14	0	0	0	(12)	
	CDH26.7	246	0	0	0	0	20	87	107	31	2	0	0	0	(13)	
	WSAvg	1.9	2.0	2.1	2.3	2.3	2.1	1.5	1.3	1.3	1.6	2.2	2.3	2.3	(14)	
(15) Precipitation	PrecAvg	473	22	17	19	25	41	58	67	61	50	40	41	33	(15)	
	PrecMax	647	46	36	56	48	93	122	127	130	104	77	59	63	(16)	
	PrecMin	342	5	3	2	8	11	4	8	16	14	13	19	10	(17)	
	PrecStd	76	11	9	12	10	23	28	31	23	24	15	12	12	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.0	1.3	9.4	20.2	29.4	31.4	31.8	29.8	25.3	17.1	7.1	1.1	(19)	
		MCWB	-1.1	-0.3	4.6	12.1	18.1	19.3	20.8	21.0	17.2	10.0	5.4	0.0	(20)	
	2%	DB	-2.1	-0.2	6.4	16.8	25.6	29.0	29.3	27.1	21.9	13.9	4.4	-0.4	(21)	
		MCWB	-2.9	-1.5	2.2	9.8	15.7	18.7	20.8	19.1	15.1	9.0	2.9	-1.2	(22)	
	5%	DB	-3.7	-2.0	4.2	13.8	22.9	27.2	27.6	25.1	19.2	11.5	2.6	-2.1	(23)	
		MCWB	-4.6	-3.2	0.9	8.0	14.2	18.1	19.9	18.1	13.7	8.0	1.3	-2.9	(24)	
	10%	DB	-5.9	-4.0	2.5	10.9	19.9	25.2	25.9	22.9	16.6	9.0	1.0	-4.2	(25)	
		MCWB	-6.6	-5.1	0.1	6.3	12.7	17.5	19.0	17.2	12.2	6.6	0.1	-4.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.9	0.2	5.0	12.5	19.2	21.4	23.6	22.2	17.6	11.6	5.6	0.3	(27)	
		MCDB	-0.1	0.9	8.9	19.1	28.5	27.7	28.1	27.5	23.6	14.8	6.9	0.8	(28)	
	2%	WB	-2.9	-1.4	2.7	10.3	16.7	20.1	22.0	20.4	15.7	9.7	3.1	-1.2	(29)	
		MCDB	-2.1	-0.3	5.5	15.8	23.9	26.2	27.2	25.4	20.9	13.0	4.3	-0.7	(30)	
	5%	WB	-4.6	-3.2	1.4	8.3	14.9	19.1	20.9	19.0	14.1	8.3	1.5	-2.9	(31)	
		MCDB	-3.8	-2.1	3.7	13.2	21.3	25.3	25.8	23.4	18.0	11.3	2.4	-2.1	(32)	
	10%	WB	-6.6	-5.0	0.2	6.3	13.2	18.2	19.9	17.8	12.8	6.6	0.2	-4.8	(33)	
		MCDB	-5.9	-4.0	2.3	10.5	18.9	23.8	24.6	21.9	16.1	8.9	1.0	-4.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	8.6	9.7	9.5	10.6	10.3	10.2	9.8	9.0	6.5	6.1	6.8	(35)	
		MCDBR	6.6	7.0	10.2	13.6	14.9	13.9	12.8	13.3	13.5	10.8	6.2	7.4	(36)	
	5% WB	MCWBR	6.4	6.3	7.2	8.3	7.5	5.7	5.4	6.2	7.1	6.7	5.6	7.2	(37)	
		MCWBR	6.8	6.4	9.0	12.9	13.7	11.8	11.2	11.3	11.9	9.8	6.1	7.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.289	0.322	0.370	0.396	0.406	0.405	0.439	0.406	0.370	0.347	0.314	0.289	(40)	
		taud	1.989	1.970	1.913	2.060	2.215	2.309	2.202	2.283	2.331	2.239	2.030	1.940	(41)	
	Ebn at Noon		532	682	749	807	828	836	793	796	770	667	491	403	(42)	
		Edh at Noon	64	100	139	141	129	119	130	112	92	77	61	51	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.71	1.69	3.05	4.38	4.90	5.77	5.29	4.17	2.66	1.32	0.63	0.41	(44)	
	RadStd		0.09	0.14	0.23	0.32	0.49	0.58	0.37	0.31	0.37	0.12	0.10	0.07	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (6 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page