

TASEYEVO, Russian Federation

WMO: 293790

Lat: 57.1784N

Lon: 94.8973E

Elev: 540

StdP: 14.41

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-46.2	-41.2	-49.6	0.3	-44.7	-45.4	0.4	-40.5	21.3	15.3	18.6	16.0	0.1	280	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.3	85.7	65.8	82.4	64.4	79.3	63.4	68.6	79.9	67.2	77.8	65.6	75.5	5.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.4	95.6	72.0	63.5	89.5	70.7	61.8	84.1	69.7	33.3	79.9	32.1	78.3	30.8	76.1	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	15.8	13.6	DB	-48.6	91.6	6.0	2.8	-52.9	93.6	-56.4	95.2	-59.8	96.8	-64.2	98.8	(4)
(5)			WB	-46.9	71.6	3.7	0.7	-49.6	72.1	-51.7	72.5	-53.8	72.9	-56.5	73.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	30.6	-8.9	-1.1	18.3	36.2	45.9	61.8	64.7	60.3	46.4	32.2	10.7	-1.7		
	DBStd	28.23	18.75	15.87	12.83	8.66	8.64	7.54	5.24	6.19	7.59	10.75	16.32	19.92		
	HDD50	8354	1827	1430	984	420	189	8	0	3	156	554	1180	1603		
	HDD65	12712	2292	1850	1449	865	594	145	70	172	559	1018	1630	2068		
	CDD50	1258	0	0	0	5	62	363	455	322	49	2	0	0		
	CDD65	138	0	0	0	0	2	49	60	26	1	0	0	0		
	CDH74	2126	0	0	0	4	61	938	745	355	23	0	0	0		
	CDH80	555	0	0	0	0	8	287	162	95	3	0	0	0		
	WSAvg	5.1	4.3	4.6	5.9	6.4	7.1	4.8	4.4	4.3	4.8	5.3	5.3	4.4		
	PrecAvg	15.4	0.6	0.6	0.6	0.7	1.3	1.8	2.3	2.0	2.0	1.3	1.3	1.0		
	PrecMax	20.0	1.3	1.0	1.1	1.3	2.9	3.9	5.9	4.1	5.4	2.0	2.0	2.0		
(15) Precipitation	PrecMin	11.7	0.2	0.2	0.1	0.2	0.4	0.4	0.2	0.9	0.7	0.6	0.8	0.3		
	PrecStd	2.1	0.3	0.2	0.3	0.4	0.7	0.9	1.1	0.8	0.8	0.4	0.3	0.4		
	DB	32.6	33.5	48.0	69.5	80.2	90.5	87.9	87.8	77.0	62.0	45.3	34.2			
	MCWB	29.0	28.8	38.0	51.5	57.5	66.4	67.3	66.9	59.9	50.0	40.4	31.2			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	27.8	30.2	43.0	61.0	74.8	86.7	84.3	82.5	70.6	55.4	39.6	30.2			
	2% MCWB	25.6	27.6	35.7	45.9	55.5	65.2	66.2	65.7	56.9	47.5	36.2	28.5			
	5% DB	23.5	27.2	39.6	56.5	69.5	83.2	81.4	77.7	65.7	50.9	35.6	27.5			
	5% MCWB	21.6	24.6	33.8	44.1	52.5	63.8	65.4	64.2	55.2	44.8	33.4	26.2			
	10% DB	20.0	22.5	36.4	51.8	64.3	80.0	78.3	73.6	60.0	46.2	33.0	23.8			
	10% MCWB	18.6	20.3	31.8	42.0	50.7	62.5	64.0	62.1	52.0	42.0	31.2	22.3			
	0.4% WB	29.6	30.2	38.8	52.8	60.0	69.7	70.5	69.3	62.7	51.9	41.6	31.8			
	0.4% MCDB	31.2	32.3	45.2	67.8	73.3	83.5	79.8	80.4	73.4	59.0	45.4	33.5			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	25.3	28.0	36.4	48.3	57.2	68.3	69.0	67.3	58.9	48.3	36.6	28.9			
	2% MCDB	27.2	30.3	41.9	57.9	70.2	81.0	79.1	78.9	67.9	54.0	39.3	30.2			
	5% WB	21.7	24.5	34.2	44.8	54.3	66.3	67.6	65.6	55.9	45.3	33.7	26.1			
	5% MCDB	23.3	27.1	39.1	54.5	66.8	78.4	77.2	75.0	63.3	50.5	35.6	27.4			
	10% WB	18.4	20.2	32.0	42.1	51.4	64.4	66.1	63.7	53.2	42.0	31.0	22.4			
	10% MCDB	20.1	22.6	36.1	51.2	62.7	76.5	75.2	71.5	59.6	46.0	33.0	23.9			
	MDBR	17.5	21.7	22.9	20.1	22.2	24.8	21.3	20.6	19.5	14.8	15.2	16.0			
	5% DB	14.1	19.4	24.0	28.9	32.0	32.9	28.3	28.7	31.3	23.4	10.7	15.7			
(36) Mean Daily Temperature Range	MCWBR	12.6	17.0	17.7	16.5	15.9	13.5	12.2	12.7	17.6	14.9	9.0	14.7			
	MCDBR	13.9	18.9	21.1	25.6	28.7	26.6	23.3	23.6	26.5	23.3	10.5	15.2			
	MCWBR	12.5	16.6	16.2	15.6	15.5	11.7	11.3	11.9	15.8	15.4	9.1	14.4			
	MCWBR	12.5	16.6	16.2	15.6	15.5	11.7	11.3	11.9	15.8	15.4	9.1	14.4			
(40) Clear-Sky Solar Irradiance	taub	0.284	0.315	0.354	0.386	0.406	0.429	0.445	0.411	0.366	0.344	0.308	0.276			
	taud	1.991	1.990	1.970	2.121	2.217	2.233	2.209	2.277	2.363	2.254	2.046	1.950			
	Ebn at Noon	170	220	245	260	263	258	250	251	246	213	159	133			
	Edh at Noon	20	31	41	42	41	41	41	36	28	24	19	16			
(44) All-Sky Solar Radiation	RadAvg	221	531	960	1392	1596	1894	1736	1389	836	419	209	129			
	RadStd	28	38	59	81	143	171	108	107	114	34	35	21			

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page