

TASEYEVO, Russian Federation

WMO: 293790

Lat: 57.1784N

Lon: 94.8973E

Elev: 165

StdP: 99.36

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-43.5	-40.6	-45.4	0.0	-42.6	-43.0	0.1	-40.3	9.5	-9.3	8.3	-8.9	0.1	280	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	29.9	18.8	28.0	18.0	26.3	17.4	20.4	26.6	19.6	25.5	18.7	24.2	2.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.5	13.7	22.2	17.5	12.8	21.5	16.6	12.0	21.0	59.5	26.6	56.8	25.7	53.8	24.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.1	6.1	DB	-44.8	33.1	3.3	1.5	-47.2	34.2	-49.1	35.1	-51.0	36.0	-53.4	37.1	(4)
(5)			WB	-43.8	22.0	2.1	0.4	-45.3	22.3	-46.5	22.5	-47.7	22.7	-49.2	23.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.8	-22.7	-18.4	-7.6	2.3	7.7	16.6	18.2	15.7	8.0	0.1	-11.8	-18.7	(6)	
	DBStd	15.68	10.42	8.81	7.13	4.81	4.80	4.19	2.91	3.44	4.22	5.97	9.06	11.07	(7)	
	HDD10.0	4641	1015	794	547	233	105	4	0	2	87	308	656	891	(8)	
	HDD18.3	7062	1273	1028	805	481	330	81	39	96	311	566	906	1149	(9)	
	CDD10.0	699	0	0	0	3	34	202	253	179	27	1	0	0	(10)	
	CDD18.3	77	0	0	0	0	1	27	33	14	1	0	0	0	(11)	
	CDH23.3	1181	0	0	0	2	34	521	414	197	13	0	0	0	(12)	
	CDH26.7	308	0	0	0	0	4	159	90	53	2	0	0	0	(13)	
(14) Wind	WSAvg	2.3	1.9	2.1	2.7	2.9	3.2	2.2	2.0	1.9	2.1	2.3	2.4	2.0	(14)	
(15) Precipitation	PrecAvg	390	16	14	14	18	32	45	58	50	50	34	33	25	(15)	
	PrecMax	508	34	25	28	33	73	98	151	105	136	52	50	51	(16)	
	PrecMin	297	4	5	2	4	9	10	6	24	18	16	20	8	(17)	
	PrecStd	53	7	5	7	9	18	24	27	20	21	9	8	9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.3	0.9	8.9	20.8	26.8	32.5	31.1	31.0	25.0	16.7	7.4	1.2	(19)	
		MCWB	-1.6	-1.8	3.3	10.8	14.2	19.1	19.6	19.4	15.5	10.0	4.7	-0.4	(20)	
	2%	DB	-2.3	-1.0	6.1	16.1	23.8	30.4	29.1	28.1	21.5	13.0	4.2	-1.0	(21)	
		MCWB	-3.6	-2.4	2.1	7.7	13.1	18.5	19.0	18.7	13.8	8.6	2.3	-2.0	(22)	
	5%	DB	-4.7	-2.7	4.2	13.6	20.8	28.4	27.4	25.4	18.7	10.5	2.0	-2.5	(23)	
		MCWB	-5.8	-4.1	1.0	6.7	11.4	17.7	18.6	17.9	12.9	7.1	0.8	-3.2	(24)	
	10%	DB	-6.6	-5.3	2.4	11.0	17.9	26.7	25.7	23.1	15.6	7.9	0.5	-4.5	(25)	
		MCWB	-7.4	-6.5	-0.1	5.5	10.4	16.9	17.8	16.7	11.1	5.6	-0.4	-5.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.3	-1.0	3.8	11.6	15.5	21.0	21.4	20.7	17.0	11.1	5.4	-0.1	(27)	
		MCDB	-0.5	0.2	7.3	19.9	23.0	28.6	26.6	26.9	23.0	15.0	7.5	0.8	(28)	
	2%	WB	-3.7	-2.2	2.5	9.1	14.0	20.2	20.6	19.6	15.0	9.1	2.6	-1.7	(29)	
		MCDB	-2.6	-1.0	5.5	14.4	21.2	27.2	26.2	26.0	20.0	12.2	4.1	-1.0	(30)	
	5%	WB	-5.7	-4.2	1.2	7.1	12.4	19.1	19.8	18.7	13.3	7.4	1.0	-3.3	(31)	
		MCDB	-4.8	-2.7	3.9	12.5	19.4	25.8	25.1	23.9	17.4	10.3	2.0	-2.5	(32)	
	10%	WB	-7.6	-6.6	0.0	5.6	10.8	18.0	18.9	17.6	11.8	5.5	-0.6	-5.3	(33)	
		MCDB	-6.6	-5.2	2.3	10.7	17.1	24.7	24.0	22.0	15.3	7.8	0.6	-4.5	(34)	
(35) Mean Daily Temperature Range	MDBR		9.7	12.1	12.7	11.1	12.3	13.8	11.9	11.4	10.9	8.2	8.4	8.9	(35)	
	5% DB	MCDBR	7.8	10.8	13.3	16.0	17.8	18.3	15.7	15.9	17.4	13.0	6.0	8.7	(36)	
		MCWBR	7.0	9.4	9.9	9.2	8.8	7.5	6.8	7.0	9.8	8.3	5.0	8.2	(37)	
	5% WB	MCDBR	7.7	10.5	11.7	14.2	16.0	14.8	13.0	13.1	14.7	12.9	5.8	8.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.284	0.315	0.354	0.386	0.406	0.429	0.445	0.411	0.366	0.344	0.308	0.276	(40)	
	taud		1.991	1.990	1.970	2.121	2.217	2.233	2.209	2.277	2.363	2.254	2.046	1.950	(41)	
	Ebn at Noon		537	693	771	819	828	812	788	790	776	671	501	420	(42)	
	Edh at Noon		63	97	130	132	128	129	129	113	89	76	59	49	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.70	1.67	3.03	4.39	5.03	5.97	5.47	4.38	2.63	1.32	0.66	0.41	(44)	
	RadStd		0.09	0.12	0.18	0.25	0.45	0.54	0.34	0.34	0.36	0.11	0.11	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page