

DZERZHINSKOYE, Russian Federation

WMO: 294810

Lat: **56.828N**Lon: **95.232E**Elev: **617**StdP: **14.37**Time Zone: **7.00 (E07)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-44.0	-37.2	-46.8	0.4	-42.6	-41.0	0.5	-36.4	19.3	15.1	15.2	17.0	0.3	150	0.599

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	85.8	67.1	82.3	65.5	79.0	63.9	69.7	80.2	67.8	78.2	66.1	76.2	5.1	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	99.5	74.2	64.3	92.2	72.7	62.2	85.7	70.5	34.3	80.2	32.7	78.0	31.3	76.0	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.4	12.3	10.7	DB	-45.6	91.6	7.7	3.3	-51.1	94.0	-55.6	95.9	-59.9	97.8	-65.5	100.2	(4)
(5)			WB	-43.9	72.6	7.0	2.7	-48.9	74.6	-53.0	76.2	-56.9	77.7	-62.0	79.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	32.0	-5.2	1.7	19.4	35.2	48.3	62.2	66.1	60.5	47.1	33.0	13.3	0.1
	DBStd	27.33	18.30	15.62	12.23	8.86	9.42	7.39	5.55	6.66	7.74	10.09	15.76	17.68
	HDD50	7947	1710	1354	950	449	150	5	0	6	146	528	1101	1548
	HDD65	12236	2175	1774	1415	894	524	137	54	170	538	991	1551	2013
	CDD50	1364	0	0	0	5	97	371	499	331	59	2	0	0
	CDD65	177	0	0	0	0	6	52	88	30	1	0	0	0
	CDH74	2102	0	0	0	3	104	766	858	344	27	0	0	0
	CDH80	564	0	0	0	0	19	229	224	88	4	0	0	0
Wind	WSAvg	4.3	3.5	3.8	4.7	5.6	5.6	4.2	3.7	3.5	4.0	4.5	4.4	3.8
Precipitation	PrecAvg	14.8	0.6	0.5	0.5	0.7	1.4	2.0	2.3	2.0	1.8	1.1	1.1	0.8
	PrecMax	18.9	1.3	1.1	1.1	1.3	3.2	4.2	6.4	4.8	5.4	2.0	2.0	1.8
	PrecMin	11.5	0.2	0.1	0.0	0.1	0.4	0.5	0.4	0.7	0.6	0.4	0.6	0.2
	PrecStd	2.0	0.3	0.2	0.3	0.4	0.7	0.9	1.1	0.9	0.9	0.4	0.4	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.5	36.0	47.5	67.7	82.6	89.9	89.6	87.2	77.5	60.7	46.2	35.1
		MCWB	29.7	30.1	38.2	50.5	61.0	67.0	68.8	67.4	61.6	49.8	41.4	31.3
	2%	DB	28.8	32.2	42.9	60.4	77.0	85.8	85.5	82.1	70.5	55.0	40.6	30.5
		MCWB	26.2	28.4	35.9	47.0	57.9	66.0	68.0	65.9	58.2	47.4	36.5	27.9
	5%	DB	24.8	28.6	39.5	54.9	71.6	82.0	82.1	77.6	65.2	50.8	36.9	27.1
		MCWB	22.5	25.3	33.6	44.4	55.1	64.6	66.6	64.2	55.6	44.9	33.5	24.9
	10%	DB	20.3	24.4	36.3	50.0	66.6	78.3	78.9	73.9	60.1	46.8	33.6	23.4
		MCWB	18.5	21.8	31.7	41.9	53.1	62.7	65.2	62.2	53.0	42.1	31.1	21.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.5	31.3	39.4	52.7	63.8	70.7	72.7	70.7	63.6	51.6	41.8	31.7
		MCDB	32.9	34.9	45.5	65.7	78.0	82.6	83.4	82.2	73.5	57.4	45.2	35.1
	2%	WB	26.4	28.7	36.4	48.4	59.7	68.3	70.4	67.7	59.4	48.3	36.7	28.2
		MCDB	28.9	32.2	41.7	57.6	73.0	80.5	79.8	78.4	68.1	53.9	39.7	30.2
	5%	WB	22.8	25.5	34.1	45.2	56.7	66.4	68.7	65.6	56.6	45.5	33.8	25.0
		MCDB	24.8	28.6	38.9	54.0	69.7	78.5	78.1	75.3	63.1	50.5	36.5	27.1
	10%	WB	18.6	21.7	31.9	42.0	53.7	64.3	67.0	63.3	54.1	42.3	31.1	21.3
		MCDB	20.3	24.4	36.1	50.1	64.8	75.6	76.2	71.8	59.7	46.6	33.7	23.3
Mean Daily Temperature Range	5% DB	MDBR	16.2	20.0	20.8	18.2	21.4	21.7	19.5	19.4	17.7	14.1	14.3	14.9
		MCDBR	13.6	17.4	21.4	27.7	29.6	30.1	25.9	26.3	28.5	21.6	13.1	16.0
		MCWBR	12.0	14.6	15.8	16.5	14.8	12.6	10.8	12.2	15.9	14.5	10.4	14.3
	5% WB	MCDBR	13.3	16.9	19.6	25.7	26.0	24.7	20.6	23.8	24.2	20.6	12.4	15.9
		MCWBR	12.0	14.4	15.1	16.2	14.2	11.6	10.2	12.1	14.2	14.2	10.1	14.4
Clear-Sky Solar Irradiance	taub	0.282	0.314	0.354	0.386	0.408	0.424	0.440	0.411	0.365	0.344	0.308	0.276	
	taud	1.998	1.994	1.973	2.139	2.206	2.245	2.222	2.273	2.360	2.255	2.061	1.959	
	Ebn at Noon	175	222	246	260	263	259	252	251	247	215	163	138	
	Edh at Noon	20	31	42	41	41	40	41	36	29	24	19	16	
All-Sky Solar Radiation	RadAvg	233	547	985	1392	1603	1891	1742	1396	856	443	220	137	
	RadStd	27	35	58	82	148	164	111	110	110	36	34	20	