

UZHUR, Russian Federation

WMO: 296530

Lat: 55.300N

Lon: 89.817E

Elev: 1271

StdP: 14.03

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.9	-30.9	-41.0	0.5	-36.9	-34.9	0.8	-30.5	16.4	16.5	14.2	16.4	2.9	180	0.623

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	82.1	65.4	79.0	64.2	76.2	62.7	68.2	77.8	66.3	75.7	64.6	73.2	6.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	96.1	72.3	62.8	89.7	71.0	61.1	84.2	69.3	33.4	77.8	31.8	75.8	30.4	73.3	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.4	13.3	11.5	DB	-37.6	87.7	7.7	3.5	-43.2	90.3	-47.7	92.3	-52.0	94.3	-57.6	96.8	(4)
(5)			WB	-38.1	71.4	7.9	2.4	-43.8	73.2	-48.4	74.6	-52.9	75.9	-58.6	77.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	32.3	-2.6	2.4	17.7	35.8	48.2	60.5	63.2	58.7	47.1	33.9	16.7	4.6		
	DBStd	25.48	16.49	15.23	13.34	9.78	9.29	6.83	5.06	6.01	7.61	9.41	13.96	14.99		
	HDD50	7615	1632	1332	1002	433	150	8	0	5	144	503	999	1407		
	HDD65	12004	2097	1752	1467	877	523	161	94	209	538	965	1449	1872		
	CDD50	1168	0	0	0	6	94	324	410	275	56	3	0	0		
	CDD65	83	0	0	0	0	3	27	39	13	1	0	0	0		
	CDH74	1100	0	0	0	1	87	384	387	209	32	0	0	0		
	CDH80	194	0	0	0	0	21	76	57	35	5	0	0	0		
	WSAvg	5.0	5.0	4.8	5.3	6.0	6.3	4.8	4.1	4.2	4.6	5.3	5.0	5.2		
	PrecAvg	16.1	0.4	0.4	0.5	0.9	1.5	2.5	3.0	2.8	1.7	1.1	0.8	0.6		
(15) Precipitation	PrecMax	21.7	0.9	0.9	1.4	2.4	2.9	5.1	5.5	6.1	3.6	2.4	1.5	1.4		
	PrecMin	9.9	0.0	0.1	0.1	0.0	0.4	1.3	1.0	0.6	0.4	0.5	0.3	0.2		
	PrecStd	2.5	0.2	0.2	0.3	0.6	0.7	0.9	1.2	1.3	0.8	0.4	0.4	0.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.4	35.1	48.8	68.9	83.1	86.6	84.9	84.4	78.4	62.9	49.1	36.1		
		MCWB	30.2	30.2	39.4	50.8	61.7	65.6	67.2	68.1	58.9	49.9	42.1	32.0		
	2%	DB	29.2	31.8	42.1	62.3	75.7	81.8	81.4	79.6	70.5	56.0	42.6	30.7		
		MCWB	25.9	27.8	35.7	48.3	56.8	63.9	66.8	65.6	57.1	46.7	37.9	27.3		
	5%	DB	25.1	28.6	38.6	57.2	71.4	78.3	78.3	75.8	65.3	51.5	38.3	28.0		
		MCWB	22.4	25.4	33.3	45.8	55.3	62.8	65.5	63.3	54.5	44.6	33.9	25.1		
	10%	DB	20.7	24.6	35.4	51.9	66.6	75.0	75.5	71.9	60.9	47.5	34.6	24.7		
		MCWB	18.4	21.7	31.1	42.7	53.0	61.4	64.1	61.7	52.5	41.8	31.3	22.1		
	0.4%	WB	30.5	31.2	40.6	52.8	63.8	68.7	71.6	70.4	61.5	51.4	42.6	31.2		
		MCDB	34.2	34.4	47.8	65.5	78.9	80.4	81.1	80.7	74.2	60.0	48.2	35.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.3	28.0	36.4	49.4	59.1	66.4	68.7	67.1	58.4	47.8	38.0	27.7		
		MCDB	29.1	31.4	41.4	59.8	71.4	77.2	77.4	77.1	67.7	54.5	42.6	30.2		
	5%	WB	22.4	25.4	33.6	46.4	56.6	64.5	67.1	64.7	55.8	44.9	34.3	25.2		
		MCDB	25.1	28.6	38.1	56.9	68.3	75.1	75.6	73.1	63.7	51.2	37.6	28.0		
	10%	WB	18.5	21.7	31.3	43.0	54.1	62.8	65.4	62.6	53.1	42.2	31.5	22.1		
		MCDB	20.6	24.5	35.2	51.4	64.9	72.3	73.4	70.6	60.1	47.2	34.5	24.7		
	5% DB	MDBR	14.9	17.8	19.4	19.1	20.9	20.8	18.9	19.6	18.6	14.8	13.5	14.2		
		MCDBR	15.3	16.8	19.0	29.4	31.2	28.4	24.7	27.8	28.8	22.5	14.1	14.1		
		MCWBR	13.1	14.3	13.9	16.5	16.3	13.4	12.1	14.1	16.0	14.2	10.4	12.3		
		MCWBR	14.8	16.7	18.8	27.5	26.9	23.2	21.1	23.7	25.6	21.4	13.3	14.0		
(38) Clear-Sky Solar Irradiance	taub		0.269	0.304	0.352	0.393	0.402	0.400	0.423	0.406	0.366	0.342	0.303	0.270		
	taud		2.057	2.032	1.968	2.117	2.204	2.306	2.242	2.260	2.319	2.244	2.071	1.991		
	Ebn at Noon		199	235	251	261	266	268	258	255	250	222	180	162		
	Edh at Noon		21	31	43	43	42	38	40	37	30	26	21	18		
(44) All-Sky Solar Radiation	RadAvg		271	585	1036	1418	1584	1848	1645	1351	905	482	242	170		
	RadStd		29	49	83	83	182	169	107	123	104	48	32	21		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page