

UZHUR, Russian Federation

WMO: 296530

Lat: 55.300N

Lon: 89.817E

Elev: 387

StdP: 96.76

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.3	-34.9	-40.5	0.1	-38.3	-37.1	0.1	-34.7	7.3	-8.6	6.4	-8.7	1.3	180	0.623

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	27.9	18.6	26.1	17.9	24.5	17.0	20.1	25.5	19.1	24.3	18.1	22.9	2.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.7	22.4	17.1	12.8	21.7	16.1	12.0	20.7	59.7	25.4	56.2	24.3	52.9	22.9	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.9	5.9	5.2	DB	-38.7	31.0	4.3	1.9	-41.8	32.4	-44.3	33.5	-46.7	34.6	-49.8	36.0	(4)
(5)			WB	-38.9	21.9	4.4	1.3	-42.1	22.9	-44.7	23.7	-47.1	24.4	-50.3	25.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.2	-19.2	-16.4	-8.0	2.1	9.0	15.8	17.3	14.8	8.4	1.0	-8.5	-15.2	(6)	
	DBStd	14.16	9.16	8.46	7.41	5.44	5.16	3.79	2.81	3.34	4.23	5.23	7.76	8.33	(7)	
	HDD10.0	4231	907	740	557	241	83	4	0	3	80	279	555	782	(8)	
	HDD18.3	6669	1165	973	815	487	291	89	52	116	299	536	805	1040	(9)	
	CDD10.0	649	0	0	0	3	52	180	228	153	31	2	0	0	(10)	
	CDD18.3	46	0	0	0	0	2	15	22	7	1	0	0	0	(11)	
	CDH23.3	611	0	0	0	1	48	213	215	116	18	0	0	0	(12)	
	CDH26.7	108	0	0	0	0	12	42	32	19	3	0	0	0	(13)	
(14) Wind	WSAvg	2.3	2.2	2.2	2.4	2.7	2.8	2.2	1.8	1.9	2.1	2.4	2.2	2.3	(14)	
(15) Precipitation	PrecAvg	408	9	9	12	23	37	64	75	71	42	27	21	16	(15)	
	PrecMax	551	22	22	36	60	74	130	140	154	91	62	39	35	(16)	
	PrecMin	251	1	2	3	1	9	34	26	15	10	12	8	4	(17)	
	PrecStd	64	5	6	8	14	18	23	31	34	20	11	10	8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.4	1.7	9.3	20.5	28.4	30.3	29.4	29.1	25.8	17.1	9.5	2.3	(19)	
		MCWB	-1.0	-1.0	4.1	10.4	16.5	18.7	19.6	20.1	15.0	10.0	5.6	0.0	(20)	
	2%	DB	-1.5	-0.1	5.6	16.8	24.3	27.7	27.4	26.4	21.4	13.3	5.9	-0.7	(21)	
		MCWB	-3.4	-2.3	2.1	9.1	13.8	17.7	19.4	18.6	13.9	8.2	3.3	-2.6	(22)	
	5%	DB	-3.8	-1.9	3.6	14.0	21.9	25.7	25.7	24.3	18.5	10.8	3.5	-2.2	(23)	
		MCWB	-5.3	-3.6	0.7	7.6	12.9	17.1	18.6	17.4	12.5	7.0	1.1	-3.8	(24)	
	10%	DB	-6.3	-4.1	1.9	11.1	19.2	23.9	24.2	22.1	16.0	8.6	1.4	-4.0	(25)	
		MCWB	-7.6	-5.7	-0.5	5.9	11.7	16.3	17.8	16.5	11.4	5.5	-0.4	-5.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.8	-0.4	4.8	11.6	17.7	20.4	22.0	21.3	16.4	10.8	5.9	-0.4	(27)	
		MCDB	1.2	1.4	8.8	18.6	26.1	26.9	27.3	27.0	23.4	15.5	9.0	1.8	(28)	
	2%	WB	-3.1	-2.2	2.4	9.7	15.1	19.1	20.4	19.5	14.7	8.8	3.3	-2.4	(29)	
		MCDB	-1.6	-0.3	5.2	15.5	21.9	25.1	25.2	25.0	19.9	12.5	5.9	-1.0	(30)	
	5%	WB	-5.3	-3.7	0.9	8.0	13.7	18.1	19.5	18.2	13.2	7.2	1.3	-3.8	(31)	
		MCDB	-3.8	-1.9	3.4	13.8	20.2	24.0	24.2	22.8	17.6	10.7	3.1	-2.2	(32)	
	10%	WB	-7.5	-5.7	-0.4	6.1	12.3	17.1	18.6	17.0	11.7	5.7	-0.3	-5.5	(33)	
		MCDB	-6.3	-4.2	1.8	10.8	18.3	22.4	23.0	21.5	15.6	8.4	1.4	-4.1	(34)	
(35) Mean Daily Temperature Range	MDBR		8.3	9.9	10.8	10.6	11.6	11.5	10.5	10.9	10.3	8.2	7.5	7.9	(35)	
	5% DB	MCDBR	8.5	9.3	10.5	16.3	17.4	15.8	13.7	15.4	16.0	12.5	7.8	7.8	(36)	
		MCWBR	7.3	8.0	7.7	9.2	9.1	7.4	6.7	7.8	8.9	7.9	5.8	6.8	(37)	
	5% WB	MCDBR	8.2	9.3	10.4	15.3	15.0	12.9	11.7	13.2	14.2	11.9	7.4	7.8	(38)	
		MCWBR	7.1	7.9	7.9	9.1	8.3	6.7	6.4	7.2	8.2	7.7	5.6	6.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.269	0.304	0.352	0.393	0.402	0.400	0.423	0.406	0.366	0.342	0.303	0.270	(40)	
	taud		2.057	2.032	1.968	2.117	2.204	2.306	2.242	2.260	2.319	2.244	2.071	1.991	(41)	
	Ebn at Noon		628	742	790	822	839	846	814	803	787	701	566	511	(42)	
	Edh at Noon		66	99	135	135	132	121	127	117	96	81	65	56	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.85	1.84	3.27	4.47	4.99	5.83	5.19	4.26	2.85	1.52	0.76	0.54	(44)	
	RadStd		0.09	0.16	0.26	0.26	0.57	0.53	0.34	0.39	0.33	0.15	0.10	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page