

NENASTNAYA PRIISKOVOYE, Russian Federation

WMO: 297520

Lat: 54.6581N

Lon: 88.6798E

Elev: 3898

StdP: 12.74

Time Zone: 7.00 (E07)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.2	-17.1	-26.8	1.4	-18.1	-23.1	1.8	-14.1	29.7	1.6	27.4	4.4	7.8	250	0.725

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	73.3	58.7	70.2	57.5	67.4	56.2	60.7	69.6	59.2	67.4	57.8	65.0	4.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.5	81.5	63.6	55.9	77.0	62.2	54.6	73.3	61.3	28.8	69.6	27.7	67.6	26.7	65.2	65.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.0	21.2	18.6	DB	-24.4	78.8	6.4	3.6	-29.0	81.4	-32.8	83.5	-36.4	85.5	-41.1	88.1	(4)
(5)			WB	-24.6	63.8	6.3	1.8	-29.2	65.2	-32.9	66.3	-36.5	67.3	-41.1	68.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	30.2	4.7	7.7	19.8	32.1	38.7	54.4	56.6	53.6	42.2	29.0	13.3	8.7		
	DBStd	20.92	10.98	11.55	10.30	10.22	9.63	8.50	5.99	6.60	9.69	11.25	11.64	11.50		
	HDD50	7851	1405	1184	935	541	371	55	13	36	274	656	1100	1281		
	HDD65	12721	1870	1604	1400	987	815	325	267	356	686	1115	1550	1746		
	CDD50	622	0	0	0	4	21	188	218	147	39	5	0	0		
	CDD65	18	0	0	0	0	0	7	7	3	1	0	0	0		
	CDH74	68	0	0	0	0	0	27	27	10	4	0	0	0		
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0		
	WSAvg	7.7	9.9	8.9	9.3	7.8	6.7	4.7	4.0	4.5	6.1	8.4	11.2	11.0		
	PrecAvg	58.9	3.9	3.3	4.3	4.7	4.7	4.6	4.4	5.0	5.2	6.9	6.3	5.6		
(15) Precipitation	PrecMax	71.4	10.0	7.4	9.5	11.8	10.9	7.8	7.2	12.3	9.5	11.7	10.3	10.4		
	PrecMin	45.9	0.4	0.4	1.6	1.5	0.9	1.9	2.4	1.4	0.8	3.3	4.0	1.9		
	PrecStd	7.1	2.1	1.6	2.0	2.1	2.5	1.5	1.3	2.2	2.1	2.1	1.7	2.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.6	34.2	52.1	62.9	67.6	77.7	77.7	75.4	71.4	60.0	43.3	33.5		
		MCWB	25.0	28.8	38.6	48.6	50.6	60.7	61.3	59.2	54.0	45.7	36.5	27.1		
	2%	DB	25.7	28.8	44.6	55.5	61.8	73.5	72.5	70.7	65.5	54.6	37.2	29.4		
		MCWB	21.5	23.5	34.6	44.0	47.7	58.5	59.3	57.9	51.7	42.3	30.8	24.3		
	5%	DB	22.4	25.6	38.7	51.0	57.3	70.2	69.2	67.3	60.5	50.8	32.5	26.1		
		MCWB	18.5	21.6	31.6	40.7	45.6	57.4	58.4	57.0	49.5	41.1	28.6	22.1		
	10%	DB	19.0	22.5	34.0	46.9	53.7	67.2	65.9	63.8	55.8	45.1	28.2	23.3		
		MCWB	16.5	19.5	28.3	39.0	43.3	55.8	57.1	55.5	47.2	38.6	25.2	20.3		
	0.4%	WB	26.5	30.0	40.2	48.7	52.9	63.0	62.9	62.3	56.3	47.6	39.5	28.5		
		MCDB	29.9	33.8	51.1	62.3	63.1	73.9	72.0	69.7	69.4	55.8	43.1	32.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	22.0	24.4	35.5	44.8	49.6	60.3	60.8	59.6	52.9	44.4	32.0	25.2		
		MCDB	25.5	27.6	43.7	53.2	58.9	70.2	69.6	67.0	62.7	52.3	35.6	27.9		
	5%	WB	18.7	21.9	31.9	42.1	47.2	58.7	59.3	57.9	50.5	41.8	29.1	22.8		
		MCDB	21.6	25.0	37.5	49.1	54.4	67.5	67.1	64.8	57.9	48.6	32.9	25.7		
	10%	WB	16.3	19.5	28.8	39.5	44.9	57.0	58.0	56.5	48.3	39.0	25.6	20.3		
		MCDB	19.1	22.6	33.7	46.0	52.3	65.0	64.7	62.5	53.9	45.0	27.5	23.2		
	5% DB	MDBR	12.4	14.3	15.8	14.6	12.7	13.7	12.0	12.0	11.7	9.8	10.8	10.6		
		MCDBR	15.8	17.8	22.6	19.2	16.2	17.6	16.0	16.9	17.7	14.6	12.3	12.9		
		MCWBR	12.6	14.3	15.8	11.9	9.1	9.1	7.9	8.1	9.1	8.2	9.0	10.2		
		MCWBR	15.1	17.3	20.8	18.6	14.9	15.6	13.8	13.9	15.6	13.6	11.5	12.3		
(35) Mean Daily Temperature Range	5% WB	MCWBR	12.5	14.2	14.8	12.2	9.7	8.7	7.6	7.6	8.5	8.7	9.2	10.3		
	Clear-Sky Solar Irradiance	taub	0.245	0.278	0.320	0.356	0.364	0.361	0.376	0.364	0.332	0.312	0.274	0.246		
		taud	2.104	2.085	2.022	2.108	2.276	2.389	2.351	2.365	2.413	2.307	2.092	2.027		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	220	252	266	273	279	281	273	270	265	239	200	185		
		Edh at Noon	20	30	41	43	39	35	36	34	28	24	21	17		
(44) All-Sky Solar Radiation	RadStd		286	597	1034	1413	1606	1815	1611	1345	918	496	259	181		
			35	56	83	81	198	174	112	130	109	53	39	25		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (13 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page