

VERKHNYAYA GUTARA, Russian Federation

WMO: 297890

Lat: 54.2129N

Lon: 96.9693E

Elev: 984

StdP: 90.05

Time Zone: 8.00 (E08)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -36.5	(c) -34.1	(d) -37.9	(e) 0.1	(f) -36.3	(g) -35.4	(h) 0.1	(i) -34.1	(j) 5.0	(k) -12.4	(l) 4.4	(m) -11.2	(n) 0.1	(o) 200	(p) 0.679

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 12.3	(c) 26.5	(d) 15.9	(e) 24.5	(f) 15.4	(g) 22.4	(h) 14.5	(i) 17.6	(j) 23.5	(k) 16.6	(l) 22.1	(m) 15.6	(n) 20.7	(o) 1.2	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.6	12.5	19.5	14.6	11.7	18.3	13.6	11.0	17.3	53.7	23.6	50.5	22.1	47.4	20.8	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4.3	3.4	2.8	-39.4	30.8	3.5	1.7	-42.0	32.0	-44.0	33.0	-46.0	33.9	-48.6	35.1
			-39.4	19.4	3.5	1.0	-42.0	20.1	-44.0	20.7	-46.0	21.3	-48.5	22.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.5	-19.0	-15.9	-7.9	-0.3	5.3	12.2	14.7	12.7	6.7	-1.2	-10.2	-16.1		
	DBStd	12.80	6.90	6.86	6.09	5.46	4.06	3.81	2.69	3.23	3.98	5.28	6.99	7.41		
	HDD10.0	4556	899	725	556	308	154	22	2	12	115	346	607	809		
	HDD18.3	7249	1158	958	814	558	406	185	114	177	350	604	857	1067		
	CDD10.0	353	0	0	0	0	7	88	148	94	15	0	0	0		
	CDD18.3	4	0	0	0	0	0	1	2	1	0	0	0	0		
	CDH23.3	301	0	0	0	0	7	109	104	71	10	0	0	0		
	CDH26.7	53	0	0	0	0	0	19	17	15	1	0	0	0		
(14) Wind	WSAvg	0.8	0.6	0.8	1.0	1.0	1.1	0.7	0.6	0.5	0.7	0.8	0.8	0.8		
(15) Precipitation	PrecAvg	517	4	5	7	30	47	77	141	107	56	22	9	6		
	PrecMax	802	18	55	25	84	131	126	266	226	164	45	21	18		
	PrecMin	387	0	0	1	10	4	25	68	30	11	5	0	1		
	PrecStd	81	3	9	4	17	22	28	46	43	27	10	5	4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.1	3.1	10.8	18.8	24.3	29.2	28.8	29.0	24.9	16.4	7.1	2.1		
		MCWB	-3.0	-1.0	3.8	8.0	12.4	16.1	17.3	16.8	13.6	7.7	2.7	-1.4		
	2%	DB	-2.9	-0.3	7.7	14.7	21.0	26.3	26.0	25.3	20.9	12.5	4.3	-1.7		
		MCWB	-5.2	-3.4	2.4	6.3	10.5	15.0	17.0	15.7	12.2	6.1	0.7	-4.3		
	5%	DB	-5.6	-2.7	4.8	12.0	18.0	24.2	24.0	22.3	17.7	9.3	1.9	-3.6		
		MCWB	-7.4	-5.0	0.5	4.8	8.9	14.5	16.4	15.1	10.5	4.3	-0.5	-5.7		
	10%	DB	-8.4	-5.0	2.3	9.3	15.0	21.7	21.8	19.7	14.6	6.5	-0.6	-5.3		
		MCWB	-9.8	-6.8	-1.1	3.6	7.5	13.6	15.6	14.2	9.4	2.6	-2.8	-7.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.1	-0.8	4.6	8.7	12.9	18.0	19.2	18.1	14.8	8.2	3.0	-0.9		
		MCDB	-0.3	2.7	10.1	16.5	23.0	25.1	24.4	24.4	21.8	15.3	6.7	1.7		
	2%	WB	-5.1	-3.2	2.4	6.7	11.1	16.6	18.0	17.0	12.9	6.4	1.2	-4.0		
		MCDB	-2.9	-0.7	7.5	13.3	19.5	22.8	23.8	23.1	19.1	11.9	3.9	-2.3		
	5%	WB	-7.4	-4.9	0.6	5.2	9.4	15.5	17.1	15.7	11.3	4.7	-0.6	-5.6		
		MCDB	-5.7	-2.7	4.5	11.2	16.5	21.9	22.4	21.2	16.3	9.0	2.0	-3.7		
	10%	WB	-9.8	-6.8	-1.1	3.9	7.9	14.5	16.1	14.5	9.7	2.9	-2.6	-7.0		
		MCDB	-8.5	-5.0	2.1	9.0	14.3	20.4	20.9	19.1	14.0	6.2	-0.8	-5.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.2	15.5	15.8	13.4	13.5	14.4	12.3	12.1	13.4	12.1	11.3	11.3		
		MCDBR	14.7	16.5	18.2	18.8	21.5	20.7	17.6	18.3	20.4	17.4	12.0	11.5		
		MCWBR	12.6	13.5	13.0	10.6	11.1	10.1	9.0	9.3	11.2	10.4	8.7	9.6		
		MCDBR	14.4	15.9	17.3	16.5	19.2	16.7	14.6	15.6	17.7	16.7	11.5	11.5		
	5% WB	MCWBR	12.4	13.0	12.4	9.7	10.3	8.8	8.2	8.6	10.0	10.2	8.5	9.7		
(40) Clear-Sky Solar Irradiance	taub		0.255	0.289	0.331	0.371	0.389	0.380	0.391	0.371	0.332	0.309	0.283	0.257		
	taud		2.112	2.088	2.059	2.104	2.179	2.351	2.350	2.373	2.432	2.325	2.126	2.049		
	Ebn at Noon		689	785	830	848	855	868	850	846	840	767	635	582		
	Edh at Noon		65	96	125	138	136	116	114	105	87	76	65	57		
(44) All-Sky Solar Radiation	RadAvg		0.98	1.96	3.32	4.50	4.90	5.37	4.92	4.20	3.00	1.76	0.94	0.66		
	RadStd		0.10	0.16	0.23	0.21	0.45	0.50	0.43	0.34	0.34	0.16	0.11	0.06		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	-0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page