

DIKIMYDA, Russian Federation

WMO: 300890

Lat: 61.950N

Lon: 126.617E

Elev: 576

StdP: 14.39

Time Zone: 9.00 (E09)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-53.7	-50.8	-56.6	0.2	-53.4	-53.8	0.2	-50.6	10.0	3.0	7.4	-2.8	0.0	90	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.8	86.9	66.9	83.1	65.4	79.1	63.8	69.8	82.1	67.6	78.9	65.5	75.8	5.7	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.7	97.0	74.9	63.6	89.9	72.4	61.6	83.6	70.0	34.3	82.4	32.5	79.0	30.7	75.9	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	12.8	9.7	DB	-56.3	92.6	2.1	3.6	-57.8	95.1	-59.0	97.2	-60.2	99.2	-61.6	101.8	(4)
(5)			WB	-56.3	73.7	2.1	2.1	-57.8	75.2	-59.0	76.4	-60.2	77.6	-61.6	79.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	-27.4	-17.7	4.5	27.6	45.3	59.8	64.1	59.1	43.4	24.0	-5.8	-24.2
	DBStd	34.72	14.82	14.23	15.42	10.39	6.66	6.45	6.34	6.45	6.97	11.23	16.60	15.58
	HDD50	11574	2399	1896	1412	673	178	7	1	9	218	806	1675	2300
	HDD65	16074	2864	2316	1877	1123	612	176	95	203	647	1271	2125	2765
	CDD50	1082	0	0	0	0	32	301	438	290	21	0	0	0
	CDD65	106	0	0	0	0	0	20	67	19	0	0	0	0
	CDH74	2046	0	0	0	0	45	569	1043	386	3	0	0	0
	CDH80	668	0	0	0	0	8	161	389	110	0	0	0	0
Wind	WSAvg	2.8	0.6	1.3	3.0	4.3	4.8	3.9	3.6	3.3	3.4	3.3	1.7	0.7
Precipitation	PrecAvg	15.9	0.6	0.5	0.5	0.7	1.7	2.0	2.8	2.4	2.0	1.4	0.9	0.6
	PrecMax	22.0	1.2	1.3	1.0	1.8	3.0	3.8	6.4	6.9	4.3	2.7	2.1	1.3
	PrecMin	11.2	0.2	0.1	0.1	0.2	0.4	0.6	1.1	0.3	0.4	0.6	0.4	0.2
	PrecStd	2.6	0.2	0.2	0.2	0.3	0.7	0.7	1.1	1.2	0.8	0.5	0.4	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	23.4	47.9	61.4	80.1	89.6	93.0	88.5	73.1	50.4	39.6	20.4
		MCWB	11.7	21.0	37.1	45.2	57.1	65.8	70.1	66.3	58.7	42.8	34.7	19.2
	2%	DB	6.4	17.2	39.5	55.5	71.8	84.7	88.6	83.2	65.4	45.2	31.6	13.4
		MCWB	5.5	15.7	32.1	42.2	52.7	64.2	69.3	65.8	53.6	39.9	29.5	12.5
	5%	DB	1.5	10.1	34.3	50.9	66.9	80.9	84.5	78.5	60.0	42.1	25.1	7.8
		MCWB	0.7	8.7	28.9	40.0	50.5	63.2	67.2	64.7	51.1	37.5	23.3	7.1
	10%	DB	-3.8	4.6	29.8	46.1	61.7	76.8	80.3	73.7	56.1	38.7	18.7	0.5
		MCWB	-4.3	3.7	26.1	36.8	48.2	60.9	65.8	62.4	49.4	34.7	17.3	-0.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	21.0	38.1	45.9	58.5	69.3	73.1	70.8	60.0	44.5	36.4	18.9
		MCDB	13.2	23.2	47.5	58.3	77.7	82.4	86.3	81.8	70.6	48.8	39.8	20.1
	2%	WB	5.6	15.7	32.8	43.0	54.4	66.6	71.1	68.0	56.2	40.7	29.4	12.7
		MCDB	6.4	17.7	39.0	54.9	68.8	80.4	84.4	78.7	61.8	44.2	32.1	13.3
	5%	WB	0.7	8.7	29.2	40.3	51.9	64.7	69.0	65.6	52.9	38.2	23.5	7.1
		MCDB	1.4	10.0	33.8	49.8	63.6	77.8	81.0	75.4	58.2	41.7	25.4	7.7
	10%	WB	-4.3	3.6	26.0	37.4	49.5	62.6	67.0	63.5	49.9	34.9	17.3	0.0
		MCDB	-3.8	4.6	30.2	45.0	60.3	73.9	77.4	72.7	55.0	38.2	18.6	0.6
Mean Daily Temperature Range	5% DB	MDBR	16.7	24.7	33.0	28.7	25.0	27.2	24.8	24.9	20.6	16.5	16.6	14.9
		MCDBR	18.7	26.6	31.9	34.0	37.4	36.5	34.9	35.4	29.5	18.7	17.4	18.1
		MCWBR	17.8	24.6	25.0	21.3	19.6	17.3	16.7	19.3	18.1	13.2	15.1	17.4
	5% WB	MCDBR	18.8	26.4	30.2	31.0	32.0	31.9	29.6	29.7	25.2	17.3	17.1	17.7
		MCWBR	17.9	24.5	23.9	19.7	17.8	16.4	15.0	17.1	16.6	12.8	14.9	17.0
Clear-Sky Solar Irradiance	taub	0.220	0.260	0.298	0.350	0.407	0.418	0.531	0.508	0.364	0.285	0.221	0.190	
	taud	1.960	2.071	2.077	2.078	2.184	2.251	1.904	1.920	2.301	2.326	1.992	1.881	
	Ebn at Noon	144	220	253	262	256	256	217	208	231	214	140	93	
	Edh at Noon	12	23	33	41	41	39	54	49	27	18	11	7	
All-Sky Solar Radiation	RadAvg	115	438	998	1625	1658	1875	1697	1298	802	362	167	55	
	RadStd	7	17	32	65	121	123	103	89	92	39	12	2	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+1.35	N/A	N/A	N/A	N/A	N/A	-488	-493	N/A	N/A

Nomenclature: See separate page