

DIKIMYDA, Russian Federation

WMO: 300890

Lat: 61.950N

Lon: 126.617E

Elev: 175

StdP: 99.23

Time Zone: 9.00 (E09)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-47.6	-46.0	-49.2	0.0	-47.4	-47.7	0.0	-45.9	4.5	-16.1	3.3	-19.3	0.0	90	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	30.5	19.4	28.4	18.6	26.1	17.7	21.0	27.8	19.8	26.0	18.6	24.3	2.5	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.9	23.8	17.6	12.8	22.4	16.4	11.9	21.1	61.9	28.0	57.6	26.1	53.6	24.4	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	5.7	4.4	DB	-49.1	33.7	1.1	2.0	-49.9	35.1	-50.6	36.2	-51.2	37.4	-52.0	38.8	(4)
(5)			WB	-49.1	23.2	1.1	1.2	-49.9	24.0	-50.6	24.7	-51.2	25.3	-52.0	26.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-6.0	-33.0	-27.6	-15.3	-2.5	7.4	15.4	17.8	15.0	6.4	-4.4	-21.0	-31.2	(6)	
	DBStd	19.29	8.23	7.91	8.57	5.77	3.70	3.58	3.52	3.58	3.87	6.24	9.22	8.65	(7)	
	HDD10.0	6430	1333	1053	784	374	99	4	1	5	121	448	931	1278	(8)	
	HDD18.3	8930	1591	1287	1043	624	340	98	53	113	359	706	1181	1536	(9)	
	CDD10.0	601	0	0	0	0	18	167	243	161	12	0	0	0	(10)	
	CDD18.3	59	0	0	0	0	0	11	37	11	0	0	0	0	(11)	
	CDH23.3	1137	0	0	0	0	25	316	579	214	2	0	0	0	(12)	
	CDH26.7	371	0	0	0	0	4	89	216	61	0	0	0	0	(13)	
(14) Wind	WSAvg	1.3	0.3	0.6	1.3	1.9	2.1	1.7	1.6	1.5	1.5	1.5	0.7	0.3	(14)	
(15) Precipitation	PrecAvg	405	14	12	12	18	43	51	70	62	50	35	24	16	(15)	
	PrecMax	560	30	32	25	45	77	97	163	175	110	68	54	34	(16)	
	PrecMin	284	5	2	3	6	10	15	28	8	11	14	9	6	(17)	
	PrecStd	66	6	6	5	8	18	19	29	30	21	12	11	6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-10.5	-4.8	8.8	16.3	26.7	32.0	33.9	31.4	22.8	10.2	4.2	-6.5	(19)	
		MCWB	-11.3	-6.1	2.8	7.4	13.9	18.8	21.2	19.0	14.8	6.0	1.5	-7.1	(20)	
	2%	DB	-14.2	-8.2	4.2	13.0	22.1	29.3	31.5	28.4	18.5	7.3	-0.2	-10.3	(21)	
		MCWB	-14.7	-9.1	0.1	5.7	11.5	17.9	20.7	18.8	12.0	4.4	-1.4	-10.8	(22)	
	5%	DB	-17.0	-12.2	1.3	10.5	19.4	27.2	29.1	25.8	15.6	5.6	-3.8	-13.4	(23)	
		MCWB	-17.4	-12.9	-1.7	4.4	10.3	17.3	19.6	18.2	10.6	3.1	-4.9	-13.8	(24)	
	10%	DB	-19.9	-15.2	-1.2	7.8	16.5	24.9	26.8	23.2	13.4	3.7	-7.4	-17.5	(25)	
		MCWB	-20.2	-15.7	-3.3	2.7	9.0	16.1	18.8	16.9	9.6	1.5	-8.1	-17.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-11.2	-6.1	3.4	7.7	14.7	20.7	22.8	21.5	15.5	6.9	2.4	-7.3	(27)	
		MCDB	-10.4	-4.9	8.6	14.6	25.4	28.0	30.2	27.7	21.4	9.3	4.3	-6.6	(28)	
	2%	WB	-14.7	-9.1	0.5	6.1	12.4	19.2	21.7	20.0	13.4	4.8	-1.5	-10.7	(29)	
		MCDB	-14.2	-7.9	3.9	12.7	20.4	26.9	29.1	25.9	16.5	6.8	0.0	-10.4	(30)	
	5%	WB	-17.4	-12.9	-1.5	4.6	11.1	18.2	20.6	18.7	11.6	3.4	-4.7	-13.8	(31)	
		MCDB	-17.0	-12.2	1.0	9.9	17.6	25.5	27.2	24.1	14.5	5.4	-3.7	-13.5	(32)	
	10%	WB	-20.2	-15.8	-3.3	3.0	9.7	17.0	19.4	17.5	10.0	1.6	-8.2	-17.8	(33)	
		MCDB	-19.9	-15.2	-1.0	7.2	15.7	23.3	25.2	22.6	12.8	3.4	-7.4	-17.5	(34)	
(35) Mean Daily Temperature Range	MDBR		9.3	13.7	18.4	15.9	13.9	15.1	13.8	13.9	11.5	9.2	9.2	8.3	(35)	
	5% DB	MCDBR	10.4	14.8	17.7	18.9	20.8	20.3	19.4	19.7	16.4	10.4	9.6	10.0	(36)	
		MCWBR	9.9	13.7	13.9	11.8	10.9	9.6	9.3	10.7	10.0	7.4	8.4	9.7	(37)	
	5% WB	MCDBR	10.4	14.7	16.8	17.2	17.8	17.7	16.5	16.5	14.0	9.6	9.5	9.8	(38)	
		MCWBR	9.9	13.6	13.3	10.9	9.9	9.1	8.3	9.5	9.2	7.1	8.3	9.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.220	0.260	0.298	0.350	0.407	0.418	0.531	0.508	0.364	0.285	0.221	0.190	(40)	
	taud		1.960	2.071	2.077	2.078	2.184	2.251	1.904	1.920	2.301	2.326	1.992	1.881	(41)	
	Ebn at Noon		454	694	799	826	807	806	685	657	728	676	441	294	(42)	
	Edh at Noon		39	72	104	129	128	122	169	153	86	56	36	23	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.36	1.38	3.15	5.12	5.23	5.91	5.35	4.09	2.53	1.14	0.53	0.17	(44)	
	RadStd		0.02	0.05	0.10	0.21	0.38	0.39	0.33	0.28	0.29	0.12	0.04	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.75	N/A	N/A	N/A	N/A	N/A	-271	-274	N/A	N/A

Nomenclature: See separate page