

MAMA, Russian Federation

WMO: 301570

Lat: 58.313N

Lon: 112.890E

Elev: 224

StdP: 98.66

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-42.7	-40.7	-44.8	0.0	-42.4	-42.9	0.1	-40.4	8.5	-19.4	7.5	-21.3	1.1	120	0.678

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	30.2	19.4	27.9	18.8	25.8	17.9	21.1	27.3	20.0	25.7	18.9	24.2	2.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.3	23.7	18.0	13.3	22.5	16.9	12.4	21.5	62.5	27.5	58.5	25.7	55.1	24.4	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.5	5.7	DB	-44.4	33.9	3.1	1.4	-46.6	34.9	-48.4	35.7	-50.2	36.5	-52.4	37.5	(4)
(5)			WB	-44.2	23.6	2.9	1.5	-46.2	24.6	-47.9	25.5	-49.5	26.3	-51.6	27.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.2	-27.4	-21.3	-11.5	-0.5	7.3	15.9	19.0	15.8	7.3	-2.3	-16.2	-26.1	(6)	
	DBStd	17.33	8.63	8.18	7.66	4.74	3.92	4.10	3.28	3.53	3.90	5.22	9.06	8.71	(7)	
	HDD10.0	5514	1158	876	668	316	104	4	0	3	99	381	786	1119	(8)	
	HDD18.3	7963	1417	1109	926	566	343	95	32	93	331	639	1036	1378	(9)	
	CDD10.0	682	0	0	0	0	19	181	281	183	18	0	0	0	(10)	
	CDD18.3	88	0	0	0	0	0	21	53	14	0	0	0	0	(11)	
	CDH23.3	1061	0	0	0	0	15	349	556	139	2	0	0	0	(12)	
	CDH26.7	326	0	0	0	0	3	108	187	28	0	0	0	0	(13)	
	Wind	WSAvg	2.3	2.3	2.1	2.3	2.6	2.6	2.3	2.0	2.1	2.4	2.5	2.3	(14)	
(15) Precipitation	PrecAvg	556	28	24	23	28	41	63	67	72	67	60	50	34	(15)	
	PrecMax	702	69	46	52	58	106	144	152	143	109	168	148	69	(16)	
	PrecMin	453	12	9	5	12	20	26	24	24	25	14	21	12	(17)	
	PrecStd	62	14	10	11	12	20	24	32	27	21	36	26	13	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-4.7	-1.1	7.2	15.3	25.2	32.4	33.4	29.5	21.9	10.0	3.7	-3.7	(19)	
		MCWB	-5.8	-2.7	2.2	7.4	14.1	19.7	21.2	20.1	15.7	6.0	1.9	-4.7	(20)	
	2%	DB	-8.7	-3.4	3.2	12.0	21.5	29.9	31.0	26.9	17.9	7.5	1.6	-7.0	(21)	
		MCWB	-9.5	-4.8	-0.2	5.4	12.0	18.3	20.3	18.8	12.5	4.4	0.6	-7.7	(22)	
	5%	DB	-12.4	-6.4	1.1	9.0	18.5	27.3	28.7	24.6	15.4	5.5	-0.6	-10.7	(23)	
		MCWB	-13.1	-7.5	-1.4	3.7	10.2	17.7	19.6	18.0	11.5	3.5	-1.6	-11.3	(24)	
	10%	DB	-15.3	-9.7	-0.8	6.5	15.7	25.0	26.5	22.3	13.4	4.1	-3.8	-13.7	(25)	
		MCWB	-15.8	-10.5	-3.1	2.3	8.8	16.7	19.0	16.8	10.3	2.4	-4.7	-14.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-5.8	-2.4	2.2	7.9	14.8	21.7	23.0	21.7	16.3	7.1	2.6	-4.6	(27)	
		MCDB	-4.8	-1.2	6.4	14.0	24.0	28.5	29.5	27.4	20.0	9.3	3.3	-3.8	(28)	
	2%	WB	-9.4	-4.7	0.4	5.9	12.6	19.9	21.6	20.0	13.8	5.2	0.7	-7.7	(29)	
		MCDB	-8.6	-3.4	2.7	11.1	20.0	26.9	27.9	24.7	16.7	6.5	1.5	-7.0	(30)	
	5%	WB	-13.1	-7.5	-1.3	4.2	10.7	18.6	20.6	18.8	12.1	3.8	-1.7	-11.2	(31)	
		MCDB	-12.5	-6.4	1.2	8.3	17.2	25.3	26.5	23.0	14.6	5.2	-0.7	-10.6	(32)	
	10%	WB	-15.8	-10.4	-3.1	2.7	9.2	17.4	19.6	17.6	10.7	2.4	-4.7	-14.3	(33)	
		MCDB	-15.4	-9.6	-0.9	5.9	15.1	23.6	25.2	21.4	12.9	3.9	-3.9	-13.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.5	9.2	12.8	10.7	11.9	13.5	12.0	10.5	8.2	5.9	6.2	5.9	(35)	
		MCDBR	8.3	9.2	11.7	14.1	18.2	19.1	17.4	15.3	12.5	7.5	6.4	8.4	(36)	
		MCWBR	7.7	7.9	8.8	8.1	9.3	8.8	7.6	7.5	7.1	5.0	5.4	7.9	(37)	
	5% WB	MCDBR	8.2	8.9	11.5	13.1	16.6	16.0	14.5	13.0	10.7	6.8	5.9	8.3	(38)	
		MCWBR	7.7	7.9	8.8	7.8	9.0	7.9	7.1	6.9	6.4	4.9	5.2	7.8	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.269	0.306	0.327	0.365	0.404	0.443	0.460	0.417	0.350	0.310	0.274	0.252	(40)	
	taud		1.961	1.962	1.999	2.005	2.118	2.197	2.180	2.280	2.409	2.260	2.002	1.930	(41)	
	Ebn at Noon		517	681	794	829	824	795	769	779	787	698	504	404	(42)	
	Edh at Noon		59	96	123	146	140	132	132	111	84	71	55	43	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.63	1.55	3.14	4.69	5.27	5.49	5.02	4.02	2.41	1.21	0.68	0.39	(44)	
	RadStd		0.05	0.12	0.23	0.26	0.36	0.52	0.54	0.37	0.26	0.17	0.10	0.04	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page