

UST'-NYUKZHA, Russian Federation

WMO: 303850

Lat: 56.560N

Lon: 121.591E

Elev: 1396

StdP: 13.97

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-43.0	-39.4	-46.3	0.4	-42.6	-42.7	0.5	-39.1	10.5	-13.7	7.9	-14.2	0.3	340	0.629

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	84.7	66.2	81.2	65.0	77.4	63.4	68.9	80.1	66.9	77.5	65.1	74.4	1.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	97.8	73.2	63.3	91.7	71.4	61.5	85.9	69.8	34.0	79.9	32.4	77.9	31.0	74.6	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	7.8	6.4	5.1	DB	-46.9	90.9	4.2	2.8	-50.0	92.9	-52.4	94.6	-54.8	96.2	-57.8	98.2
(5)				WB	-46.8	73.1	4.0	2.4	-49.7	74.8	-52.0	76.2	-54.3	77.5	-57.2	79.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.6	-22.2	-10.6	8.3	29.6	45.6	60.5	65.2	60.3	45.1	24.9	-3.3	-22.0	(6)
(7)		DBStd	32.57	9.46	9.38	11.17	8.44	7.25	6.85	5.78	6.65	7.45	10.05	13.01	10.02	(7)
(8)		HDD50	10825	2239	1696	1292	613	176	8	1	7	184	777	1599	2233	(8)
(9)		HDD65	15232	2704	2116	1757	1063	602	163	68	173	597	1242	2049	2698	(9)
(10)		CDD50	1198	0	0	0	0	39	324	472	326	37	0	0	0	(10)
(11)		CDD65	130	0	0	0	0	0	29	74	27	0	0	0	0	(11)
(12)		CDH74	1610	0	0	0	0	25	487	766	326	6	0	0	0	(12)
(13)		CDH80	430	0	0	0	0	5	137	221	67	0	0	0	0	(13)
(14)	Wind	WSAvg	1.1	0.9	0.8	1.1	1.6	1.7	1.2	1.0	0.9	1.0	1.1	0.8	0.9	(14)
(15)	Precipitation	PrecAvg	19.9	0.3	0.2	0.2	0.7	1.7	3.7	4.6	4.0	2.8	0.9	0.4	0.3	(15)
(16)		PrecMax	27.3	0.7	0.5	0.7	1.6	3.5	8.7	10.9	10.0	6.7	3.1	1.4	0.9	(16)
(17)		PrecMin	12.1	0.1	0.0	0.0	0.1	0.7	0.9	0.9	0.8	0.8	0.4	0.2	0.1	(17)
(18)		PrecStd	4.1	0.2	0.1	0.2	0.4	0.7	1.9	2.4	1.8	1.5	0.6	0.3	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	20.5	41.3	60.5	76.9	89.4	90.0	85.7	73.5	51.7	30.4	11.6	(19)
(20)		0.4%	MCWB	5.6	17.1	34.1	46.0	56.6	67.7	69.0	66.6	59.0	42.2	27.1	10.6	(20)
(21)		2%	DB	0.6	13.7	35.3	53.2	70.6	83.9	85.4	81.4	67.3	46.1	23.7	3.9	(21)
(22)		2%	MCWB	-0.5	11.5	29.3	41.5	53.6	64.2	67.1	65.4	55.1	38.3	21.4	2.7	(22)
(23)		5%	DB	-4.3	7.8	31.0	48.2	65.6	79.5	82.0	77.6	62.4	42.0	19.5	-3.7	(23)
(24)		5%	MCWB	-5.0	6.3	26.0	38.1	51.1	62.6	66.3	64.0	53.1	35.8	17.5	-4.4	(24)
(25)		10%	DB	-8.9	3.7	27.0	43.7	60.7	75.5	78.1	73.3	58.0	38.2	15.2	-8.5	(25)
(26)		10%	MCWB	-9.4	2.3	22.8	35.1	48.0	61.0	64.9	62.3	50.4	33.5	13.5	-9.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	17.1	34.0	47.9	58.2	70.5	72.1	69.8	60.9	42.6	27.8	10.4	(27)
(28)		0.4%	MCDWB	7.2	20.0	40.6	57.9	73.8	85.2	85.6	80.1	69.4	50.5	30.4	11.4	(28)
(29)		2%	WB	-0.4	11.3	29.6	41.8	54.8	67.1	69.6	67.4	57.2	39.2	21.6	2.6	(29)
(30)		2%	MCDWB	0.6	13.5	34.9	52.2	68.3	80.3	80.5	77.4	64.4	44.8	23.7	3.9	(30)
(31)		5%	WB	-5.1	6.4	26.1	38.7	52.0	64.5	67.7	65.5	54.0	36.4	17.6	-4.4	(31)
(32)		5%	MCDWB	-4.4	7.8	30.7	47.1	63.1	75.9	77.9	74.5	61.2	41.3	19.4	-3.9	(32)
(33)		10%	WB	-9.3	2.4	22.9	35.7	49.1	62.1	66.0	63.5	51.1	33.7	13.5	-8.9	(33)
(34)		10%	MCDWB	-8.8	3.7	26.9	42.8	58.8	72.3	75.9	71.1	56.7	37.9	15.2	-8.5	(34)
(35)	Mean Daily Temperature Range		MDBR	13.6	20.2	24.6	21.2	21.8	23.9	21.5	21.0	19.0	16.0	15.0	12.0	(35)
(36)		5% DB	MCDBR	15.1	22.4	25.6	27.1	32.5	32.6	29.4	29.1	27.5	19.8	16.9	14.7	(36)
(37)		5% DB	MCWBR	14.3	20.4	20.1	16.8	17.4	14.9	13.1	13.9	15.5	13.0	14.3	14.0	(37)
(38)		5% WB	MCDBR	15.0	22.1	25.1	25.2	29.2	28.0	24.6	24.7	24.4	18.6	16.6	14.7	(38)
(39)		5% WB	MCWBR	14.3	20.2	19.8	16.1	16.8	14.5	12.2	13.1	14.5	12.6	14.1	14.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.253	0.285	0.317	0.410	0.496	0.469	0.482	0.420	0.349	0.310	0.265	0.244	(40)	
(41)		taud	2.036	2.033	2.016	1.885	1.874	2.102	2.088	2.262	2.404	2.282	2.074	1.980	(41)	
(42)		Ebn at Noon	196	238	261	250	235	246	239	249	254	231	187	160	(42)	
(43)		Edh at Noon	19	30	40	53	58	47	47	36	27	23	18	16	(43)	
(44)	All-Sky Solar Radiation	RadAvg	251	561	1086	1620	1637	1716	1589	1315	900	560	306	172	(44)	
(45)		RadStd	15	28	59	85	156	136	137	112	86	37	17	11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	+3.01	+3.02	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page