

UAKIT, Russian Federation

WMO: 304550

Lat: 55.486N

Lon: 113.619E

Elev: 3597

StdP: 12.88

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-37.4	-33.8	-42.0	0.6	-36.9	-38.5	0.7	-33.4	22.3	0.3	18.6	-4.6	0.4	140	0.758

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	76.9	59.7	73.7	58.8	70.7	57.5	62.5	71.5	60.8	69.9	59.1	67.9	6.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.4	86.6	65.5	57.3	80.2	64.0	55.4	74.7	62.9	30.0	71.5	28.7	69.8	27.4	67.9	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.9	18.1	15.6	-42.1	82.7	4.5	2.8	-45.4	84.7	-48.0	86.3	-50.6	87.9	-53.9	89.9		
(5)			-42.2	66.3	4.5	2.6	-45.4	68.2	-48.1	69.7	-50.6	71.2	-53.8	73.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.7	-16.6	-8.7	5.6	23.7	39.9	54.6	59.3	54.3	40.7	21.9	-1.0	-15.4		
	DBStd	28.55	9.64	9.75	10.95	8.97	7.69	6.76	5.06	5.76	7.66	10.37	12.28	10.32		
	HDD50	10979	2064	1642	1376	790	324	33	4	27	291	871	1530	2027		
	HDD65	15818	2529	2062	1841	1240	778	315	185	332	728	1336	1980	2492		
	CDD50	647	0	0	0	0	11	170	292	161	13	0	0	0		
	CDD65	10	0	0	0	0	0	2	8	0	0	0	0	0		
	CDH74	249	0	0	0	0	5	81	133	30	0	0	0	0		
	CDH80	21	0	0	0	0	0	8	12	1	0	0	0	0		
(14) Wind	WSAvg	4.7	2.1	3.4	5.2	6.8	7.5	5.6	4.9	4.9	5.5	4.8	3.4	2.2		
(15) Precipitation	PrecAvg	15.2	0.1	0.1	0.2	0.6	1.2	2.9	3.6	3.7	1.7	0.5	0.3	0.2		
	PrecMax	20.9	0.4	0.3	0.3	1.7	3.7	6.9	7.6	7.2	4.6	2.0	1.0	0.7		
	PrecMin	6.9	0.0	0.0	0.0	0.1	0.2	0.9	0.9	1.0	0.5	0.0	0.1	0.0		
	PrecStd	3.6	0.1	0.1	0.1	0.4	0.8	1.6	1.6	1.7	0.9	0.4	0.2	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	21.5	38.6	54.0	71.3	80.5	81.7	77.9	69.5	49.5	35.3	17.0		
		MCWB	8.5	17.4	30.7	40.1	51.0	58.9	63.2	60.7	52.6	39.1	29.5	14.7		
	2%	DB	6.0	15.6	31.9	46.8	64.7	76.0	77.5	73.0	62.6	44.1	27.1	9.3		
		MCWB	4.1	12.7	25.9	36.1	47.6	57.9	61.1	58.8	50.1	36.0	23.5	7.6		
	5%	DB	1.3	10.6	27.1	42.3	59.5	72.6	74.6	69.5	57.8	39.9	21.0	4.1		
		MCWB	-0.1	8.4	22.0	33.1	44.9	56.7	59.9	57.1	47.5	33.1	18.7	2.5		
	10%	DB	-2.8	6.1	22.9	38.3	54.8	69.2	71.6	66.1	53.8	36.1	16.1	-0.6		
		MCWB	-3.9	4.4	18.7	30.8	42.3	55.4	59.2	55.1	45.2	30.6	14.1	-1.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	17.6	31.0	41.2	52.1	62.9	65.4	62.8	54.8	40.2	30.0	14.5		
		MCDB	11.0	21.3	38.0	53.2	69.5	72.4	75.3	70.9	65.0	48.6	34.7	16.5		
	2%	WB	4.2	12.7	25.9	36.8	48.6	60.2	63.4	60.4	51.6	36.5	23.3	7.6		
		MCDB	6.1	15.4	31.6	45.8	62.0	71.0	72.6	69.8	59.5	43.4	27.0	9.3		
	5%	WB	-0.1	8.5	22.1	33.8	45.8	58.3	61.9	58.6	48.9	33.5	18.7	2.6		
		MCDB	1.2	10.6	27.0	41.2	57.7	68.8	70.9	66.9	56.3	38.9	21.1	4.0		
	10%	WB	-3.9	4.4	18.7	31.0	43.1	56.6	60.4	57.0	46.1	30.9	14.2	-1.7		
		MCDB	-2.9	6.0	22.9	37.8	53.5	66.9	68.9	63.8	53.1	35.9	16.0	-0.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.5	18.4	21.6	19.6	19.1	21.6	20.3	19.9	18.2	17.5	15.5	13.2		
		MCDBR	16.7	21.6	24.2	24.4	28.9	29.1	27.2	26.7	25.7	20.6	18.3	17.5		
		MCWBR	15.3	18.8	18.8	15.8	15.5	14.1	13.0	13.7	14.3	13.7	15.3	16.0		
		MCDBR	16.6	21.5	24.2	23.0	26.7	23.9	22.3	21.7	23.6	19.4	18.2	17.2		
	5% WB	MCWBR	15.3	18.7	18.9	15.5	15.1	12.6	12.1	12.6	13.8	13.2	15.2	15.9		
(40) Clear-Sky Solar Irradiance	taub		0.223	0.253	0.278	0.332	0.391	0.413	0.387	0.359	0.309	0.266	0.236	0.214		
	taud		2.152	2.151	2.142	2.125	2.130	2.223	2.348	2.409	2.483	2.399	2.183	2.091		
	Ebn at Noon		229	263	283	280	269	264	269	271	273	259	219	200		
	Edh at Noon		18	27	35	42	45	42	36	32	25	21	17	15		
(44) All-Sky Solar Radiation	RadAvg		286	580	1074	1587	1795	1728	1615	1366	958	590	331	203		
	RadStd		14	28	50	74	122	98	151	107	70	41	20	13		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	-2.16	N/A	N/A	N/A	N/A	N/A	-5
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-5

Nomenclature: See separate page